



Operation data managing software

**PCWAY**

**User's Manual**

A solid black horizontal bar located directly beneath the "User's Manual" text.

PCWAY User's Manual  
ARCT1F392E-3 '07.6

## **Safety Precautions**

Read and understand this specifications, instruction manual, installation manual and catalog to make proper use of the product.

### **WARNING**

**If critical situations that could lead to user's death or serious injury is assumed by mishandling of the product:**

- Do not play the accompanying disk on an audio CD player or speakers of a personal computer.  
It could lead to the injury of your ears or the damage to the speakers due to megavolume.

### **TRADEMARKS and COPYRIGHT**

- You may use this software in accordance with the "Licensing terms for the software".
- This manual and its contents are copyrighted.
- You may not copy this manual,in whole or part,without written consent of Matsushita Electric Works,Ltd.
- Windows and Windows NT are registered trademarks of Microsoft Corporation in the United States and/or other countries.
- All other company names and product names are trademarks or registered trademarks of their respective owners.
- Matsushita Electric Works,Ltd. pursues a policy of continuous improvement of the Design and performance of its products, therefore,we reserve the right to change the manual/product without notice.

## **PREFACE**

We appreciate your purchase of our software product.

This "User's Manual" is published to tell beginners about setup and operating outline of the product.

Please understand a content of this booklet very well to use the product correctly.

In addition, see the online help of the product for details of the way of use.

### **Would you please...**

Tell us if you find something dubious or of errors in this manual despite our heed to publication of the booklet as possible.

# Table of Contents

<b>1. Installation of PCWAY .....</b>	<b>1-1</b>
1.1 System Configuration.....	1-2
1.2 Version Up from Ver1.** or Ver2.** .....	1-4
1.3 Installing .....	1-5
1.4 Verify the Installing .....	1-6
<b>2. Overview - PCWAY .....</b>	<b>2-1</b>
2.1 PCWAY Memory Area.....	2-2
2.1.1 Explanation on the Relay.....	2-2
2.1.2 Explanation on the Register.....	2-4
2.1.3 Explanation on the Event.....	2-5
2.1.4 Explanation on the Trigger and the "informing" .....	2-6
2.2 Basic operations of PCWAY .....	2-9
2.3 Basic Specifications .....	2-12
2.4 Module.....	2-13
2.5 Precautions.....	2-14
2.5.1 Operation Preferences .....	2-14
2.5.2 Operations of PCWAY .....	2-15
2.5.3 Trigger .....	2-16
2.5.4 Clipboard .....	2-17
2.5.5 Macro name .....	2-17
2.5.6 Special data register.....	2-17
2.5.7 About the file name of Microsoft® Excel .....	2-17
2.5.8 Application Startup .....	2-18
2.5.9 Export function of Each Registering Module.....	2-18
2.5.10 When you make the macro of the Microsoft® Excel .....	2-18
2.5.11 Others.....	2-18



### **3. Overview - HARDWARE.....3-1**

3.1 Overview on Hardware.....	3-2
3.2 When Connected by MEWNET-H.....	3-3
3.3 C-NET(RS232C) Connection.....	3-5
3.4 Modem (Up To 64 Remote Regions) .....	3-8
3.5 Modem (Over 65 Remote Regions) .....	3-15
3.6 Not Connect.....	3-16
3.7 Error Reception.....	3-17
3.8 Ethernet(Local/Remote) Connection.....	3-21
3.8.1 Ethernet (Local).....	3-22
3.8.2 Ethernet (Remote).....	3-24
3.9 USB (GT32) Connection.....	3-25

### **4. Basic Operations of PCWAY .....4-1**

4.1 Displaying and Operating PLC Data Information with Microsoft® Excel .....	4-2
4.1.1 Outline of the Basic Procedures.....	4-2
4.1.2 Setting the cell information .....	4-5
4.1.3 Copying and pasting the cell information.....	4-11
4.1.4 How to operate during the running of the monitoring .....	4-12
4.2 Saving PLC Information into the File .....	4-16
4.2.1 The file.....	4-16
4.2.2 Create a file and execute the processing .....	4-19
4.2.3 Displaying the file data onto the Microsoft® Excel sheet.....	4-22
4.3 Booting Microsoft® Excel Macros Automatically .....	4-25
4.3.1 What is a macro? .....	4-25
4.3.2 Creating the Macro .....	4-25
4.3.3 Register the macro which will start automatically .....	4-33
4.4 Turn on the Relay/Event at a Specified Time or at a Certain Interval .....	4-34
4.4.1 Turn the Relay and Event to On at the Specified Time of the Specified Day of the Week.....	4-34
4.4.2 Turn the Relay and Event to On at a Certain Interval.....	4-35
4.5 Playing the Sound.....	4-36
4.5.1 Procedures of the sound playing.....	4-36

4.5.2	Create the WAV file .....	4-36
4.5.3	Register at Sound Startup.....	4-36
4.6	Turn On the Event by the Changing of the Relay Information of the PLC..	4-37
4.6.1	Watch the changing of the relay.....	4-37
4.6.2	Have PCWAY recognize the relay which will be watched as the link relay.....	4-37
4.6.3	Perform the event startup .....	4-38
4.7	Managing the File .....	4-39
4.7.1	Manage the file with the generation of the accumulating file.....	4-39
4.7.2	Controlling Files Using the Microsoft® Excel Book Log .....	4-40
4.7.3	Saving Microsoft® Excel books as HTML.....	4-41
4.8	Using the Public Phone Line .....	4-42
4.8.1	The Difference between Less than 65 and 65 or More Remote Locations .....	4-42
4.8.2	When Thereare Less Than 65 Remote Regions .....	4-57
4.8.3	When There are More than 65 Remote Regions.....	4-71
4.9	Using the E-mail Function .....	4-84
4.9.1	Overview .....	4-84
4.9.2	Sending the Error Status Information to the PC and the Cellular Phone via E-mail .....	4-85
4.9.3	Sending Equipment Status Information Periodically to the PC and the Cellular Phone via E-mail .....	4-86
4.9.4	Inquiry on the Equipment Status from the PC and the Cellular Phone 4-87	

## **5. Operations From the PCWAY Menubar..... 5-1**

5.1	Cell Settings .....	5-2
5.1.1	Setting method .....	5-3
5.2	Delete Cell Settings .....	5-11
5.3	Copy Cell Settings .....	5-12
5.4	Paste Cell Settings .....	5-13
5.5	Set Cell Order .....	5-15
5.6	Run PCWAY .....	5-16
5.7	Exit PCWAY.....	5-17
5.8	Read PCWAY Settings Again.....	5-18

5.9 Start Monitor .....	5-19
5.10 Stop Monitor .....	5-20
5.11 Download Data .....	5-21
5.12 Update All Sheet Data.....	5-22
5.13 Update Active Sheet Data .....	5-23
5.14 Save Excel file .....	5-24
5.15 Save HTML File .....	5-25
5.16 Compile .....	5-26
5.17 Protecting the Sheet .....	5-27

## **6. Registering - Module .....6-1**

6.1 Setting Operation Preferences .....	6-2
6.2 Character Change.....	6-25
6.3 Message .....	6-31
6.4 Operation Formula .....	6-38
6.5 File Master.....	6-44
6.6 File Processing .....	6-50
6.7 File Trigger .....	6-57
6.8 Event Startup.....	6-62
6.9 Weekly Timer.....	6-67
6.10 Interval Timer.....	6-71
6.11 C-NET Settings.....	6-75
6.12 Auto Macro Startup .....	6-79
6.13 Sound Startup.....	6-83
6.14 Modem Support .....	6-88
6.15 Application Startup.....	6-97
6.16 Connection No. ....	6-101
6.17 Ethernet Remote.....	6-104
6.18 E-mail Setting .....	6-111

<b>7. Overview List for Reference .....</b>	<b>7-1</b>
7.1 Notation method of the Memory area in PCWAY .....	7-2
7.2 Use file name list .....	7-3
7.3 Incorporation macro name list .....	7-4
7.4 API Function for Event(V) Access .....	7-9
7.4.1 Obtaining the Status of the Specified Event Number (VC Function) .....	7-9
7.4.2 Obtaining the Status of the Specified Event Number (VB Function) .....	7-10
7.4.3 Changing the Status of the Specified Event Number (VC Function) .....	7-11
7.4.4 Changing the Status of the Specified Event Number (VB Function) .....	7-12
7.4.5 Obtaining the Status of All Events (VC Function) .....	7-14
7.5 Functions Upgraded in PCWAY Ver. 2.5 .....	7-15
7.5.1 PCWAY macro auto record .....	7-15
7.5.2 Available for WR, WX, WY and WL devices .....	7-15
7.5.3 Available for [Decimal point] ([Real number]) data .....	7-16
7.5.4 High-speed data communication .....	7-16
7.5.5 AND and OR with calculation functions .....	7-17
7.5.6 Saving Microsoft® Excel books as HTML .....	7-18
7.5.7 Enable/Disable selection for the connecting station No. during PCWAY monitoring .....	7-19
7.6 Upgrade items of Ver2.74 .....	7-20
<b>8. Appendix .....</b>	<b>8-1</b>
8.1 Applications .....	8-2
8.2 PCWAY Manager .....	8-3
8.3 PCWAY Utility .....	8-4
8.4 Concerning the copying of the system created with PCWAY .....	8-6
8.5 Back-up Utility .....	8-7
8.6 PCWAY Logger .....	8-9
8.7 Compatibility Between Each OS and Microsoft® Excel .....	8-17
8.8 Compatibility Between PCWAY and Each OS .....	8-18

## **Chapter 1**

---

### **Installation of PCWAY**

## 1.1 System Configuration

---

The matters which are listed here, are what you have to prepare for besides of what is available with the PCWAY package.

Before doing the installing, please be aware of what hardware and software you are using.

### [Hardware]

- **Personal computer**

Windows® 98/ Windows® Me or Windows NT® Ver4.0/ Windows® 2000/ Windows® XP/ Windows® Vista.

(MEWNET-H, only Windows® 98 can use.)

- **Display**

Use what is suitable for Windows® 98/ Windows® Me or Windows NT® Ver4.0/ Windows® 2000/ Windows® XP/ Windows® Vista.

- **Memory**

A personal computer over 64MB is necessary. (It depends on OS.)

- **Hard disk**

It is necessary to have free space of 130MB(MIN.)

It is necessary that you have enough free space left in accordance to the contents of what has been registered.

- **Floppy disk drive**

This is necessary when installing PCWAY.

- **Mouse**

You must prepare a mouse suitable for Windows® 98/ Windows® Me or Windows NT® Ver4.0/ Windows® 2000/ Windows® XP/ Windows® Vista.

- **Printer**

You must prepare a printer suitable for Windows® 98/ Windows® Me or Windows NT® (over Ver4.0)/ Windows® 2000/ Windows® XP/ Windows® Vista.

- **Key unit**

This is already included in the PCWAY package. Please attach this to either the printer port, the USB port, or the printer cable.

(the printer cable is indispensable according to the key unit type.)

- **PLC**

The programmable controller of our (FP series) make must be used.

- **Others**

The MEWNET-H board or modem is necessary according to the network type which will connect with the PLC.

## [Software]

- **Basic software**

Windows® 98/ Windows® Me or Windows NT® Ver4.0/ Windows® 2000/ Windows® XP/  
Windows® Vista

- **Microsoft® Excel**

PCWAY is an add-in software.

Therefore, it is necessary to have Microsoft® Excel 97(Ver8.0), Microsoft® Excel 2000,  
Microsoft® Excel Ver 2002, Microsoft® Excel Ver 2003, Microsoft® Excel Ver 2007 installed.

- **Others**

The MEWNET-H link software or the MEWNET-H setting software is necessary according to  
the network type which will connect with the PLC.

### Attachment of the key unit

The format of the connecting varies by the key unit type.

#### 1. IBM PC/AT compatible

##### Printer port direct connection type

Connection method : printer port of the personal  
computer - key unit Possible to  
connect the printer cable to the  
edge of the key unit.



#### 2. IBM PC/AT compatible

##### USB(Universal Serial Bus) port direct connection type

Connecting method : USB port of the personal  
computer - key unit  
The USB port is monopolized.  
The USB cable cannot be  
connected to the edge of the key  
unit.



### ◆ NOTE

This cannot be used unless there is the environment where the USB device can  
be used at the personal computer.

For further information, please refer to each of the manuals of the corresponding  
personal computer.

## 1.2 Version Up from Ver1.\*\* or Ver2.\*\*

---

Usually, when you installed PCWAY, PCWAY automatically converts to new files from the old files of PCWAY.

But, executes below when the work folder of PCWAY is 2 or more.

1. There is "W\_TCcvt.exe" in the new PCWAY install folder.  
Copy "W\_TCcvt.exe" to the work folders of the old version.
2. Execute "W\_TCcvt.exe" in the work folders of the old version.



## 1.3 Installing

---

1. Verify whether Windows® and Microsoft® Excel has been installed, or not.  
If Windows® and Microsoft® Excel has not been installed, please make sure that those are installed, before you install PCWAY.
2. Start Windows® operating system.
3. Set the PCWAY floppy disk no.1 in to the disk drive, and execute **setup.exe**.
4. When the program for the installing has started, follow the instructions which has been displayed on to the screen.



---

### ◆ NOTE

---


**Please make sure that you have filled-out the form which we have included in the package. This will be the user's card.  
Please send this back to our company after you have filled this out.**

## 1.4 Verify the Installing

1. When you have finished the installing procedures, the following “Groove” window will be displayed.



2. Start Microsoft® Excel and verify whether the PCWAY menu and PCWAY icons have been displayed, or not.



## Chapter 2

---

### Overview - PCWAY

## 2.1 PCWAY Memory Area

---

Here, we explain about the relay and the register of the PLC.

Also, we explain about the PCWAY event, and the trigger and the “informing” which takes place with the internal processing.

### 2.1.1 Explanation on the Relay

---

With PCWAY, the relay of the PLC is expressed as the "relay".

The acceptance of the usage of the relay and the possible range for the relay numbers for usage, varies by the PLC type which is adopted for use.

#### 1. X: External Input

X of PLC: External input

Only possible to READ.

#### 2. Y: External Output

Y of PLC: External output

Possible to READ and WRITE.

#### 3. R: Internal Relay

R of PLC: Internal relay and also the special internal relay concerning the internal relay, READ and Write is possible.

With the special internal relay, it is possible to only READ.

#### 4. T: Timer

T of PLC: Timer Relay

Only possible to READ. (Cannot WRITE)

#### 5. C: Counter

C of PLC: Counter Relay

Only possible to READ. (Cannot WRITE)

#### 6. L: Link Relay

L of PLC: Link relay

Possible to Read and WRITE.

## 7. M: Relay Link Area

This is the most important area used for the “trigger”(-introduced later on, in this manual). Only possible to READ.

- **When using the MEWNET-H link board.**  
When the relay link range has been set with the MEWNET-H Setting Software (independently sold), the recognition starting from MO will be possible.
- **When using the C-NET (RS232C) network type**  
As the same as the MEWNET-H, with PCWAY it is possible to set the relay link area simultaneously, by doing the registering at C-NET Settings.



### ◆ NOTE

**When the network type is MEWNET-H, the registered contents at “C-NET Settings” will no longer be valid.**

- **When using the modem network type**  
As the same as the upper C-NET (RS-232C), when using C-NET Settings to set a similar relay link area, it is necessary to use the C-NET No. adapted to each of the Modem Support registering.

## 8. Other relays

It is not possible to use the P (Pulse Relay) or the E(Error Informing Relay) with PCWAY.

### [Summary]

Relay	READ	WRITE	Use as Trigger
X: External Input relay	A	N/A	N/A
Y: External output relay	A	A	N/A
R: Internal relay	A	A	N/A
R: Special internal relay	A	N/A	N/A
T: Timer	*A	N/A	N/A
C: Counter	*A	N/A	N/A
L: link relay	A	A	N/A
M: Relay link area	A	N/A	A
P: Pulse relay	N/A	N/A	N/A
E: Error informing relay	N/A	N/A	N/A

A: Available  
N/A: Not available

\*If the network type is MEWNET-H, the timer and counter are not able to do “READ”.

## 2.1.2 Explanation on the Register

---

With PCWAY, the memory area of below is expressed as the "Register".

It is possible to change the contents of what will be displayed on to the Microsoft® Excel cell, by the value and the character code which has been stored inside the register.

Whether it is possible to use a certain memory area and the memory area range which can be used, varies by the PLC type.

### 1. DT: Data register

Possible to Read and WRITE.

### 2. LD: Link register

Possible to Read and WRITE.

### 3. FL: File register

Possible to Read and WRITE.

### 4. SV: Setting value of the timer / counter

Possible to Read and WRITE.

### 5. EV: Elapsed value of the timer / counter

Possible to Read and WRITE.

### 6. dt: Special data register

Only possible to READ.

### 7. m :Data link area

This is the memory area which is valid only when the network type is MEWNET-H.

Only possible to READ.

- **When using the MEWNET-H link board.**

Recognizes starting from m0 according to the range of the data link area which has been set with the [MEWNET-H Setting Software](independently sold).

- **When using the C-NET (RS-232C) network type**

This is not possible to use.

- **When using the modem network type**

This is not possible to use.

### 8. WR: Internal Relay

Possible to Read and WRITE.

### 9. WX: External Input

Only possible to READ.

## 10.WY: External Output

Possible to Read and WRITE.

## 11.WL: Link Relay

Possible to Read and WRITE.

## 12.Other memory areas

The index registers are not possible to use with PCWAY.

### [Summary]

Relay	READ	WRITE
DT: Data register	A	A
LD: Link data register	A	A
FL: File register	A	A
SV: Setting value of timer and counter	A	A
EV: Elapsed value of timer and counter	A	A
dt: Special data register	A	A
m: Data link area	A	N/A
WR: Internal Relay	A	A
WX: External Input	A	N/A
WY: External Output	A	A
WL: Link Relay	A	A
Index register	N/A	N/A

A: Available  
N/A: Not available

## 2.1.3 Explanation on the Event

### Event (V)

The event is the relay which operates in the internal part of PCWAY, independent to the PLC.

The notation method which exists with PCWAY is from:

Concerning V, V0 to V99F. In all, 1600.

(the notation method is the same as the PLC relay : the first digit under is the hexadecimal.)

This is used with the internal processing and does not take place at the same time as the PLC.

### [Summary]

Relay	READ	WRITE	Use as Trigger
V: Event	A	A	A

A: Available

## 2.1.4 Explanation on the Trigger and the "informing"

---

### Definition of the Trigger

With PCWAY, it is possible to display the PLC data on to the Microsoft® Excel sheet. Such visual performances are possible.

Also, it is possible to perform internal matters, such as accumulating data into the file, or the playing of the sound.

The relay and the event which is used to start such internal tasks are called the "trigger". Only the relay (relay link area-(M)) and the event (V) can be registered as the "trigger". When this relay link area (M) or the event (V) has changed from OFF -> ON, each of the internal processing will be started.



### ◆ NOTE

---

- **The event (V) can be used as the trigger independent to the network type.**
- **The Relay link area (M) used as the trigger, varies by the network type.**
- **When using the MEWNET-H Link board**  
It is necessary to adapt to the relay link area which has been set using the [MEWNET-H Setting Software]. (Independently sold)
- **When using C-NET (RS-232C) network type**  
You must make sure to have the area which will be used as the relay link registered at C-NET Settings.  
The relay which can be specified as the link relay is either the R: internal relay or the L: link relay.
- **When using the Modem network type**  
It is necessary to have the area which will be used as the relay link, registered based on the networks connected to each of the PLCs.  
It is crucial to register this at C-NET Settings.  
The relay which can be specified as the link relay is the R: internal relay or the L: link relay.
- **When using no network**  
The relay link area cannot be used as the trigger.
- **When using Ethernet network type**  
You must make sure to have the area which will be used as the relay link registered at [C-NET Settings].  
The relay which can be specified as the relay link is either the R: internal relay or L: Link relay.

### Definition of Informing

The word "informing" has been adopted for use to describe that each of the internal processing which have started due to the trigger, have completed.

Use this trigger to perform handshakes with the PLC or start each of the internal processing consecutively.



## Example of Handshaking Performances with the PLC by the Trigger and the Informing Relay


(When the trigger is the relay link area: M)

Here, we explain about this, using the network type of C-NET(RS-232C) as an example.

1. Select [Various Types of Records (O)]->[C-NET Settings (N)] and set R0 to RF as the relay link M0 to MF.  
By doing so, with the turning ON of the R0 of the PLC, it is possible to have PCWAY recognize M0 turning to ON.

(It is not possible to have R0 recognized as the trigger at this point.  
When connected with C-NET(RS-232C), it is necessary to registering at [C-NET Settings]. )

2. If you would like to have the trigger turn to on when the input X0 has turned on, it is necessary to have a program at the PLC as of the figure below:



The trigger here is R0.

(With PCWAY, by the prior 1 procedures, it is possible to have this recognized as M0)

After X0 has turned ON and having R0 turn ON, this will be put to self-hold.


PCWAY will receive that R0 has turned to ON(M0 turning ON) and will start the internal treatment(file processing ; etc.).

By registering the R100 as the informing relay at each of the registering menus of the various types of internal treatment, the following will happen:

After the internal treatment has finished, and PCWAY has turned R100 to ON, after a certain pulse width, (initial value: 500msec) PCWAY will confirm that R0 has turned OFF and then PCWAY will next turn OFF R100.

(When trigger R0 does not turn OFF although the informing relay R100 has turned to ON, due to a problem of the program at the PLC side, R100 will not turn to OFF. )

As described above for the PLC side, it is necessary to have a program which will self-hold itself adapted to the operations of the informing and the trigger of PCWAY.



### ◆ NOTE

When the relay link area: M has been set as the trigger, it is necessary to set the informing relay.

## Operations when the Trigger is the Event: V

When the event: V has been specified as the trigger, PCWAY will perform the internal treatment (file processing; etc.) when event: V has turned to on.


And then PCWAY will turn off the event: V which has been set as the trigger.

In such a case, it is not necessary to specify the informing relay.

Specify this when it is necessary for you to inform the PLC that the PCWAY internal treatments has been completed.

However, for the event: V which has been specified as the trigger at the [Sound Startup] registering, PCWAY will not turn OFF this event even when the sound playing has completed.,.

After you have confirmed the sound, it is necessary for the user to turn OFF event: V, manually. (by hand)



## Informing Event

Apart from the upper informing relay which handshakes with the PLC, there exists the informing event.

The informing event promotes PCWAY to turn ON the event: V after the internal treatment has been completed.

This is used when you would like to have other internal treatment started sequentially independent to the PLC after the PCWAY internal treatment has completed.

## [Summary]

Trigger	Action after the internal treatment	Registration of informing relay	informing event
Relay link (M)	Informing relay turns on with pulse	Indispensable	Turns on after the internal treatment
Event (V)	Event (V) turns off	Not indispensable	Turns on after the internal treatment

## 2.2 Basic operations of PCWAY

---

Here we will introduce general performances which are possible with PCWAY.

Also, the range of the possible performances expands when you use the macro of Microsoft® Excel, or by using each of the small programs together (the initial registering of each program is required first).

### **What is possible:**

1. Real time display of the PLC memory area at the Microsoft® Excel cell
2. Changing the PLC memory area directly from the Microsoft® Excel cell
3. Saving the PLC data into the file and displaying the data which has been saved into the file.
4. Other useful functions

### **1. Real time display of the PLC memory area at the Microsoft® Excel cell**

With PCWAY, only the currently displayed (active) sheet information can be changed. The sheet information which has not been displayed will not be updated.

Contents	Function/registration that is related
The Character and the color which will be displayed on to the cell is changed by the status of the relay and the event. (ON/OFF)	Character Change
The register value is computed and is displayed on to the cell with decimal numbers.	Operation Formula
Displays the register value by binary, hexadecimal, MEW notation (only the 1st digit under-hexadecimal).	
Recognizes the contents which has been continuously stored in to the register as the character code (ASCII code) and displays as the character.	
Changes the character and color which will be displayed at the cell (at 101 stages) by the register value.	Message
The current situation of the PLC relay is displayed.	Character Change

## 2. The memory area of the PLC is changed directly from the Microsoft® Excel cell

Contents	Function/registration that is related
By double-clicking the cell, the relay of the PLC is reversed. (Level Operation)	Character Change
After you double-clicked the cell turning the relay of the PLC to ON, after a certain period of time, the relay turns to OFF. (Pulse Operation)	Character Change Operation Formula
Double-click the cell, and turn ON the PLC relay, regardless of the current status.	Character Change
Double-click the cell, and turn OFF the PLC relay, regardless of the current status.	Character Change
After you have finished inputting, perform an operation and then store in to the register by decimal numbers.	Operation Formula
Store the binary numbers, hexadecimal numbers and the MEW notation (the 1st digit under is the hexadecimal) of which you have inputted, in to the register.	
The character which you have inputted, is stored in to the register as the ASCII code.	
Downloads all at once, the contents of the cells of which the range has been specified, to the PLC.	Download Data

## 3. Save the PLC data in to the file or display the saved data

Contents	Function/registration that is related
PCWAY saves the PLC data in to the file at optional timings by the trigger from the PLC.	File Master File Processing
PCWAY saves the PLC data in to the file at regular intervals.	Interval Timer File Master File Processing
PCWAY saves the PLC data in to the file, at the specified time of the specified date.	Weekly Timer File Master File Processing
Displays the saved file data on to Microsoft® Excel.	File Master
Saves as the Microsoft® Excel book.	Save Excel File
Saving Microsoft® Excel books as HTML	Save HTML File

- The saving of the PLC data in to the file performs independent to the running of Microsoft® Excel.
- The data which has been saved is CSV format. Therefore the displaying of the data at a different application besides Microsoft® Excel is possible.
- There are 2 optional selections in all, at the displaying of the formerly saved file data on to Microsoft® Excel. [Update file contents each time] and [Do not update].

#### 4. Others

Contents	Function/registration that is related
Turn ON the PLC relay and the event at a certain interval.	Interval Timer
Turn ON the PLC relay and the event at a specified time at a specified date.	Weekly Timer
Starts automatically the macro which the user has prepared.	Auto Macro Startup
The WAV file is generated at a specified time.	Sound Startup
The event is turned ON by the changing of the PLC relay (relay link area) .	Event Startup
Connects with distant PLC's through the modem.	Modem Support
Updates all sheet information inside the book.	Update All Sheet Data
Updates all sheet information of a currently active sheet.	Update Active Sheet Data
PCWAY is connected to one PLC through RS-232C (or Ethernet) and communicates with other PLCs through the PLC link unit.	Operation Preferences (Option) (Use Link unit No.)
By performing the compiling, PCWAY acts with high-speed performance.	Operation Preferences (Option) (Sheet data no-refresh mode)
Transfers the execution environment, such as data registered for the PCWAY, to another personal computer	Backup Utility

## 2.3 Basic Specifications

Item	Specification
The number of cells which can set to the PLC relay, register and the event on to one sheet.	8191 cells
The number of files which can be displayed on to one sheet.	100 files
Maximum number of cells which can be downloaded to the PLC at once.	8191 cells
[Character Change] by ON and OFF of the relay and the event.	100 types
[Operation Formula] for the register	100 types
The registered message which changes by the register value.	100 types (4097 stages/types)
[File Master] Maximum record number Maximum field number Generation	600 types 30000 records 256 field/records 3 generations/files
File Processing (File Trigger)	2000 types
Event Startup	1000 types
Weekly Timer	100 types
Interval Timer	100 types
Auto Macro Startup	1000 types
Sound Startup	1000 types
Modem Support	64 types (64 areas)
Modem Connection	4096 regions
Application Startup	100 types
Ethernet Remote	254 types
E-mail Setting	100 types
Maximum number of PLC to connect	254 units (However, this relies on the maximum number which can be connected for the network type)
Layer number of the MEWNET link	Only one layer (After the 2nd layer-invalid)



### ◆ NOTE

For the differences in modem response registration and modem connections, please refer to section, "Modem (Up To 64 Remote Regions)" and section, "Modem (Over 65 Remote Regions)".

## 2.4 Module

---

PCWAY is made up of 3 modules, in all.

### **Add In Software :**

Displays the PLC relay and register values on to the Microsoft® Excel cell, or downloads data which has been entered in to the cell, to the PLC.

This covers the visual performances, such as the displaying of the data.

It is necessary to have PCWAY.EXE (of below) running, in order to have the PLC relay or the register value displayed on to the Microsoft® Excel cell.

### **Module for register :**

With PCWAY we have prepared various modules in order to make your usage of PCWAY, program less as possible.

For further information on this area, please refer to: Module

### **PCWAY.EXE :**

This covers the part which is not visible to the user, such as the processing areas (file processing; timer processing, for example) or the communication with the PLC.

This part of the package becomes the core of the program.

PCWAY.EXE must always be running.

Even if you do not have Microsoft® Excel running, as long as this module is being runned, the logging of the data is possible.

## 2.5 Precautions

---

### 2.5.1 Operation Preferences


---

- It is not possible to use the MEWNET-H network when you have installed PCWAY with Windows NT®.  
Other network types can use it.
- When using node number 0, it is not possible to use the MEWNET-H, Ethernet(Remote) network.  
Also, when the network type is C-NET or the modem, it is not possible to use node number 0 when you are using the C-NET adapter for the system.  
And, if you use ET-LAN unit in Ethernet (local), Pay attention because Unit No.0 can't use.  
When using C-NET or the modem, there will not be an error displayed, and PCWAY will operate irregularly, or an end the program.
- When there is not much memory area of the personal computer, PCWAY might not operate correctly.  
Therefore we recommend the use of the memory area over 32MB.
- PCWAY might not operate correctly when there are a several other programs added-in to Microsoft® Excel.  
Please make sure to remove the Add-In programs.
- Booting Microsoft® Excel more than once and beginning monitoring on two or more Microsoft® Excel programs is not permitted.
- Please attach the key unit which is included inside the package.  
Without this being attached, PCWAY will not operate.



## 2.5.2 Operations of PCWAY

---

- Only the data of a currently active sheet can be updated, for instance the PLC information which has been set on to the Microsoft® Excel cell, or the file data.  
Concerning the sheet which is not currently active, the displaying will not be updated.  
When you would like to save the contents of a current book, it is necessary to update all of the sheets.  
For further information, refer to **5.12 Update All Sheet Data**.
- When you happen to delete or insert an Microsoft® Excel row, column or a cell, during the running of the monitor, it is possible that the PLC data and the relay display position might shift a little.  
It is necessary to stop the monitor first, and then perform the deleting or the inserting.
- When each of the registered contents or the matters which have been set before have been changed, unless you select the Click [Read PCWAY Settings Again] , it is not possible to operate the changed contents.
- For the settings below, it is necessary to re-start PCWAY after you have finished this, or else the changed contents will not be possible to operate.
  - Operation Preferences
  - Connection No. (for the node numbers)
  - File Master
  - File Processing
  - File Trigger
  - Event Startup
  - Weekly Timer
  - Interval Timer
  - C-NET Settings
  - Auto Macro Startup
  - Sound Startup
  - Modem Support
  - Application Startup
  - Ethernet Remote
  - E-mail Setting

### 2.5.3 Trigger

---

With the PCWAY, various types of processing are registered so that they are initiated when a corresponding trigger goes on.

When working with triggers, the following items should be confirmed.

#### 1. File Processing

When the same trigger has been set for the different [No.]s of [File Processing], the file processing corresponding to each of the registered number at [No.], will be executed, in turn.

#### 2. Auto Macro Startup

When the same trigger has been set for the different [No.]s of [Auto Macro Startup], the macros corresponding to each of the registered numbers will be executed, in turn.

#### 3. Sound Startup

When the same trigger has been set for the different [No.]s of [Sound Startup], each of the sounds corresponding to the registered number will be played in turn. –This will be repeated over and over.

#### 4. Event Startup

When the same trigger has been set for the different [No.]s at [Event Startup], the registered event corresponding to each of the registered numbers, will be turned to ON, in turn.

#### 5. Application Startup

When the same trigger has been set at [No.] s of different Application Startup windows®, applications associated to [No.] is started in turn, starting from the smaller number which is registered.

#### 6. Ethernet Remote

When the same trigger has been set for the different [No.]s of [Ethernet Remote], the file processing corresponding to each of the registered number at [No.], will be executed, in turn.

#### 7. E-mail Settings

When the same trigger has been set for the different [No.]s of [E-mail Settings], the file processing corresponding to each of the registered number at [No.], will be executed, in turn.



## ◆ NOTE

- **Same Trigger Setting**  
When the same trigger has been set for each of the registering topics, you must note that in such a case, only one item for processing which has been registered will be performed.  
(for instance, when the same trigger has been set for "File Processing" and "Auto Macro Startup" registering).  
Concerning on which registered item for processing will be valid, this varies each time.  
Please avoid setting the same trigger.
- **Concerning the numbers (at [No.]) which you register.**  
The registered item will be executed in the number order where the item associated with the smaller number is executed first.

### 2.5.4 Clipboard

With PCWAY, it is possible to use the clipboard when displaying the file data on to the Microsoft® Excel sheet.

Note that when this clipboard is used at a different application during the running of the monitor, then the displaying performances for the file data could be affected.

### 2.5.5 Macro name

The macro name: **PCWAY---** is used at the system of PCWAY.

Please avoid using the macro name which starts with: **PCWAY---** and including the special characters when creating the macro program.

You don't add "()" after your Microsoft® Excel Macro Name, when you input your Microsoft® Excel Macro in Auto Macro Startup.



## ◆ EXAMPLE

(Macro Name) Sub TEST() ---> TEST

### 2.5.6 Special data register

The special data register starts from either the 9000th PLC set or the 90000th set, according to the PLC type.

Therefore, it is necessary with PCWAY to specify at the "offset" of each of the starting numbers.

PLC type	Special data register	Reserved in PCWAY
FP-e, FP0, FP1, FP-M, FP3, FP-C, FP5, FP10, FP10, FP10S	DT9000 ~ DT9255	dt0 ~ dt255
FPΣ, FP2, FP2SH, FP10SH	DT90000 ~ DT90255	dt0 ~ dt255

### 2.5.7 About the file name of Microsoft® Excel

Do not use the special characters for the file name.

PCWAY will not operate correctly, if these are used.

## 2.5.8 Application Startup

---

1. Applications cannot be booted by specifying a data file related to an application in the column for the name of the application to be executed.  
For example, "Notepad" cannot be booted by specifying TEST.TXT (a text file) in the application name column.  
To run an application as described above, specify the application name as "Notepad", and then set TEST.TXT as the argument.
2. Microsoft® Excel should not be booted multiple times to monitor PLC data.  
If Microsoft® Excel is booted by booting an external application while monitoring is already beginning, an error will occur if an attempt is made to begin monitoring again. Monitoring should only be begun by running one Microsoft® Excel program.

## 2.5.9 Export function of Each Registering Module

---

This function added for printing the registering file.

If you edit the exported text file, it can't reflect to the registering file.

Please print the registering file by software that edits the text file.

The software is Microsoft® NotePad and Microsoft® WordPad, Microsoft® WORD, Microsoft® Excel etc.

The text file is CSV mode.

## 2.5.10 When you make the macro of the Microsoft® Excel

---

Verify the performance of your macro on your responsibility before starting up the system.

Matsushita Electric Works, Ltd. will not take responsibility for any abnormal operation due to a failure in your created macro linked with PCWAY.

Precautions for the users using Microsoft® Excel 97 or later; without fail, describe Macro in the standard module

- when to call up PCWAY macro function in the macro you created.
- when to register the created macro in the automatic macro start up.

In addition, do not use the macro, SetTimer function of Windows® which is for Windows® directly to execute. This may cause an abnormal performance in Microsoft® Excel.

## 2.5.11 Others

---

1. Limitation item of PLC

FP10S PLC can't use "all nodes" in Cell Settings.

2. PCWAY can't communicate at the same time with other software using the same COM port.  
But about Our FPWIN GR of Ver1.1 or more, they can communicate at the same time.
3. You can't together use LINE and TEL in using MODEM.
4. [All nodes] of Node No. in Cell Settings.

It can't use PLC Type.

FP5

FP10

FP3 Less than Ver4.5

FP10S Less than Ver1.5

5. When managing the chart-sheet

When changing the work sheet to the chart-sheet, the monitor of PCWAY will stop.

All PCWAY macros will stop followed by the stopping of the monitor of PCWAY.

Interval Timer, Weekly Timer, and File Processing will not be stopped.

## **Chapter 3**

---

### **Overview - HARDWARE**

## 3.1 Overview on Hardware

---

- PCWAY can be used with all network environments listed below:

- MEWNET-H
- C-NET (RS232C)
- Modem
- Not Connect
- Ethernet (Local)
- Ethernet (Remote)
- USB

It is not possible to use the networks listed above, together.

- Concerning the PLC(s) which is connected with the computer through RS232C (or the PLC(s) which are connected to the computer through a modem), it is possible to communicate as node "0".
- When the MEWNET-H/ P/ W link unit is attached to the PLC(s) (which is connected by RS232C as above), then it is possible to access other PLCs situated at the same level, by the following: Go to [Settings] pull-down menu at [Operation Preferences], and select [Option]. Place a check mark at [Use Link unit No. when connection by RS232C].



### ◆ NOTE

---

- When PCWAY is connecting to the CPU port of PLC, PCWAY can connect only Unit No.0
  - When using FP10S, only the tool port can be adopted for use.
- 
- Concerning the function which enables the informing of PCWAY errors using the modem ([Error Reception] function), it is possible to use these networks (introduced above), together. However, when PCWAY is connected to the PLC(s) through C-NET (RS232C), you must set the communication port to another port.

For further details, refer to **3.7 Error Reception**.

## 3.2 When Connected by MEWNET-H

---

- It is necessary to attach MEWNET-H link board (independently sold) to the computer.  
Including the computer which has MEWNET-H Link Board attached to it, the overall number of connectable nodes are: 64 nodes.  
(with 2 computers, the number of the PLC is: up to 62 sets)  
However, only PLCs at the same level as the computer only, will be perceived.  
In other words, PLCs positioned at different levels will not be perceived.  
(In such cases, the MEWNET-H Link Software independently sold will become necessary for use.)
- When you would like to start the internal processing of PCWAY, when the PLC turns on the connections (such as the file processing or the auto macro startup, and the sound playing), it is necessary to set the relaylink (M) using the MEWNET-H setting software.  
For the PLC relay, the internal relay (R) and the relay link (L) can be registered as the "relay link area".


( It is not possible to write into the PLC relay link area from the link board which is attached to the computer. )

For detailed information, refer to the "MEWNET-H Link Unit" manual and other documents.

( If using only the functions that display PLC information in Microsoft® Excel cells, or download Microsoft® Excel cell values to the PLC, it is not necessary to specify a relay link area (M) in the MEWNET-H settings software. )


## ■ Setting [Operation Preferences]

Run [Operation Preferences] and set the information introduced to you below:

Click on the  button under Network.


Select [MEWNET-H] under [Network Type].

Enter the correct settings for the [Registered Board No.], [Segment Address], and [Interrupt parameters], and enter a setting for the [Timeout] parameter.

For the PLC which is currently connected, click the  command button and run [Connection No.].

Place a check mark at the check box for the node which you will adopt for use.


For further information, refer to **6.1 Setting Operation Preferences** and **6.16 Connection No.**





### 3.3 C-NET(RS232C) Connection

- The number of the PLC nodes which can be connected to the computer during the C-NET connection is: Max. 99 nodes (It depends on hardware.)
- To set up the system so that the internal processing of the PCWAY (functions such as File Processing, Auto Macro Startup, and Sound Startup) is booted when the PLC turns on the relay, the [C-NET Settings] of the PCWAY must be used to recognize the various PLC relays as the relay link area(M).
- By setting [C-NET Settings], the PLC internal relay(R) will be set as the relay link area. When the PLC type is: FP3, FP-C, FP1OSH, it is possible to set the link area(L), also.



When connected as the figure above, set at [C-NET Settings], as the example introduced to you below:

No.	Execute	Comment	Relay link range	Setting range
1	<input type="radio"/> No	Node 1, WRO-WR1		1R0 - 1R1F
	<input checked="" type="radio"/> Yes	Node 1, WR	0 From 2 Word	1M0 - 1M1F
2	<input type="radio"/> No	Node 2, WRO		2R0 - 2RF
	<input checked="" type="radio"/> Yes	Node 2, WR	0 From 1 Word	1M20 - 1M2F
3	<input type="radio"/> No	Node 3, WRO-WR1		3R0 - 3R1F
	<input checked="" type="radio"/> Yes	Node 3, WR	0 From 2 Word	1M30 - 1M4F
4	<input type="radio"/> No			1R0 - 1RF
	<input checked="" type="radio"/> Yes	Node 1, WR	0 From 1 Word	
5	<input type="radio"/> No			1R0 - 1RF
	<input checked="" type="radio"/> Yes	Node 1, WR	0 From 1 Word	

For further details, refer to **6.11 C-NET Settings**.

## ■ Setting [Operation Preferences]

Run [Operation Preferences] and set the information introduced to you below.


Click on the **Communication Settings(S)** button under Network.

Select [C-NET (RS232C)] under [Network Type].


Enter the correct settings for the COM Port, Baud Rate, Data Length, Stop Bit, and Parity parameters, and enter a setting for the Timeout parameter.

**Connection No. (P)** and place a check mark at the check boxes for the node numbers which you will use.


For further details, refer to **6.1 Setting Operation Preferences** and **6.16 Connection No..**



- When you would like to connect the CPU of the PLC with RS232C and then access to other PLCs positioned at the same level, set as the following:



At a network such as the one above, when wishing to access PLC No.1~3 (of the figure above), run [Operation Preferences] and open the [Operation Preferences] dialog box by selecting [Option] at the [Settings] (of menu bar) pull-down menu.



Place a check mark at [Use Link unit No. when connected by RS232C]. After these settings have been entered, all subsequent access to the PLC is handled via link code numbers, rather than CPU code numbers.



## ◆ NOTE

- If you did not place a check mark before at the prior dialog box, the No.2 PLC(of the figure above) will be perceived as node number 1.
- By placing a check mark, only No.2 of above (which is connected directly with the computer) will be perceived as node number 0 (self node) regardless of the node number of the link unit.
- If you attempt accessing to the PLC after placing a check mark, this mode will not be canceled until the PLC is switched to OFF.  
(This can be canceled-however the CPU of the PLC will memorize this.)  
In order to cancel this, it is necessary to turn off the switch of the No.2 PLC.
- When using FP10S, only the tool port can be adopted for your use.

### 3.4 Modem (Up To 64 Remote Regions)

- A modem can be used to monitor PLCs in remote regions (up to 64 regions) either manually or automatically.

Also, the PLC configuration can be changed in region units.

[ If connections include 65 or more regions, automatic patrolling of PLCs is not possible, and the PLC configuration cannot be changed in region units. ]

It is necessary to set the settings for all of the regions (such as the telephone number) at [Modem Support].


- Set the necessary settings at:

[Modem Support], [C-NET Settings], and [Connection No.] for each region.

When you would like to start the internal processing of PCWAY (such as the File Processing, Auto Macro Startup, and the Sound Startup), by the PLC turning ON the relays of each regions, it is necessary to have each of the PLC relays perceived as the relay link area(M).

(This is possible by using [C-NET Settings]).


The settings at [C-NET Settings] is necessary only with the modem (even when the networks of each of the regions are connected with MEWNET-H).



In order to connect as the upper figure, set as the followings introduced to you next.

## ■ Setting [Operation Preferences]

Run [Operation Preferences] and set the information introduced below.


Click on the  button under Network.


Select Modem under Network Type.

Enter the correct settings for the [COM Port], [Baud Rate], [Data Length], [Stop Bit], and [Parity] parameters, and enter setting for the [Timeout] and [Public Line Timeout] parameters.

Check Pulse if a dial-type line is being used (no check is necessary if a [Tone](push-type) line is being used).

Enter a setting for the Modem Init command (AT command).

Erase the check mark from Over 65 Regions under Number of Regions. If this check mark is not erased, the  button will not be displayed.




To set the parameters for the various regions connected to the network, click on

Modem Support (M)

, and boot the [Modem Support] function.

Go to the other settings dialog box, entering from the [Details] command button at the [Modem Support] dialog box and set [C-NET No.] and [Connection No.].

For further details, refer to: **4.8 Using the Public Phone Line** and **6.14 Modem Support**.



• **Region 1**

[Modem Support]

No.1: register the informations such as the telephone numbers.

Modem Support

No.

Execute ☒ Yes

C-NET No.  Browse (U)

Connection No.  Browse (E)

Single Trigger ☒ Yes V

Ongoing Trigger ☒ Yes V

Limited Time ☒ None  Min

Tel. No.

Informing Relay ☒ Notify R

Informing Event ☒ Notify V

Comments

PageUp (U) PageDown (D) Exit (E) Help (H)

Node

- 0
- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15

[C-NET Settings]

No.1:  
No.1 Node 1  
WR0-1 word

No.2 Node 2  
WR0-1 word

C-NET Settings

File(F) Help(H)

C-NET No.

Comment

No.	Execute	Comment	Relay link range	Setting range
1	<input type="radio"/> No	Node 1, WR0-1word		1R0 - 1RF
	<input checked="" type="radio"/> Yes	Node 1	WR <input type="text" value="0"/> From <input type="text" value="1"/> Word	1N0 - 1NF
2	<input type="radio"/> No	Node 2, WR0-1word		2R0 - 2RF
	<input checked="" type="radio"/> Yes	Node 2	WR <input type="text" value="0"/> From <input type="text" value="1"/> Word	2N0 - 2NF
3	<input type="radio"/> No			3R0 - 3RF
	<input checked="" type="radio"/> Yes	Node 1	WR <input type="text" value="0"/> From <input type="text" value="1"/> Word	
4	<input type="radio"/> No			4R0 - 4RF
	<input checked="" type="radio"/> Yes	Node 1	WR <input type="text" value="0"/> From <input type="text" value="1"/> Word	
5	<input type="radio"/> No			5R0 - 5RF
	<input checked="" type="radio"/> Yes	Node 1	WR <input type="text" value="0"/> From <input type="text" value="1"/> Word	

[Connection No.]

No.1: Place a check at no.1 and 2

Connection No.

File(F) Help(H)

No.

Comment

Check node number you want to connect.

<input type="checkbox"/> 0	<input type="checkbox"/> 1	<input checked="" type="checkbox"/> 2	<input checked="" type="checkbox"/> 3	<input type="checkbox"/> 4	<input type="checkbox"/> 5	<input type="checkbox"/> 6	<input type="checkbox"/> 7	<input type="checkbox"/> 8	<input type="checkbox"/> 9
<input type="checkbox"/> 10	<input type="checkbox"/> 11	<input type="checkbox"/> 12	<input type="checkbox"/> 13	<input type="checkbox"/> 14	<input type="checkbox"/> 15	<input type="checkbox"/> 16	<input type="checkbox"/> 17	<input type="checkbox"/> 18	<input type="checkbox"/> 19
<input type="checkbox"/> 20	<input type="checkbox"/> 21	<input type="checkbox"/> 22	<input type="checkbox"/> 23	<input type="checkbox"/> 24	<input type="checkbox"/> 25	<input type="checkbox"/> 26	<input type="checkbox"/> 27	<input type="checkbox"/> 28	<input type="checkbox"/> 29
<input type="checkbox"/> 30	<input type="checkbox"/> 31	<input type="checkbox"/> 32	<input type="checkbox"/> 33	<input type="checkbox"/> 34	<input type="checkbox"/> 35	<input type="checkbox"/> 36	<input type="checkbox"/> 37	<input type="checkbox"/> 38	<input type="checkbox"/> 39
<input type="checkbox"/> 40	<input type="checkbox"/> 41	<input type="checkbox"/> 42	<input type="checkbox"/> 43	<input type="checkbox"/> 44	<input type="checkbox"/> 45	<input type="checkbox"/> 46	<input type="checkbox"/> 47	<input type="checkbox"/> 48	<input type="checkbox"/> 49
<input type="checkbox"/> 50	<input type="checkbox"/> 51	<input type="checkbox"/> 52	<input type="checkbox"/> 53	<input type="checkbox"/> 54	<input type="checkbox"/> 55	<input type="checkbox"/> 56	<input type="checkbox"/> 57	<input type="checkbox"/> 58	<input type="checkbox"/> 59
<input type="checkbox"/> 60	<input type="checkbox"/> 61	<input type="checkbox"/> 62	<input type="checkbox"/> 63	<input type="checkbox"/> 64	<input type="checkbox"/> 65	<input type="checkbox"/> 66	<input type="checkbox"/> 67	<input type="checkbox"/> 68	<input type="checkbox"/> 69
<input type="checkbox"/> 70	<input type="checkbox"/> 71	<input type="checkbox"/> 72	<input type="checkbox"/> 73	<input type="checkbox"/> 74	<input type="checkbox"/> 75	<input type="checkbox"/> 76	<input type="checkbox"/> 77	<input type="checkbox"/> 78	<input type="checkbox"/> 79
<input type="checkbox"/> 80	<input type="checkbox"/> 81	<input type="checkbox"/> 82	<input type="checkbox"/> 83	<input type="checkbox"/> 84	<input type="checkbox"/> 85	<input type="checkbox"/> 86	<input type="checkbox"/> 87	<input type="checkbox"/> 88	<input type="checkbox"/> 89
<input type="checkbox"/> 90	<input type="checkbox"/> 91	<input type="checkbox"/> 92	<input type="checkbox"/> 93	<input type="checkbox"/> 94	<input type="checkbox"/> 95	<input type="checkbox"/> 96	<input type="checkbox"/> 97	<input type="checkbox"/> 98	<input type="checkbox"/> 99

- **Region 2**

[Modem Support]

No.2: register the informations such as the telephone numbers.

[C-NET Settings]

No.2:

No.1 Node 1  
WR0-1 word

No.2 Node 2  
WR0-1 word

No.3 Node3  
WR0-1 word

[Connection No.]

No.2: Place a check at No.1, 2 and 3 (at check box)



• **Region 3**

[Modem Support]

No.3: register the informations such as the telephone numbers.

Modem Support

No.

Execute ☒ Yes

C-NET No.

Connection No.

Single Trigger ☒ Yes V

Ongoing Trigger ☒ Yes V

Limited Time ☒ None  Min

Tel. No.

Informing Relay ☒ Notify R

Informing Event ☒ Notify V

Comments

Node

- 0
- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15

PageUp(U) PageDown(D) Exit(E) Help(H)

[C-NET Settings]

No.3:

No.1 Node 1  
WR0-2 word

C-NET Settings

File(F) Help(H)

C-NET No.

Comment

No.	Execute	Comment	Relay link range	Setting range
1	<input type="radio"/> No	Node 1, WR0-2 words		1R0 - 1R1F
	<input checked="" type="radio"/> Yes	Node 1 <input type="text" value="WR"/> <input type="text" value="0"/> From <input type="text" value="2"/> Word		3M0 - 3M1F
2	<input type="radio"/> No			1R0 - 1R1F
	<input checked="" type="radio"/> Yes	Node 1 <input type="text" value="WR"/> <input type="text" value="0"/> From <input type="text" value="1"/> Word		
3	<input type="radio"/> No			1R0 - 1R1F
	<input checked="" type="radio"/> Yes	Node 1 <input type="text" value="WR"/> <input type="text" value="0"/> From <input type="text" value="1"/> Word		
4	<input type="radio"/> No			1R0 - 1R1F
	<input checked="" type="radio"/> Yes	Node 1 <input type="text" value="WR"/> <input type="text" value="0"/> From <input type="text" value="1"/> Word		
5	<input type="radio"/> No			1R0 - 1R1F
	<input checked="" type="radio"/> Yes	Node 1 <input type="text" value="WR"/> <input type="text" value="0"/> From <input type="text" value="1"/> Word		

[Connection No.]

No.3: Place a check at No.1 (at check box)

Connection No.

File(F) Help(H)

No.

Comment


Check node number you want to connect.

<input type="checkbox"/> 0	<input checked="" type="checkbox"/> 1	<input type="checkbox"/> 2	<input type="checkbox"/> 3	<input type="checkbox"/> 4	<input type="checkbox"/> 5	<input type="checkbox"/> 6	<input type="checkbox"/> 7	<input type="checkbox"/> 8	<input type="checkbox"/> 9
<input type="checkbox"/> 10	<input type="checkbox"/> 11	<input type="checkbox"/> 12	<input type="checkbox"/> 13	<input type="checkbox"/> 14	<input type="checkbox"/> 15	<input type="checkbox"/> 16	<input type="checkbox"/> 17	<input type="checkbox"/> 18	<input type="checkbox"/> 19
<input type="checkbox"/> 20	<input type="checkbox"/> 21	<input type="checkbox"/> 22	<input type="checkbox"/> 23	<input type="checkbox"/> 24	<input type="checkbox"/> 25	<input type="checkbox"/> 26	<input type="checkbox"/> 27	<input type="checkbox"/> 28	<input type="checkbox"/> 29
<input type="checkbox"/> 30	<input type="checkbox"/> 31	<input type="checkbox"/> 32	<input type="checkbox"/> 33	<input type="checkbox"/> 34	<input type="checkbox"/> 35	<input type="checkbox"/> 36	<input type="checkbox"/> 37	<input type="checkbox"/> 38	<input type="checkbox"/> 39
<input type="checkbox"/> 40	<input type="checkbox"/> 41	<input type="checkbox"/> 42	<input type="checkbox"/> 43	<input type="checkbox"/> 44	<input type="checkbox"/> 45	<input type="checkbox"/> 46	<input type="checkbox"/> 47	<input type="checkbox"/> 48	<input type="checkbox"/> 49
<input type="checkbox"/> 50	<input type="checkbox"/> 51	<input type="checkbox"/> 52	<input type="checkbox"/> 53	<input type="checkbox"/> 54	<input type="checkbox"/> 55	<input type="checkbox"/> 56	<input type="checkbox"/> 57	<input type="checkbox"/> 58	<input type="checkbox"/> 59
<input type="checkbox"/> 60	<input type="checkbox"/> 61	<input type="checkbox"/> 62	<input type="checkbox"/> 63	<input type="checkbox"/> 64	<input type="checkbox"/> 65	<input type="checkbox"/> 66	<input type="checkbox"/> 67	<input type="checkbox"/> 68	<input type="checkbox"/> 69
<input type="checkbox"/> 70	<input type="checkbox"/> 71	<input type="checkbox"/> 72	<input type="checkbox"/> 73	<input type="checkbox"/> 74	<input type="checkbox"/> 75	<input type="checkbox"/> 76	<input type="checkbox"/> 77	<input type="checkbox"/> 78	<input type="checkbox"/> 79
<input type="checkbox"/> 80	<input type="checkbox"/> 81	<input type="checkbox"/> 82	<input type="checkbox"/> 83	<input type="checkbox"/> 84	<input type="checkbox"/> 85	<input type="checkbox"/> 86	<input type="checkbox"/> 87	<input type="checkbox"/> 88	<input type="checkbox"/> 89
<input type="checkbox"/> 90	<input type="checkbox"/> 91	<input type="checkbox"/> 92	<input type="checkbox"/> 93	<input type="checkbox"/> 94	<input type="checkbox"/> 95	<input type="checkbox"/> 96	<input type="checkbox"/> 97	<input type="checkbox"/> 98	<input type="checkbox"/> 99

- Settings for reception from the PLC

Boot [Operation Preferences], and specify the following information.

Place a check mark by Receive under Network.

Then click on the  button and enter the reception settings.

For detailed information, refer to **6.1 Setting Operation Preferences**.

- When wishing to display the relay link area information onto the Microsoft® Excel cell, specify [C-NET No.] (the same No. as the Modem Support No.) to that node number.

Within the relay link area, information for different regions can be specified on the same sheet.



### ◆ EXAMPLE

When displaying R0 of the PLC node number of region no.3, set 20 from the relay link area (M) of C-NET No.2.

- Concerning other PLC information besides of the relay link area, specify the PLC node number (only for that region).



### ◆ EXAMPLE

When displaying Data register (D) 0 of PLC node number 3 of region no.2 (of the prior figure), set 0 of Data Register (D) of Node 3.



### ◆ NOTE

Concerning PLC information besides the relay link area, when you have set information of different regions onto the same sheet, this will be perceived as the information of the currently connected region.

It is not possible to set PLC information onto the same sheet besides the Relay link area.

It is important to make active, the sheet which will display the information of the connected area, when connecting the lines.

## 3.5 Modem (Over 65 Remote Regions)

---

- Using a modem, PLCs in remote areas (up to 4,096 regions) can be monitored manually or automatically.

However, when there are 65 or more regional connections, automatic patrolling of PLCs is not possible and you cannot change the PLC configurations for each region.

Settings for the various regions (telephone numbers, etc.) must be registered under [Modem Connection].


For information on using [Modem Connection], please refer to the corresponding Help function. When [Modem Connection] is booted, a Help item appears on the menu.

- Specify the [Connection No.] and [C-NET Settings] parameters shared by all of the remote areas.

To set up the system so that the internal processing of the PCWAY (functions such as file processing, auto macro startup, and sound startup) is booted when the PLCs in the various remote regions connected to the network turn on the relays, the [C-NET Settings] of the PCWAY must be used to recognize the various PLC relays as the relay link area (M).

- **Operating environment settings**

Boot [Operation Preferences], and specify the following information.

Click on the  button under [Network].

Select [MODEM] under [Network Type].

Enter the correct settings for the [COM Port], [Baud Rate], [Data Length], [Stop Bit], and [Parity] parameters, and enter setting for the [Timeout] and [Public Line Timeout] parameters.

Check [Pulse] if a dial-type line is being used (no check is necessary if a [Tone] (push-type) line is being used), and enter a setting for the [Modem Init command (AT command)].

Place a check mark by [Over 65 Regions] under [Number of Regions]. If this check mark is not entered, the [Over 65 Regions] button will not be displayed.

To set conditions for connections, click on the [Over 65 Regions] button.

For information on the contents of settings, refer to **6.1 Setting Operation Preferences**.

Enter settings for the [Over 65 Regions] and [Connection No.] settings.

- **Settings for reception from the PLC**

Boot [Operation Preferences], and specify the following information.

Place a check mark by [Receive] under [Network].


Then click on the  button and enter the reception settings.

For detailed information, refer to **6.1 Setting Operation Preferences**.

## 3.6 Not Connect

- Select [not Connect] at [Net Type].

This can only handle Event (V), and the gathered file data.



## 3.7 Error Reception

---

Besides the function operation of the modem which enables PCWAY to call up PLCs in remotely located regions, there exists a function which enables the PLC to call up PCWAY and inform PCWAY of any errors.



### ◆ NOTE

---

When calling PCWAY from the PLC, make sure to:

- Set the PLC which will call up as node1 when there is only one PLC in a remote area, or when connected to C-NET using the C-NET adapter.
- Place a check mark at [Use Link unit No. when connection by RS232C] when the PLC of a remote area wants to access to other PLCs of other stations situated at the same layer (in the condition when it is attached to MEWNET-H link Unit).  
Go to this from the [Operation Preferences] menubar "Setting" pull-down menu and select [Option].

The [Error Reception] function at [Operation Preferences] can be used with any network PCWAY is based on, at that moment.

(However, during the C-NET (RS232C) connection, it is not possible to use the same serial port number.)

## ■ Setting [Operation Preferences]

- Run [Operation Preferences] and set the information introduced below.

Place a check mark by [Receive] under [Error Reception], and click on the button.

Communication  
Settings (A)

The screenshot shows the 'Operation Preferences' dialog box with the following settings:

- PC Type:** IBM PC/AT
- Network:** Net Type: MODEM
- Error Reception:** ☒ Receive (highlighted with a red box and arrow), ☐ Permit the connection (M)
- Refresh Interval Settings:** Display Data: 1 00msec, Relay Link: 1 00msec, File Processing: 1 00msec, Macro Startup: 1 00msec
- Event Hold Field:** Hold Range Start No. (0-100): 0, Hold Entire Range: (empty)
- Timeout Settings:** Retry: ON, Interval: 5 min
- Work Folder:** C:\Program Files\PCWAY

- Enter the correct settings for the [COM Port], [Baud Rate], [Data Length], [Stop Bit], and [Parity] parameters, and enter setting for the [Timeout] and [Public Line Timeout] parameters.

Check Pulse if a dial-type line is being used (no check is necessary if a Tone (push-type) line is being used), and enter a setting for the AT command.

For detailed information, refer to **6.1 Setting Operation Preferences**.


The screenshot shows the 'Communication Setting - Operation Preferences' dialog box with the following settings:

- Network type:** MODEM
- COM port:** COM1
- Baud rate:** 9600 bps
- Data length:** 8 bits
- Stop bit:** 1 bit
- Parity:** Non
- Dial mode:** Tone
- Time-out:** 10 sec
- Public Line Time-out:** 60 sec
- Modem Command (AT-Command):** ATV1E0S0=1S2=43

- With regard to the PLC information for the various regions connected to the network, if there are 65 or more regions, place a check mark by [Over 65 Regions] under [Number of Regions],


and click on

Over 65 Regions(O)




Enter settings for [Information Relay] and [Information Event] as necessary.

A setting must always be entered for [Read Register], and a check mark must be placed by No. 1 in the [Connection No.] list.




For detailed information, refer to **6.1 Setting Operation Preferences**.

If there are fewer than 65 regions, boot the Modem Support function, and specify the telephone numbers and other information.



Set at [Read Register] edit box, going from the [All Settings] button.  
For further details, refer to **4.8 Using the Public Phone Line** or **6.14 Modem Support**.





## 3.8 Ethernet(Local/Remote) Connection

---

- Understand registration of IP address for a personal computer very well, the ET-LAN unit and Ethernet to use the Ethernet communication.  
Prior to using an ET-LAN unit, especially, match a configuration of a personal computer to configurations of PLCs after understanding descriptions in "ET-LAN instruction manual" very well.  
(PLCs are sure to require a program for specifying IP address.)
- The number of PLCs connecting with a personal computer via Ethernet counts up to 64.  
In use of an ET-LAN unit, however, a personal computer occupying one connection number decreases the number of PLCs able to connect to maximum 63.
- To start internal procedure of PCWAY (such as the File Processing, the Auto Macro Startup, and the Sound Startup) by PLCs turning on the relay, each relay of PLCs must be perceived as the relay link area(M) with [C-NET Settings] of PCWAY.  
(The equipment is connected physically via Ethernet, but register with [C-NET Settings])

The Ethernet connection has two types.


### 3.8.1 Ethernet (Local)

On Ethernet(Local), PCWAY connects the PC and PLC as soon as executing.

Use the Ethernet local connection ordinarily for full-time communication.  
The connection has two types.

#### ■Not using each link path of MEWNET

##### • Example of Hardware




- \* Max. 64 PLCs can be connected.  
Even if using one ET-AN unit, maximum 63 PLCs can connect.  
That means a personal computer itself must have a node number.  
(See detailed explanation in "ET-LAN Unit Introduction Manual.)
- \* Connect PLC to HUB via our ET-LAN unit or the Ethernet/RS232C converter unit on the market.  
When connecting Ethernet/RS232C converter unit, plug the RS232C cable into TOOL port of PLCs.  
But connection to FP3 require the Ver.4.4 later converter (corresponding to C-NET)

#### ■Using each link path of MEWNET


##### • Example of Hardware

Using Tool port of CPU



- \* Check number 0, 2, and 3 to enter the node number above.
- \* Connect No.1 PLC with the node No.0.

## Using ET-LAN Unit



- \* Check number1, 2, and 3 to enter the node number above.
- \* No.1 Link Unit must set the CPU right side.
- \* When you directly connect PCWAY and our ET-LAN Unit, Ethernet cable uses the crossing cable.
- \* MEWNET-H/W/P Link Unit uses nearest at the CPU place please.



### ◆ NOTE

Only top hierarchy level in each link unit of MEWNET can be connected while the second hierarchy level later cannot connected.

### 3.8.2 Ethernet (Remote)


Use the Ethernet remote connection, only if necessary for communication with PLC.  
Communication starts when either

- Turning on the event(V) or
- Informing error from PLC to PCWAY.

(Usually PLCs are not connected to PCWAY.)

Use Remote connection when user structured system is mainly as follows:

Example 1)



#### ■ Form of connection

The Remote connection has three types.

- Send Line

Connecting to PLCs from PCWAY.

There are two types of Regular Connection method (a method of connection which must be manually cut) and One Scan Connection method (a method of connection which be automatically cut off after scanning over PLCs).

The automatically link connection can be also applied to all destinations entered with the One Scan Connection method.

- Reception

Connecting to PCWAY from PLC.

PCWAY can be connecting until specifying wait time.

- Error Reception


Connecting to PCWAY from PLC.

As soon as receiving an error, PCWAY automatically cuts off line after only required processing.

## 3.9 USB (GT32) Connection


---

- One GT32 unit can be connected to a computer with a USB cable.




### ■ Operating environment settings

Start [Operation Preferences] to specify the following information.

Click the  button of [Net Type].

Select "USB" in the Network Type.

Also, specify the Time-out setting.

For the connected PLC, click  to start [Connection No.], and check the unit number of the PLC to be connected.



### ◆ NOTE

---

If more than one GT32 are connected to a computer using devices such as USB hubs, the PCWAY or GT32 may operate unusually.  
Do not connect more than one GT32 to a computer.



## **Chapter 4**

---


### **Basic Operations of PCWAY**

## 4.1 Displaying and Operating PLC Data Information with Microsoft® Excel

### 4.1.1 Outline of the Basic Procedures

#### 1. Start Microsoft® Excel


- First, from the tool bar [Tools], click [Add-ins..].
- Confirm if there has been placed a check mark at [PCWAY English]  
(the check mark indicates that the add-in of PCWAY has been performed.)



- **What to do when PCWAY add-in has not been performed:**

Have you not chosen [No] to the displayed question, [Is Microsoft® Excel installed?] at the starting point during the installing procedure?

- If so, go to:  
Microsoft® Excel menu bar -> [Tools]->[Add-ins...] and click [Browse...].  
then select [PCWAY.xla] from the folder where PCWAY has been installed into.
- **In case when although the add-in of PCWAY has been performed, the menu bar or the tool bar, etc. has not been displayed onto the screen:**
- Go to [Start] at windows® -> [Programs] -> [PCWAY] -> [Operation Preferences], and run this.  
Then go from the [Operation Preferences] menu bar -> [Settings] and select [Option].




At this dialog box, place a check mark at both the [PCWAY menubar visible] and [Use PCWAY toolbar visible].

After saving and finishing [Operation Preferences], re-start Microsoft® Excel.



## 2. Configuring PCWAY

Run the PCWAY [Operation Preferences]  and match the communication conditions with the PLC.


Clicking on  displays a screen showing the [Connection No.] list. Specify the number to be connected.

For further information on settings, refer to: **6.16 Connection No.**

## 3. Set the cell information

Select the cell on the Microsoft® Excel sheet, where you would like to display the PLC relay status or the register values.


There are three ways in setting the information as shown below:

1. Select an appropriate cell on the sheet and click the [Cell Settings] .
2. Double click the cell on the sheet where you would like to display the relay status or the register value.
3. Select the cell on the sheet and then go from the menu bar to [PCWAY] ->[Cell Settings(S)], and click this option.

The dialog box for [Cell Settings] can be displayed by any of the three ways above.

For more details on the procedures of [Cell Settings], please refer to **4.1.2 Setting the cell information.**


Concerning on more setting, refer to **5.1 Cell Settings.**



The 'Cell Settings' dialog box is shown with the following fields and options:




- Target:** Radio buttons for Relay (selected), Register, File Data, Event, Connection, and Connection Settings.
- Attribute:** Radio buttons for Read Only (selected), Read/Write, and Write Only.
- Node No.:** A dropdown menu currently showing '1'.
- Device Code:** A dropdown menu currently showing 'X : External Input'.
- Device No.:** A text input field containing '0'.
- Character Change No.:** A dropdown menu currently showing '1'.
- Character Change:** A button next to the Character Change No. dropdown.
- Next Time Open On Double-click:** A checked checkbox.
- Buttons:** OK, Cancel, and Delete buttons at the bottom.

#### 4. Run PCWAY

When the necessary settings for the cell information has been completed, left-click the [Run PCWAY] .




#### ◆ NOTE

- When  has not appeared onto the task bar under the screen, this means that PCWAY has not been executed. Furthermore, if PCWAY has not been executed, the communication with the PLC will not be possible, later on.
- If there appears an error sign during the running of PCWAY, left-click the [Exit PCWAY]  and end the PCWAY program.  
Next, left-click the [Operation Preferences]  and execute the settings, reconfirm the communication conditions with the PLC, and re-do the settings.

After this, left-click the [Run PCWAY]  once again.

#### 5. Start the monitoring

Left-click the [Start monitor] . The values of the PLC will be displayed on to the cell where the information settings have been set.

#### 6. Do the necessary operations below while the monitor is in operation

(These operations can only be done during the running of the monitor.)  
Operate the:


- Changing of the relay status
- Changing of the register value
- Operation of the continuous change mode of the register value
- Data downloading

of the registered cell.

For further information on operation, refer to **4.1.4 How to operate during the running of the monitoring.**

#### 7. Stop the monitor

Click the [Stop Monitor] .


When you would like to change an operation of the cell settings such as when wishing to correct something at the information setting, execute the [Stop Monitor] .

Concerning the information settings, this can be set during the starting of the monitor. However, it is necessary to change this part temporarily to another sheet, so that the displayed settings can be seen.

## 4.1.2 Setting the cell information

Select the cell where you would like to display the current status of the PLC relay or the register value on the Microsoft® Excel sheet.

The setting can be done by either of the three methods introduced to you below:

1. Select a cell on the sheet and click the [Cell Settings] .
2. Double click the cell where you would like to display the current status of the PLC relay or the value of the register, etc. on to the Microsoft® Excel sheet.
3. Select a cell on the sheet first, go from the menu bar to [PCWAY] and click [Cell Settings (S)].


With either of the methods, the displaying of the [Cell Settings] is possible.

For further information on [Cell Settings], refer to **5.1 Cell Settings**.



### ◆ NOTE

If you go from the [Operation Preferences] menu bar -> [Settings] and select [OPTION], the following dialog box will appear onto the screen.




The [Cell Settings] dialog box will not be displayed onto the screen later on when you double click this unless there is a check mark at the "Double-click for cell settings" first, at the [Operation Preferences] dialog box.



## ◆ EXAMPLE


### • Relay setting

When wishing to display and operate the R0 status of the internal relay, do the same settings as the figure below.



The 'Cell Settings' dialog box is shown. It has two tabs: 'Target' and 'Attribute'. The 'Target' tab is selected, showing options for Relay, Register, File Data, Event, Connection, and Connection Settings. The 'Attribute' tab is also visible, showing options for Read Only, Read/Write, and Write Only. The 'Node No.' is set to 1. The 'Device Code' is set to R : Internal Relay. The 'Device No.' is set to 0. The 'Operation Method' is set to Level Operation. The 'Character Change No.' is set to 1. A 'Character Change' button is circled. There is a checkbox for 'Next Time Open On Double-click'.

Specify the text and the color to be displayed when R0 is on, and when it is off, under "No. 1" in the list in [Character Change].



The 'Character Change' dialog box is shown. It has a table with columns 'No.', 'When ON', and 'When OFF'. The 'No.' column has a list of numbers from 1 to 10. The 'When ON' column has a text field. The 'When OFF' column has a text field. The 'No. 1' row is selected. The 'When ON' field for 'No. 1' contains the text 'RUN'. The 'When OFF' field for 'No. 1' contains the text 'STOP'. The 'When OFF' field is highlighted in blue. To the right of the table is a 'Select No.' dropdown menu with '1' selected. Below the dropdown is a 'Clear selection' button. There are also options for 'Character input' and 'Edit display color'. The 'Edit display color' option is selected, showing a 'Select color' button. Below this are options for 'Background color' (Yes/No) and 'Select character color' and 'Select background color' with color selection buttons.

This Select No. is changeable by clicking the buttons of the numbers under "No.", which is located on the very left side of the Character Change dialog box.


The registered contents at [Character Change] can also be used at the other [Cell Settings].



## ◆ EXAMPLE

### • Register setting No.1

The value of the DT0 data register is shown divided by 10. To multiply the value by 10 for operation and write it to the PLC, enter the settings shown below.




The 'Cell Settings' dialog box is shown with the following settings:

- Target: ☒ Register
- Attribute: ☒ Read/Write
- Node No.: 1
- Device Code: DT : Data Register
- Device No.: 0
- Display Method: NUM : Numeric Value
- No. of Words: 1
- Operation Formula No.: 1
- Input Range: MIN [ ] MAX [ ]
- ☒ Next Time Open On Double-click

The 'Operation Formula' button is circled, and an arrow points from it to the 'Operation Formula' dialog box.

Specify  $X/10$  in the Read column and  $X*10$  in the Write column under No.1 of the Operation Formula.



The 'Operation Formula' dialog box is shown with the following settings:

- No.: 1
- Comment: [ ]
- Read:  $X/10$
- Write:  $X*10$

To place upper and lower limits on the value used for the operation, enter values in the [MIN] and [MAX] columns.



## ◆ EXAMPLE

### • Register Setting No. 2

When you would like to display the data register DT0 to DT5 as a Character code, please set as below.

Cell Settings

Target

- ☐ Relay
- ☒ Register
- ☐ File Data
- ☐ Event
- ☐ Connection
- ☐ Connection Settings

Attribute

- ☒ Read Only
- ☐ Read/Write
- ☐ Write Only

Node No. 1

Device Code DT : Data Register

Device No. 0

1 → Display Method CHR : Character Code

2 → No. of Words 6

☒ Next Time Open On Double-click

OK Cancel Delete


1. Set the Display Method to CHR:Character Code at the Display Method edit box.
2. Set to 6 at the No. of Words edit box.



## ◆ EXAMPLE


### • Register setting No.3

Based on the value of the DT0 data register, to display [RUN] for a DT0 value of 0, [STOP] for a DT0 value of 1, and [WAIT] for a DT0 value of 2, enter the settings shown below.



The 'Cell Settings' dialog box is shown. It has two main sections: 'Target' and 'Attribute'. In the 'Target' section, 'Register' is selected. In the 'Attribute' section, 'Read Only' is selected. The 'Node No.' is set to 1. The 'Device Code' is set to 'DT : Data Register'. The 'Device No.' is set to 0. The 'Display Method' is set to 'MSG : Message Display'. The 'No. of Words' is set to 1. The 'Message No.' is set to 1. The 'Message' field is empty. The 'Next Time Open On Double-click' checkbox is checked. The 'OK', 'Cancel', and 'Delete' buttons are at the bottom.

Set the following for "No. 1" in the [Message]:  
Data value 0 --- RUN  
Data value 1 --- STOP  
Data value 2 --- WAIT



The 'Message' dialog box is shown. It has a menu bar with 'File(E)', 'Edit(E)', and 'Help(H)'. The 'No.' field is set to 1. The 'Comment' field is empty. The 'Data value' column has values 0, 1, 2, 3, 4, 5, 6, 7, 8, 9. The 'Message' column has values RUN, STOP, WAIT, and empty fields for 3 through 9. The 'Character input' radio button is selected. The 'Edit display color' radio button is selected. The 'Select color' button is shown. The 'Background color' section has 'Yes' selected. The 'Select character color' section shows a row of color swatches. The 'Select background color' section shows a row of color swatches.

Data value	Message
0	RUN
1	STOP
2	WAIT
3	
4	
5	
6	
7	
8	
9	



## ◆ EXAMPLE

### • Setting of Event

When displaying and operating the status of event V0 status, do the settings as demonstrated below by the figure.

Cell Settings

Target:

- ☐ Relay
- ☐ Register
- ☐ File Data
- ☒ Event
- ☐ Connection
- ☐ Connection Settings

Attribute:

- ☐ Read Only
- ☒ Read/Write
- ☐ Write Only

Event No.

Character Change No.  Character Change

☒ Next Time Open On Double-click

OK Cancel Delete

Specify the text and the color to be displayed when V0 is on, and when it is off, under "No. 1" in the [Character Change].

Character Change

File(E) Help(H)

No.	When ON	When OFF
1	RUN	STOP
2		
3		
4		
5		
6		
7		
8		
9		
10		

Select No.  Clear selection

☐ Character input

☒ Edit display color

Select color

Background color ☒ Yes ☐ No

Select character color

Select background color


The [Select No.] can be changed by clicking on the number at the left end in the [Character Change].


The registered contents at [Character Change] can also be used at the other [Cell Settings].




### 4.1.3 Copying and pasting the cell information


1. Select a cell which you would like to copy.

Click [Copy Cell Settings] .





2. Click the cell range where you would like to paste the copied contents.

When you have selected the cell or cells which you would like to paste, click the [Paste Cell Settings] .



At this point, the device number and event number of the pasted cells will increment, one by one.



Before performing the pasting, by clicking [Set Cell Order] , the setting of the desired pasting direction will be fixed.


For further details, please refer to **5.5 Set Cell Order**.

#### 4.1.4 How to operate during the running of the monitoring

- Changing the Register
- Changing the Relay status
- The Continuous-Change-Mode
- Data downloading

##### Changing the register value

Double click the cell where you would like to change the previously registered value. The [Register Contents Correction] dialog box will be displayed. With this, input the value at the “New Value” edit box. When you click OK, the value of the register will be changed.



There can be a number of reasons why the [Register Contents Correction] dialogbox does not emerge. Please consult the following to fix this.

- Erroneous settings under [Cell Settings]
  - [Target] is not set to [Register].  
Select Register, and if any other items need to be changed, correct the Settings of those items as well.
  - Attribute is set to Read Only  
Select either “Read/Write” or “Write Only”.

For more details on setting new values, refer to: **4.1.2 Setting the cell information.**

Concerning Setting, refer to: **5.1 Cell Settings.**


## Convert the Relay status

Double click the cell where you would like to change the ON/OFF of the Relay.

The [Relay Operation] dialog box will be displayed.

By clicking [OK], the current relay status will change variously, depending on what has been set.

Level operation	:	The current relay status will change from ON to OFF, and OFF to ON.
Pulse Operation	:	Regardless of the current relay status, if you turn the relay to ON, it will automatically change to OFF after a certain period of time.
ON operation	:	Regardless of the current relay status, the relay will always turn to ON.
OFF operation	:	Regardless of the current relay status, the relay will always turn to OFF.



If the [Relay Operation] dialog box does not emerge, the following reasons can be considered:




- Erroneous settings under [Cell Settings]
  - [Target] is not set to "Relay".  
Select [Relay], and if any other items need to be changed, correct the settings of those items as well.
  - [Attribute] is set to "Read Only".  
Select "Read/Write" or "Write Only".
  - A check mark has not been placed next to [ON/OFF confirmation message] by selecting [Settings on the operation Preferences] menu bar, and then [Option].  
The system will operate correctly in this case.

For more details on the procedures refer to: **4.1.2 Setting the cell information.**


Concerning on more setting details, refer to: **5.1 Cell Settings.**








## Continuous Change Mode

If the register value is lined up next to each other in the Row and Column of direction (horizontal and vertical direction), it is possible to make changes with the register value without going through the procedures of selecting only up to one cell at a time.

Concerning the moving direction of the cell or cells, set the    at the [Set Cell Order].

1. First, double click the cell which you would like to change, starting from the one that comes first. The [Register Contents Correction] screen will be displayed. Choose "Continuous Change".



- If the movement mode of the cell is in the "No Action"    position, the [Continuous Change] message window will be displayed. At this point, it is important not to ignore the setting of the cell movement mode to either "Downward"  , or "To the right"  . Click "OK", set the movement mode of the cell, and then execute once again the matters instructed above at No.1.




Refer to: **5.5 Set Cell Order** on how to do the setting.

2. By clicking "OK" after the changing of the register, the cells will automatically move towards the selected direction specified at the [Set Cell Order]. With this, change the register value.


## How to download data

Download to the PLC, the values where the range has been specified already.

1. Specify the cell range where [Attribute] of the information setting is set as "Write only".



### Specified range of the cells.



2. Click the  or go from the [PCWAY] in the menu bar to [Download Data].

For more details, refer to **5.11 Download Data**.

## 4.2 Saving PLC Information into the File

### 4.2.1 The file

With PCWAY, it is possible to save PLC information into the hard disk.  
The gathered data which has been saved into the hard disk, is called a file.



#### ◆ NOTE

**The file we are referring to now is not the Microsoft® Excel book file one.**

A file is made up of 2 types of information sources-field and record.

[The constitution of the file]

	field No.1	field No.2	field No.3	field No.4
Example	Date	Time	Production No.	Defect No.
Record1				
Record2				
Record3				

#### Field

A field indicates a data item.

Items such as the date, time, and number of production are called fields.

Settings can be entered for up to 256 fields (items).

There are 5 field types which can be set with PCWAY: Date, Time, Integer, Real Num., and Char.

Select the type which matches best with the item.

Date : month / day / year (4digits) (MM/DD/YYYY)

Time : hour / minute / second (HH:MM:SS)

Integer : LONG (-2147483648-2147483647 range)

Real Num. : DOUBLE (1.7E-308-1.7E+308 RANGE)

Char. : storable up to 32 characters (this is not UNICODE).

#### Record

A group (one horizontal row in the previous page) of the fields (data items) discussed in the previous page is called a record.

Data can be saved in units of one record (one horizontal row in the previous page) at a time, and numerous records can be compiled to form a file.

Up to 30,000 records (cases) can be saved.

#### File

The accumulation of data made up of fields and records, will make up a file.

File name: it is always necessary to give your file a name.

With PCWAY, it is possible to register 600 types of these files.

Since the file is saved in the text format (CSV format), it is possible to open the file at a different application, besides Microsoft® Excel.

## File Generation

With PCWAY, it is possible to use 3 generation files (of different extensions) for one file. For instance, when you have registered a file named "TEST", it is possible to use 3 generation files with PCWAY, such as:

" TEST.1 ", " TEST.2 ", and " TEST.3 ".

TEST.1: named Generation 1

TEST.2: named Generation 2

TEST.3: named Generation 3

Only the Generation 1 (TEST.1) file is capable of constantly saving the PLC information.

The Generation 2 (TEST.2) and Generation 3 (TEST.3) file are used to backup the Generation 1 (TEST.1) file.

## File Processing

The processing for the file is called: file processing

File processing is the processing for the file, such as writing-in of the PLC information, or the copying of the generation 1 file to the generation 2 file (in order to do the backup).

It is necessary to set the PLC register with every field (item) of the file, when saving PLC information into the file.

For instance, it is necessary to set DT0 of node number 1 for the number of production field, and for the defect field, then DT1 of node number 1 should be set.

For such a situation, such a program of the PLC which would store the number of production into DT0, and number of defects into DT1 becomes necessary.

[ The field for data and time will be written-in automatically by the clock of the computer ]  
when the file processing has started.

Usually, it is possible to register a number of file processings for one file type. For instance, usually you would write in PLC information into Generation 1 file.

However, when this becomes full, it is possible to copy the Generation 1 file to the Generation 2 file.

Throughout the entire PCWAY program, the number of file processings which you can register in all is: 2000 entries.

(It is not possible to download the data which has been saved into the file before, to the PLC.)

## Communicating with the [File Processing] trigger.

When the trigger turns to ON, the file processing will be executed.

The trigger of above is the trigger for the Relay (Relay link area: M) or the event (V).

By deciding the exact timing when to turn ON this trigger, it is possible to perform the file processing, at various timings.

For instance,

- By turning the event to on at a certain interval ( [Interval Timer] ), the file processing will also be performed at a certain interval.
- By turning the event to on at a specified time and date ([Weekly Timer]), the file processing will also be performed at a specified time and date.
- When [Number in Production] has reached its goal number, turn the relay link to on with the PLC.

Create the program and perform the file processing using the relay link as the trigger.

Such performances are possible.

For further information on each of the registering, refer to **6.9 Weekly Timer** and **6.10 Interval Timer**.

## File processing using the link relay as the trigger

In order to turn the link relay to on at the PLC, it is necessary to do the programming at the PLC so that the relay link (which becomes the trigger) will self-hold itself. With this, it is possible for PCWAY to recognize that the relay link has turned to on. The informing relay is there for you to cancel the self-hold.



### ◆ EXAMPLE


#### For the file processings of linkrelay: L0 and informing relay: R0

- Preconditions

It is necessary to have PCWAY recognize the link relay: L0 as the relay link: M0.

( For MEWNET-H: use the MEWNET-H setting software (independently sold)  
For C-NET or the Modem: refer to **6.11 C-NET Settings**.

- The program for the PLC



With the turning ON of X0, L0 will self-hold itself.

- Operation of PCWAY

With the turning on of L0, the file processing will be executed. The R0 will be turned to on after the file processing has been completed.

When L0 has turned to off, confirm this, and turn off R0.

#### The file processing using the event as the trigger.

When using the event as the trigger, PCWAY will turn this event to OFF after the file processing has been completed.



## 4.2.2 Create a file and execute the processing

---

Here, we will give an example of processing.



### ◆ EXAMPLE

---

- **Settings of the file**

Store the processes of the number of production, number of defects, and defect rate, into the file, at every 1 hour interval.

**At every 1 hour, the number in production and number of defects will be re-sated at 0.**  
Up to 100 of the most updated files (of 100 hrs.) will be saved.

**What to prepare with the PLC.**

1. Data that needs to be saved must be stored in a PLC register. A program is necessary, such as storing the number of production in DT0 of the station no. 1 PLC and the number of defects in DT1 of station no. 1.

To find out the defects rate, a function is used which allows operations to be carried out on values of registers using the PCWAY, and the results to be stored in a file.

2. A program must be set up so that the time that the equipment has been operating is added up with the PLC, and when the one-hour point is reached, a relay (here, L0 is used) goes on that triggers the PCWAY, so that data is held autonomously.

The relay that discontinues this self-hold of the data is called an information relay (here, it is R0) with the PCWAY.

When L0 goes on, the PCWAY stores the number of production and other information in a file, and then the PCWAY turns on R0.

A program is required so that this R0 discontinues the self-hold circuit, and resets the number of production and number of defects to 0.

After confirming that L0 has gone off, the PCWAY turns R0 off.

**Preparations for PCWAY**

When connected by C-NET(RS232C), in order to use L0 as trigger M0, the settings at [C-NET Settings] is necessary.

For further information on the setting procedures, refer to **6.11 C-NET Settings**.

## Creating the file

In order to create the file, first you must set at [File Master], the saving numbers (record numbers), each of the field types (data items) and the writing mode, etc.

For further information on each of the items and registering methods, refer to: **6.5 File Master**.

Run [File Master] and register the following settings as file no.1.

The screenshot shows the 'File Master' dialog box with the following settings:

- File base setting**
  - File No.: \* 1 :Production File
  - Comment: Production File
  - File name: test
  - Record quantity: 100
  - Write mode: Insert at end of file
  - Display renewal event: No
- Treatment when file data is full**
  - Continue processing: [checked]
  - Set the event to turn on when full: No
- Specify field type**
  - Type: Real num.
  - Method: Only specified
  - Digits after decimal point: 2
- Field List Table**

No.	Type	Comment
1	Date	File access date
2	Time	File access time
3	Integer	for number in production
4	Integer	for number of defects
5	Real num.	for defect rate

File Name : test  
When planning to create a file at the folder besides the work folder, input at the folder and file name.

Write Mode : Insert at end of file  
The record at the very most end is the newest data.

Treatment when file data is full :  
Continue processing  
Always saves the 100 of the most updated records.

Digits after decimal point :  
2  
(The defects rate is saved to two digits to the right of the decimal point.)

After the finishing registering, select [Save] option at the pull-down menu list of [File] of the menu bar.

### Registering the file processing

The target to be read from the data stored in a file, the processing timing, and other items are stored using [File Processing].

For further information on each of the items and the registering methods, refer to: **6.6 File Processing**

Run [File Processing] and register the following settings as [Execution No.] 1.

No	Type	Subject	Access method	M:Message No	F:Formula No	Node	Code	Address	Word	Fixed char.
1	Date	None								
2	Time	None								
3	Integer	PLC	Numeric	F	None	1	DT	0	1	
4	Integer	PLC	Numeric	F	None	1	DT	1	1	
5	Real num.	PLC	Numeric	F	1	1	DT	1	1	

Formula No. : 1

Register at [No.]1 in [Operation Formula] dialog box as the following figure below.

The X is equivalent to DT1 (number of defects)

No.	Comment	Read	Write
1	Defect rate	X/ (X+1DT)	

When all of the registering has been completed, go to and select [Save] from [File] in the menu bar.

You have now completed all of the registrations for the file processing.


If you have PCWAY running, the file processing will be executed at the same timing as when the program of PLC has turned L0 to ON.

## 4.2.3 Displaying the file data onto the Microsoft® Excel sheet


Display the file data which you have created, onto the Microsoft® Excel sheet.

1. Select the corner of the cell where you would like to display the file data which you have created.


All of the file data will be displayed at the selected cell as the first field of the first record.



If there are 100 record files in 3 fields, a range of cells is displayed starting with the selected cell and extending three cells to the right and 100 cells in the downward direction. Even if only one record of data has been stored, all 100 cells in the downward direction are displayed (99 of those cells will be empty). As long as any data at all exists within that range, the rest of the range will be displayed, with the cells empty.

Set the file data displaying at the [Cell Settings] icon .


For further information on the settings, refer to: **5.1 Cell Settings**



2. When the settings has been completed, click "OK".

3. After running [Run PCWAY] , run the [Start Monitor] .

When the file processing has been completed, the data will be displayed as the following shown below:




	A	B	C	D	E	F	G	H
1								
2		1/19/2004	10:12:27	0	200	300		
3		1/19/2004	10:12:58	10	300	15		
4		1/19/2004	10:13:13	500	600	77		
5		1/19/2004	10:13:27	30	20	15		
6		1/19/2004	10:13:43	800	60	258		
7								



## ◆ NOTE

When updating the file takes too long, select "Do Not Update" instead of "Updating File Contents Each Time" in "Update Method".



Cell Settings

Target:

- ☐ Relay
- ☐ Register
- ☒ File Data
- ☐ Event
- ☐ Connection
- ☐ Connection Settings

Attribute:

- ☒ Read Only
- ☐ Read/Write
- ☐ Write Only

File No.  File No. Reference

Generation

Display Method

Update Method

☒ Next Time Open On Double-click

OK Cancel Delete

In such a case, in order to update the displaying of the file, it is necessary to

- set [Display renewal event] at [File Master] dialog box.
- do the necessary settings at [Cell Settings] in order to turn this event to ON.

**File Master**

File(E) Edit(E) Help(H)

File base setting

File No. \* 1 :Production File

Comment Production File

File name test

Record quantity 100 Write mode Insert at end of file

Display renewal event 0

Treatment when file data is full

Continue processing Set the event to turn on when full V No

Specify field type

Type None Method Only specified Digits after decimal point No

No.	Type	Comment
1	Date	File access date
2	Time	File access time
3	Integer	for number in production
4	Integer	for number of defects
5	Real num.	for defect rate

**Microsoft Excel - Book1**

File Edit View Insert Format Tools Data Window Help PCWAY

A1

**Cell Settings**

Target

Relay

Register

File Data

Event

Connection

Connection Settings

Attribute

Read Only

Read/Write

Write Only

Event No. 0

Character Change No. 1 Character Change

☒ Next Time Open On Double-click

OK Cancel Delete

## 4.3 Booting Microsoft® Excel Macros Automatically

---

### 4.3.1 What is a macro?

---

The function which allows Microsoft® Excel to run automatically, is called a macro.

By combining the macro with PCWAY, it is possible to automatically generate reports or to change the colors of the charts by the PLC information.

However, you must have to know a lot about the Microsoft® Excel macro in order to use this function.

Please use while referring to the precautions introduced to you later on, only after you have understood the basics of the macro system.

### 4.3.2 Creating the Macro

---

#### 4.3.2.1 Procedures on the making of the macro

---

1. When something has gone wrong when using the macro which you have made, the PCWAY Add-In program might not operate properly.  
Therefore, it is necessary to remove the PCWAY Add-In program from Microsoft® Excel first, and then do the testing with the macro, alone.
2. Concerning on how to remove the PCWAY Add-In program...  
With Microsoft® Excel 97, go to the main menu bar of Microsoft® Excel-> [Tools]-> [Add-Ins...].  
Remove the check mark at PCWAY English at the check box lists of the [Add-In] dialog box.

Run PCWAY	Ctrl + Shift + B
Exit PCWAY	Ctrl + Shift + C
Start Monitor	Ctrl + Shift + D
Stop Monitor	Ctrl + Shift + E
Download Data	Ctrl + Shift + G
Update All Sheet Data	Ctrl + Shift + H
Update Active Sheet Data	Ctrl + Shift + I
Save Excel File	Ctrl + E
Save HTML File	Ctrl + M




#### ◆ EXAMPLE

---

When [Ctrl + Shift + B], [Ctrl + Shift + D], and [Ctrl + E] are pressed in recording new macros, the following macros are automatically recorded in "Module", respectively.

```
Application.Run "PCWAYsubShellPcwayStart"  
Application.Run "PCWAYsubRunStart"  
Application.Run "PCWAYsubFileSave"
```

3. Execute the macro which you have created, going from Microsoft® Excel [Tools]-> [Macro]. Make sure that you have not made any errors.



#### ◆ NOTE

When an error has emerged when you have started the macro which was created in the state of PCWAY add-in being registered, then it is necessary to re-start Microsoft® Excel.

#### 4.3.2.2 Built -In functions

PCWAY is ready with the following built-in functions.  
Use when necessary.

##### Method for inputting

1. When Sub Procedure:

Call Application.Run("Function name", Argument 1,...)

Example) Download Data

Call Application.Run("PCWAYsubDownLoad")

2. When Function Procedure:

Return value = Application.Run("Function name", Argument 1,...)

Example) Specified saving process of Microsoft® Excel file name(File name : TEST)

Dim Filename as String

Filename = Application.Run("PCWAYfncFileSaveNameType","TEST")



## Menubar Toolbar registration function

- **Cell Settings** Sub PCWAYsubSetCell
- **Delete Cell Settings** Sub PCWAYsubCellDel
- **Copy Cell Settings** Sub PCWAYsubCellCopy
- **Paste Cell Settings** Sub PCWAYsubCellPaste
- **Set Cell Order: No Action** Sub PCWAYsubCellMoveNo
- **Set Cell Order: Down word** Sub PCWAYsubCellMoveDown
- **Set Cell Order: To the Right** Sub PCWAYsubCellMoveRight
- **Start PCWAY** Sub PCWAYsubShellPcwayStart
- **Exit PCWAY** Sub PCWAYsubExecuteStop
- **Read PCWAY Settings Again** Sub PCWAYsubExecuteRestart
- **Start Monitor** Sub PCWAYsubRunStart
- **Stop Monitor** Sub PCWAYsubRunStop
- **Download Data** Sub PCWAYsubDownLoad
- **Update All Sheet Data**(with message) Sub PCWAYsubRefresh
- **Update All Sheet Data**(without message) Sub PCWAYsubRefreshNoMessage
- **Update Active Sheet Data**(with message) Sub PCWAYsubSheetRefresh
- **Update Sheet Data**(without message)

Sub PCWAYsubSheetRefreshNoMessage(Argument 1 as String)

Argument1: Sheet name that renews information  
In the case that argument 1 was omitted or in the case that "" was specified,  
the active sheet is renewed.

Example) Renews the information of Sheet no.2.

Call Application.Run("PCWAYsubSheetRefreshNoMessage", "Sheet2")

- **Save Microsoft® Excel File** (fixed File name : Present file name+YYMMDDHHMMSS)

Sub PCWAYsubFileSave

- **Save Microsoft® Excel File** (possible to specify file name)

Function PCWAYfncFileSaveNameType\_

(Argument 1 as String, Argument 2 as Integer) As String

Argument1: Specified file name (File expansion (xls) is not included)  
When you registered only the file name, the HTML file is saved to the same  
folder as the Microsoft® Excel book file.

Argument2: 0:Saves the original book.  
1:Original book is not saved.  
(It is 0 in the case of omission.)

Return value:File name which was saved (Folder name accompaniment)

Example) The name called TEST is attached when saving the present book.  
The original book is not saved.

Dim strFilename as String  
strFilename=Application.Run("PCWAYfncFileSaveNameType", "TEST", 1)

- **Save HTML File** (fixed File name : Present file name)

Sub PCWAYsubHTMLFileSave

- **Save HTML File** (possible to specify file name)

Function PCWAYfncHTMLFileSaveNameType\_

(Argument 1: As String, Argument 2: As Integer) As String

Argument1: Specified file name (File expansion (htm) is not included)  
When you registered only the file name, the HTML file is saved to the same folder as the Microsoft® Excel book file.

Argument2: 0:Saves the original book.  
1:Original book is not saved.  
(It is 0 in the case of omission.)

Return value:File name which was saved (Folder name accompaniment)

• <b>Operation Preferences</b>	Sub PCWAYsubShellEnvironUpdate
• <b>Character Change</b>	Sub PCWAYsubShellDisplayChange
• <b>Message</b>	Sub PCWAYsubShellMessage
• <b>Operation Formula</b>	Sub PCWAYsubShellCalc
• <b>File Master</b>	Sub PCWAYsubShellFileMaster
• <b>File Processing</b>	Sub PCWAYsubShellFileLog
• <b>File Trigger</b>	Sub PCWAYsubShellFileTrigger
• <b>Event Startup</b>	Sub PCWAYsubShellEventTrigger
• <b>Weekly Timer</b>	Sub PCWAYsubShellWeeklyTimer
• <b>Interval Timer</b>	Sub PCWAYsubShellIntervalTimer
• <b>C-NET Settings</b>	Sub PCWAYsubShellCNetEntry
• <b>Auto Macro Startup</b>	Sub PCWAYsubShellEventMacro
• <b>Sound Startup</b>	Sub PCWAYsubShellSound
• <b>Application Startup</b>	Sub PCWAYsubShellRunExec
• <b>Modem Support</b>	Sub PCWAYsubShellModem
• <b>Application Startup</b>	Sub PCWAYsubShellRunExec
• <b>Ethernet Remote</b>	Sub PCWAYsubShellEthernet
• <b>E-mail Setting</b>	Sub PCWAYsubShellEMail
• <b>Help display</b>	Sub PCWAYsubHelpDisp
• <b>Compile</b>	Sub PCWAYsubCompile

## Internal treatment function

- Confirm the currently connected node number

Sub PCWAYsubMyAppSetUnitState

- Function for obtaining PCWAY execution folder

Function PCWAYfncExecDirectory as String

Return value: Execution folder

Example)

Dim strFolder as String

strFolder= Application.Run("PCWAYfncExecDirectory")

- Function for obtaining PCWAY work folder

Function PCWAYfncWorkDirectory as String

Return value: Work folder

Example)

Dim strFolder as String

strFolder= Application.Run("PCWAYfncWorkDirectory")

- Obtains sheet protection password

Function PCWAYfncGetProtect as String

Return value:Password

Example)

Dim strPassword as String

strPassword= Application.Run("PCWAYfncGetProtect")

Supplement example)

This is the example of the removing of the sheet protection of the sheet (for example Sheet1).

After the above function is inputted, the following function is inputted.

Worksheets("Sheet1").UnProtect StrPassword

The next is the example of the protecting of the sheet, once again.

After the above function is inputted the following function is inputted.

Worksheets("Sheet1").Protect StrPassword

- Changing the interval timer settings temporally

Function PCWAYfncSetIntervalChange(Argument 1 as Integer, Argument 2 as Integer, Argument 3 as Integer) as Integer

Argument1: Interval Timer No.(1 to 100)

Argument2: Execution flag 0: End  
1: Execute

Argument3: Interval time(every seconds)

Return value: 0 :Normal  
-1:Interval timer no. and specified error of folder to be executed  
-2:Specified error of execution flag  
-3:Specified error of interval time

Example)

Execute the interval timer processing of No. 1 at every 3 second interval.

Dim intRet as Integer

intRet= Application.Run("PCWAYfncSetIntervalChange" ,1,0,3)

- Processing for obtaining the event number status

Function PCWAYfncEventRead(ByVal Argument 1 as String) As Integer

Argument 1:       Event no.  
                   Example) For V21, the argument is "21".

Return value:     0: OFF  
                   1: ON

Example)

To obtain the status of event V21

```
Dim intRet as Integer
intRet = Application.Run("PCWAYfncEventRead","21")
'If intRet is 1, the event is on, and if 0, the event is off.
```

- Processing for setting the event number status

Function PCWAYfncEventWrite(ByVal Argument 1 as String, ByVal Argument 2 as Integer) As Integer

Argument 1:       Event no.  
                   Example) For V21, the argument is "21".

Argument 2:       1: ON  
                   0: OFF

Return value:     0: Normal

Any other value:   Error

Example)

To turn V21 on

```
Dim intRet as Integer
intRet = Application.Run("PCWAYfncEventWrite","21",1)
```



## ◆ EXAMPLE

### Usages of the functions for PCWAY

- The following example describes the changing of the sheet, using the press button.  
When using: PCWAYsubAutoSheet for the changing of the sheet with the macro, make sure to inform the Add-in program that the sheet has been changed.

```
Sub Command 1_Click()  
    Sheets("Sheet1").Select           'Sheet Change  
    Call Application.Run("PCWAYsubAutoSheet") 'inform the Sheet changing  
End Sub
```

- The following example describes the downloading of the data, using:  
PCWAYsubDownLoad

```
Execute during the running of the monitor.  
If Application.DisplayNoteIndicator = False Then  
    'Download the data which has been entered in to the B15 cell.  
    Range("B15").Select           'Select the cell  
    Call Application.Run("PCWAYsubDownLoad") 'Download Data  
End If
```

- The next example describes the back-upping of the data using:  
PCWAYfncFileSaveNameType

```
Dim strFileName As String  
Dim strBuffer As String  
  
strFileName= "TestBackup"  
strBuffer = Application.Run("PCWAYfncFileSaveNameType",strFileName)
```

### Precautions concerning usage

With PCWAY, the following procedures are registered.  
When the properties of the procedures below are changed, then the PCWAY Add-In program might not operate correctly.  
Please be careful.

### Procedure various types of settings

```
With Application  
    .OnSheetActivate = "PCWAYsubAutoSheet" 'Sheet activate  
    .OnDoubleClick = "PCWAYsubDoubleClick" 'Double click  
    .OnData = "PCWAYsubDDEAddinEvents" 'DDE Link  
    .DisplayNoteIndicator = True 'Memo mark  
    .ActiveCell.NoteText = "=MEW(" 'Memo  
    .ScreenUpdating = True 'Screen display renewal  
End With
```

### Event procedure relation function

- |  |                            |
|--|----------------------------|
| • Sheet data notice processing             | Sub PCWAYsubAutoSheet      |
| • Double click processing                  | Sub PCWAYsubDoubleClick    |
| • Cell input processing                    | Sub PCWAYsubCellEntry      |
| • DDE Event arrival of the post processing | Sub PCWAYsubDDEAddinEvents |



#### ◆ NOTE


---

Attention when you use "PCWAYsubDoubleClick" of Event procedure relation function into Microsoft® Excel Macro.

Use "PCWAYsubDoubleClickEntry", when you want to use "PCWAYsubDoubleClick".

Ex.) Operating ON/OFF the relay of Microsoft® Excel Cell "B2".  
Range("B2").Select  
Call Application.Run("PCWAYsubDoubleClickEntry");

### 4.3.3 Register the macro which will start automatically

When you have created the macro, by setting [Auto Macro Startup] , it is possible to start automatically, the macro which you have created.  
It is possible to set the relay link area(M) and the event(V) as the trigger which will start the macro.

For further information, refer to: **6.12 Auto Macro Startup**

#### Informing the trigger of the automatically starting macro

[Auto Macro Startup] will be started by the trigger turning to ON.

This trigger is equivalent to the relay (relay link: M), or the event(V).

By determining the time when to turn the trigger to ON, it is possible to start the macro at various timings.

- Start the macro starting at a certain interval by setting [Interval Timer] which enables the event to turn to ON at a certain interval.
- Start the macro at a specified time of the specified date by setting [Weekly Timer] which enables the event to turn to ON at a specified time of the specified date.
- Create a program with the PLC which will turn ON the relay link when the number of production has reached it's goal number.  
Start the macro using this relay link as the trigger.

Such performances are possible.

For further information on the registering, refer to **6.9 Weekly Timer** and **6.10 Interval Timer**.

#### Starting the macro using the relay link as the trigger.

In order to turn ON the relay link with the PLC, in order to have PCWAY recognize the turning ON of the relay link, it is necessary to create a program at the PLC side, which will have this relay link (which becomes the trigger) put to self-hold.

Use [Informing Relay] in order to cancel the self-hold state.



#### ◆ EXAMPLE

##### When starting the macro automatically...

link relay: L0


informing relay : R0

- Preconditions

It is necessary to have PCWAY recognize link relay : L0 as relay link : M0.

When MEWNET-H: Use MEWNET-H setting software  
(independently sold)  
When C-NET, or the Modem, refer to **6.11 C-NET Settings**

- Program at the PLC side



By X0 turning to ON, L0 will be put to self-hold.

- Operation of PCWAY

When L0 has turned to ON, PCWAY will start the macro and turn ON R0 after this.

After PCWAY confirms that L0 has turned to OFF, PCWAY will turn R0 to OFF.

#### Starting the macro using the event as the trigger

When using the event as the trigger, after executing the macro, PCWAY will turn this event to OFF.

## 4.4 Turn on the Relay/Event at a Specified Time or at a Certain Interval

---


### 4.4.1 Turn the Relay and Event to On at the Specified Time of the Specified Day of the Week

---

PCWAY will turn on the relay and event at a specified time of a specified day of the week. Set the necessary settings at [Weekly Timer] in order to use this.

For further information, refer to: **6.9 Weekly Timer**

To turn on relay R0 of node number 1 using pulses, Monday through Friday at 17:30, the following settings would be entered.



By using together [Weekly Timer] and [File Processing], it is possible to perform the [File Processing] at a specified time everyday, or by using [Weekly Timer] with the [Auto Macro Startup], it is possible to generate reports at a specified time, everyday.




#### 4.4.2 Turn the Relay and Event to On at a Certain Interval

PCWAY will turn the relay/event to on at a certain interval.

In order to make use of this function, set the necessary settings at [Interval Timer].

For further information, refer to **6.10 Interval Timer**

When you would like to turn event V0 to ON at a 1 min. interval, set as the figures shown below:



By using together [Interval Timer] and the [File Processing], it is possible to perform the file processing at a certain interval.

By using together [Interval Timer] with the [Auto Macro startup], it is possible to start the macro at a certain interval.

Starting time of a certain interval is 0:00 a.m..

For example, If it's "1min" of up settings,

V0 is ON at 0:00, 0:01, 0:02, 0:03.....23:59.

For example, If up settings is "1Hour",

V0 is ON at 0:00, 1:00, 2:00, 3:00.....23:00.

## 4.5 Playing the Sound

---

### 4.5.1 Procedures of the sound playing

---

The playing of the sound file will be started by the trigger turning to ON.

This trigger is equivalent to the relay (link relay :M) or the event(V).

By determining the timing of when to turn ON the trigger, it is possible to perform the sound playing at various timings.

For example:

- Perform the sound playing at a certain interval by setting [Interval Timer] which enables the turning ON of the event at a certain interval.
- Perform the sound playing at the specified time of the specified day of the week by setting [Weekly Timer] which enables the turning on of the event at a specified time of a specified day of the week.
- Create a program which will turn on the relay link with the PLC when the production number has reached its target number and will perform the sound playing using the link relay as the trigger.

By doing so, it is possible to perform the sound playing using this link relay as the trigger.

For further information on the registering, refer to **6.9 Weekly Timer** and **6.10 Interval Timer**.

The sound will be played over and over while this trigger is still ON.

(Apart from other internal processings, it is not possible with PCWAY, to turn off the event or to turn on the informing relay with PCWAY.)

Please turn off the trigger manually, after confirming the sound.

#### **Playing the sound using the link relay as the trigger**

Using the PLC, create a program that enables self-holding of the link relay that will serve as the trigger.

The playing of the sound can be stopped by assigning a cell in the Microsoft® Excel sheet that handles pulsed operation of the relay that cuts off the self-holding of the trigger.

#### **Playing the sound using the event as the trigger**

When using the event as the trigger, by assigning the cell which will operate this event at the Microsoft® Excel sheet, it is possible to stop the playing of the sound.

### 4.5.2 Create the WAV file


---

PCWAY does not have the WAV file attached to it.

Create the WAV file, etc. in order to play the sound. Use windows® [Sound Recorder]; etc..

### 4.5.3 Register at Sound Startup

---

Start [Sound Startup]  and register the trigger, etc. in order to make the sound playing possible.

For further information, refer to: **6.13 Sound Startup**

## 4.6 Turn On the Event by the Changing of the Relay Information of the PLC

---

### 4.6.1 Watch the changing of the relay

---

With PCWAY, it is possible to change the character and the color which you will display later on to the Microsoft® Excel cell by the PLC relay turning to ON /OFF.

However the use of this is limited to the displaying only.

When you would like to use together the changing of the relay (ON/OFF) with other processing, it is necessary to follow the matters below.

1. You will need a macro for watching the contents of the currently displayed cell.
2. In order to start this macro with a certain interval, you must register at [Interval Timer] so that the event will turn ON at a certain interval.
3. The registering for [Auto Macro Startup] which uses this event is necessary.

Since there are many registering required and various types of processing used together after the registering, the processes on the whole, will be rather slow.

In order to make the usage must easier, follow the next procedures.

Turn the event to ON after watching the changing of the relay to on -> off or off -> on.

Use [Event Startup] which enables to use this event to have other processing used together.

Monitoring is carried out on an ongoing basis no matter which spreadsheet is active, such as the relay being changes from on to off, or from off to on, and various events can be turned on individually.



#### ◆ NOTE

---

It is also possible to turn the event ON only with one certain sheet that is active.

### 4.6.2 Have PCWAY recognize the relay which will be watched as the link relay

---

In order to have the relay constantly watched, it is necessary to have PCWAY recognize this relay as the link relay area.

The method for this varies by the network type.

#### When MEWNET-H

It is possible to have the internal relay(R) or the link relay(L) recognized as the relay link area(M), using the MEWNET-H setting software(independently sold)

For further information, refer to the "MEWNET-H link unit" manual.

#### When C-NET (RS-232C)

By setting PCWAY [C-NET Settings], it is possible to have the internal relay(R) or the link relay(L) recognized as the relay link area(M) at every PLC node number.

For further information, refer to: **6.11 C-NET Settings**

#### When using [Modem]

By setting PCWAY [C-NET Settings], it is possible to have the internal relay(R) or the link relay(L) as the relay link area(M) at every PLC node number.


For further information, refer to: **4.8 Using the Public Phone Line** and **6.11 C-NET Settings**

### 4.6.3 Perform the event startup

It is possible to watch the OFF->ON or ON->OFF changing of the link relay area, and turn ON each of the different events.

For further information, refer to: **6.8 Event Startup**

When you would like to watch the OFF->ON changing of link relay M0 and turn event V0 to ON, set as the following figures:



By using [Event Startup] with [Auto Macro Startup], it is possible to change the chart color, etc.

## 4.7 Managing the File

---

### 4.7.1 Manage the file with the generation of the accumulating file

---

It is possible to save the PLC information into the file whenever the trigger turns to ON, using [File Processing] of PCWAY.

It is also possible to back-up the accumulated file of the PLC information.

For further information, refer to: **4.2 Saving PLC Information into the File**

- As quoted before, PCWAY will handle up to 3 generation files for one file.  
Only the generation 1 file (extension .1) can be accumulated in to the file of the PLC information. It is possible to either copy or transfer this file to the generation 2 file (extension .2) or the generation 3 file (extension .3), as well.  
In order to make this possible, set the necessary settings at [File Processing].  
For further information, refer to: **6.6 File Processing**

By accumulating every day, data in to the generation 1 file for a month, and then transferring generation 1 file to the generation 2 file at the end of the month, by doing so, generation 1 file will be initialized, and generation 2 file will be usable as the prior month's data file.

Therefore, it would be possible to store the current month's data in to generation1 file, and the prior month's data in to generation 2 file.



#### ◆ NOTE

---

For the generation, only up to the 3rd generation can be used.  
When you are in need of a file revision other than this, (file revision besides the 1st, 2nd, and 3rd generation) refer to: **4.7.2 Controlling Files Using the Microsoft® Excel Book Log.**

## 4.7.2 Controlling Files Using the Microsoft® Excel Book Log

---



### The inconveniences when saving the Microsoft® Excel book by: "File" -> "Save".

Although it is possible to save the Microsoft® Excel book from the "File" menu, potentially, there will arise problems with this, such as described below:

1. PCWAY will only update the displaying of the sheet information of a currently active sheet. Therefore, if a sheet is not active right before it's saving, the data will not be updated from what has been last displayed (unless you have used only one sheet during the process).
2. When you re-open a formerly saved book and then start the monitor, the data which has been saved before will be updated, due to the current PLC information and etc. This is because the PLC information and the cell are held still linked by the [Cell Settings].

### What to be careful of when saving the Microsoft® Excel book

As a solution for the prior matters, it is necessary to follow the procedures introduced to you below, before you save a particular book.

1. When there happens to exist a several number of sheets in a book, it is necessary to do the settings at [Update All Sheet Data] before saving the book.  
Either click the  of [Update All Sheet Data] or go to the menu bar -> [PCWAY] -> [Update All Sheet Data]
2. Before saving the book, when you would like to erase all of the settings (formerly set) at [Cell Settings] and save only the data, use [Save Excel File].  
Either click the  of [Save Excel File] or go to the menu bar -> PCWAY -> [Save Excel File].  
With PCWAY, the file name which has been saved using [Save Excel File] will be:  
the file name before being saved+YYYYMMDDHHMMSS (year, month, day, hour, minute, second)  
By using [Update All Sheet Data] and [Save Excel File] together with the macro, it is possible to save the file automatically.

### 4.7.3 Saving Microsoft® Excel books as HTML

---

- Active books can be saved as HTML by selecting one from the following three options:
  - 1) [HTML File Save] icon on the PCWAY tool bar
  - 2) PCWAY menu
  - 3) Shortcut key "Ctrl + M"

Microsoft® Excel books can also be saved as HTML by calling from the user-created macro in [Auto Macro Startup].

#### **Built-in macros:**

File name automatically saving process: Sub PCWAYsubHTMLFileSave

File name designation saving process: Function PCWAYfncHTMLFileSaveNameType\_  
(Argument 1: As String, Argument 2: As Integer) As String


Argument 1: File name to be saved (An extension is not included.)

Argument 2: 0: Original book is saved.  
1: Original book is not saved.  
(When "Argument 1" is set but "Argument 2" is not set,  
the case "0" above is applied.)

Return value: Saved HTML file name (with full path)

#### **What to be careful of when saving the HTML format**

1. When there happens to exist a several number of sheets in a book, it is necessary to do the settings at [Update All Sheet Data] before saving the book.

Either click the  of [Update All Sheet Data] or go to the menu bar -> [PCWAY] -> [Update All Sheet Data]

2. For a file name saved in "File name automatically saving process" above, the extension ".htm" is added to the target book name, and the file is created in the same folder as the target file. At this time, the target book is also overwritten.

To specify file names and folders, use "File name designation saving process" above.

When files and folders have already been saved as HTML automatically, they are overwritten to save.

When a book is newly created, ".xls" and ".htm" files are saved in PCWAY work folder.

## 4.8 Using the Public Phone Line

---

### 4.8.1 The Difference between Less than 65 and 65 or More Remote Locations

---

Public telephone lines can be used to monitor information at remote PLCs (in up to 4,096 regions), and to display and operate data, and save data to files.

Once a remote PLC is connected to the public phone lines, you are able to use all the functions provided with PCWAY.

The functions that can be executed may differ depending on how many PLCs are connected.

#### **When there are less than 64 remote regions**

1. Even if the network configuration for the remote PLCs is different for different regions, you are still able to observe all PLCs.
2. When connecting from PCWAY to the remote PLC:  
There are two types of connections: ongoing connection (where connection is maintained until it is severed) and single connection (where connection is automatically severed after all the remote PLCs are scanned once). Also, you can have the single connection performed all registered remote regions in rotation.
3. When connecting from the remote PLC to PCWAY:  
There are two types of connections as below.
  - Normal reception  
Using the same COM port used for 2 above, you can receive data from the PLC.  
Once received, you can also have connection maintained until specified.
  - Error reception  
Using the same COM port used in 2 above or another COM port, you can receive data from the PLC.  
Once received, the required processed are performed and the connection is automatically severed.
4. Display functions  
Data from the remote region can be displayed on sheets using the Microsoft® Excel application.
5. Miscellaneous  
The registered telephone numbers cannot be used with other tool software such as FPWIN.

#### **If there are remote locations in more than 65 but fewer than 4,096 regions**

1. For the network configuration for the remote PLCs, a PLC with a node number of 1 is required. (The informing relay used to inform the PLC of the connection with PCWAY is limited to node number 1 and is turned on.)
2. When connecting from PCWAY to the remote PLC:  
Only manual connection is possible. You cannot have the single connection performed for all registered remote regions in rotation as you can with less than 64 remote regions.
3. When connecting from the remote PLC to PCWAY:  
There are two types of connections as below.
  - Normal reception  
Using the same COM port used for 2 above, you can receive data from the PLC.  
Once received, you can also have connection maintained until specified.
  - Error reception  
Using the same COM port used in 2 above or another COM port, you can receive data from the PLC.  
Once received, the required processed are performed and the connection is automatically severed.
4. Display functions  
Data from the remote region cannot be displayed on sheets using the Microsoft® Excel application.




## 5. Miscellaneous

The registered telephone numbers can be used with other tool software such as FPWIN.


### Differences in the setup

When using the public phone lines to connect a personal computer to the PLCs, the setup procedures will change depending on whether there are more or less than 65 remote PLCs.

- When less than 65 PLCs are connected, remove the check from the [Over 65 Regions] check box for Number of regions in the [Operation Preference]s dialog box.



Click the **Modem Support (Q)** button that appears and set the [read register], [informing relay], and other settings.



You can change the PLC configuration for each region.

You can set multiple node numbers for the [informing relay] node number.

- When 65 or more PLCs are connected, place a check in the [Over 65 Regions] check box for [Number of regions] in the [Operation Preferences] dialog box.

**Operation Preferences**

File(E) Settings(C) Help(H)

PC Type  
PC Type: IBM PC/AT

Network  
Net Type: MODEM(Over 65 Regions)  
Communication Settings(S)  
☒ Receive Permit the connection(M)

Error Reception  
☐ Receive Communication Settings(S)

Number of regions  
☒ Over 65 Regions Over 65 Regions(Q)

Pulse Width Settings  
Relay ON Time: 1 00msec

Refresh Interval Settings  
Display Data: 1 00msec  
Relay Link: 1 00msec  
File Processing: 1 00msec  
Macro Startup: 1 00msec

Event Hold Field  
Hold Range Start No. (0-100)  
UV: 0  
Hold Entire Range

Timeout Settings  
Retry: ON  
Interval: 5 min

Work Folder: C:\Program Files\PCWAY Drive(W)

Click the **Over 65 Regions(Q)** button that appears and set the [Read Register], [Informing Relay], and other settings.

**Operation Preferences**

MODEM(Over 65 Regions)

Informing Relay  
☒ Inform Node.1 R 0

Informing Event  
☒ Inform V 0

Read Register  
Node.1 DT 0

Connection No. (P)

OK(O) Cancel(C) Help(H)

You cannot change the PLC configuration for each region. The PLC configuration is shared by all regions.

The Informing Relay is on for only the PLC with the node number 1.

#### 4.8.1.1 Connecting to PLCs from a Personal Computer

---

##### When there are less than 65 PLCs connected

The PLC configuration can be set for each region using [Modem Support].

When the events set in [Modem Support] turn on, ongoing connection, rotating connection, and the like are possible.

You can also set the informing relay for informing the PLCs when connections are made.

More than one node number can be set. It is also possible for informing to the informing event.

##### When there are 65 or more PLCs connected

The PLC configuration is shared by all regions.


To connect, start up [Modem Connection] and connect manually.

For more information regarding settings, refer to the Help supplied with [Modem Connection].

The Help is viewed by starting up [Modem Connection] and choosing Help from the menu.

To perform the setup for 65 or more connections, place a check in the [Over 65 Regions] check box for Number of regions in the [Operation Preferences] dialog box and click the

**Over 65 Regions (Q)** button. Then perform the required settings in the dialog box that appears.



Set the [Informing Relay] for informing the PLCs when connections are made.


The [Informing Relay] is set to on only for the PLC with the node number 1.


Click the **Connection No. (P)** button and place a check at node number 1 in the dialog box that appears.

It is also possible for informing to the informing event.

#### 4.8.1.2 Connecting to PLCs from a Personal Computer

Place a check in the [Receive] check box for [Network] in the [Operation Preferences] dialog box to allow reception of transmissions from the PLCs.

Click the  button and perform the required settings in the dialog box that appears.




If the [Event] to confirm the connection turns on within the [Waiting time] to confirm the connection, or if a check is placed in the [Event automatically turn] on check box, then the phone line connection is maintained.

If the [Event] to confirm the connection turns off, or if it does not go on within the [Waiting time] to confirm the connection, then the phone line is disconnected.

## When there are less than 65 PLCs connected

Click the [Modem Support] button and then [All Settings] to set the [Read Register].



After reception, the PLC data is read with the Read Register that is set.

Setting the [Read Register] is required at the PLC.

PCWAY reads the [Read Register] PLC node number as 1.


However, if there is a check in the [Use Link unit No. when connection by RS232C] check box in the dialog box brought up by selecting [Option (O)] from the [Settings (C)] menu of the [Operation Preferences] dialog box, the [Read Register] PLC node number becomes 0.

The Read Register stores the values given below.

- 1st word: [Modem Support] number.
- 2nd word: Event number to turn on (specified by HEX).
- 3rd word: Fixed to K1.

Since the data value that becomes the event number is stored in the data value of the 2nd word, that event is set to ON.


To inform the PLC of the connection, click on [Details (D)] button at the [Modem Support] dialog box and set the informing relay.



You can set a multiple number of node numbers.

## When there are 65 or more PLCs connected

Place a check in the [Over 65 Regions] check box for [Number of regions] in the [Operation Preferences] dialog box and click the  button to display the [MODEM (Over 65 Regions)] dialog box.



At this dialog box, set the [Read Register] and after reception, the PLC data is read with the [Read Register] that is set.

Setting the [Read Register] is required at the PLC.

PCWAY reads the [Read Register] PLC node number as 1.

However, if there is a check in the [Use Link unit No. when connection by RS232C] check box in the dialog box brought up by selecting [Option (O)] from the [Settings (C)] menu of the [Operation Preferences] dialog box, the [Read Register PLC node number becomes 0.

The [Read Register] stores the values given below.


- 1st word: Fixed to K1.
- 2nd word: Event number to turn on (specified by HEX).
- 3rd word: Fixed to K1.

Since the data value that becomes the event number is stored in the data value of the 2nd word, that event is set to on.

To inform the PLC of the connection, click the [Over 65 Regions (O)] button and set the informing relay at the [MODEM (Over 65 Regions)].


The [Informing Relay] is set to on only for the PLC with the node number 1.

However, if there is a check in the [Use Link unit No. when connection by RS232C] check box in the dialog box brought up by selecting [Option (O)] from the [Settings (C)] menu of the [Operation Preferences] dialog box, the [Informing Relay] PLC node number becomes 0.

Click the  button and place a check at node number 1 in the [Connection No.] dialog box that appears.

#### 4.8.1.3 Informing of Errors to a Personal Computer from PLCs (Same Port)

The phrase "same port" refers to the port number when [MODEM] is selected under [Network Type] on the **Communication Settings (S)** menu item under Network for [Operation Preferences] in the PCWAY being the same as that specified for **Communication Settings (A)** under [Error Reception]. Reception is made possible by placing a check in the [Receive] check box for [Error Reception] in the [Operation Preferences] dialog box. Click the **Communication Settings (A)** button and perform the required settings at the [Communication Setting-Operation Preferences [Error... ] dialog box that appears.




The [Read Register] setting is required at the PLC.



**When there are less than 65 PLCs connected.**

Click the [Modem Support] button and then [All Settings] to set the [Read Register].



With this [Read Register], the first 3 words of the PLC data are read. PCWAY reads the PLC with the node number 1 for the [Read Register].

However, if there is a check in the [Use Link unit No. when connection by RS232C] check box in the dialog box brought up by selecting [Option (O)] from the [Settings (C)] menu of the [Operation Preferences] dialog box, the [Read Register] PLC node number becomes 0.

At the PLC, it is necessary to store the values given below.

1st word:

The Modem Support register number is stored as a decimal number (if the register number is 5, store K5).

2nd word:

The event number that you want to turn on during phone line connection is stored as a hexadecimal number (if the event number is 2F, store H2F)


If there is no event number that you want to turn on, then store H FFFF.

3rd word:

Fixed to the decimal value 0 (K0).

Since the data value of the 2nd word becomes the event number, that event is set to ON.

To inform the PLC of the connection, click on [Details (D)] button at the Modem Support dialog box and set the [Informing Relay].




When connection by the phone line is made, it turns from off to on.

Also, if there is link relay that is on from the link relay area set at [C-NET Settings] or trigger event, they will be executed.

Afterwards, the informing relay is set to off to inform the PLC that connection is severed and the connection is automatically severed.

## When there are 65 or more PLCs connected

Place a check in the [Over 65 Regions] check box for [Number of regions] in the [Operation Preferences] dialog box and click the  button to display the [MODEM (Over 65 Regions)] dialog box.



At this dialog box, set the [Read Register], and with this [Read Register], the first 3 words of the PLC data are read.

PCWAY reads the PLC with the node number 1 for the [Read Register].

However, if there is a check in the [Use Link unit No. when connection by RS232C] check box in the dialog box brought up by selecting [Option (O)] from the [Settings (C)] menu of the [Operation Preferences] dialog box, the [Read Register] PLC node number becomes 0.

At the PLC, it is necessary to store the values given below.

1st word:

Fixed to the decimal value 1 (K1).

2nd word:

The event number that you want to turn on during phone line connection is stored as a hexadecimal number (if the event number is 2F, store H2F)

If there is no event number that you want to turn on, then store H FFFF.

3rd word:


Fixed to the decimal value 0 (K0).

Since the data value of the 2nd word becomes the event number, that event is set to ON.

If it is necessary to inform the PLC of the connection, set the informing relay at the [MODEM (Over 65 Regions)].

The [Informing Relay] turns on for the PLC with the node number 1 only.

However, if there is a check in the [Use Link unit No. when connection by RS232C] check box in the dialog box brought up by selecting [Option (O)] from the [Settings (C)] menu of the [Operation Preferences] dialog box, the [Informing Relay] PLC node number becomes 0.

Click the  button and place a check at node number 1 in the [Connection No.] dialog box that appears.

When connection by the phone line is made, it turns from off to on.

Also, if there are relay links that are turned on and set as trigger events from the relay link area set at [C-NET Settings], they will be executed.


Afterwards, the informing relay is set to off to inform the PLC that connection is severed and the connection is automatically severed.

#### 4.8.1.4 Informing of Errors to a Personal Computer from PLCs (Different Port)

The phrase "different port" means that the port number when [MODEM] is selected under [Network Type] on the **Communication Settings(S)** menu item under Network for [Operation Preferences] in the PCWAY being different from that specified for **Communication Settings(A)** under [Error Reception].

Reception is made possible by placing a check in the [Receive] check box for [Error Reception] in the [Operation Preferences] dialog box.


Click the **Communication Settings(A)** button and perform the required settings at the [Communication Setting-Operation Preferences [Error... ] dialog box.



The [Read Register] setting is required at the PLC.

When there are less than 65 PLCs connected.

Click the [Modem Support] button and then [All Settings] to set the [Read Register].



With this [Read Register], the first 3 words of the PLC data are read. PCWAY reads the PLC with the node number 1 for the Read Register.

However, if there is a check in the [Use Link unit No. when connection by RS232C] check box in the dialog box brought up by selecting [Option (O)] from the [Settings (C)] menu of the [Operation Preferences] dialog box, the [Read Register] PLC node number becomes 0.

At the PLC, it is necessary to store the values given below.


- 1st word: The [Modem Support] register number is stored as a decimal number (if the register number is 5, store K5).
- 2nd word: The event number that you want to turn on during phone line connection is stored as a hexadecimal number (if the event number is 2F, store H2F)  
If there is no event number that you want to turn on, then store H FFFF.
- 3rd word: Fixed to the decimal value 0 (K0).

The data value stored in the 2nd word becomes the event number, and that event is set to ON. Furthermore, only the files that are triggered by that event are executed. Once they are completed, the connection is severed immediately.

You cannot inform the PLC of the connection. The registering of the informing relay becomes invalid.

### When there are 65 or more PLCs connected

Place a check in the [Over 65 Regions] check box for [Number of regions] in the [Operation Preferences] dialog box and click the  button to display the MODEM (Over 65 Regions) dialog box.



At this dialog box, set the [Read Register], and with this [Read Register], the first 3 words of the PLC data are read.

PCWAY reads the PLC with the node number 1 for the [Read Register].

However, if there is a check in the [Use Link unit No. when connection by RS232C] check box in the dialog box brought up by selecting [Option (O)] from the [Settings (C)] menu of the [Operation Preferences] dialog box, the [Read Register] PLC node number becomes 0.

At the PLC, it is necessary to store the values given below.

- 1st word: Fixed to the decimal value 1 (K1).
- 2nd word: The event number that you want to turn on during phone line connection is stored as a hexadecimal number (if the event number is 2F, store H2F)  
If there is no event number that you want to turn on, then store H FFFF.
- 3rd word: Fixed to the decimal value 0 (K0).



The data value stored in the 2nd word becomes the event number, and that event is set to ON. Furthermore, only the files that are triggered by that event are executed.

Once they are completed, the connection is severed immediately.

You cannot inform the PLC of the connection. The registering of the informing relay becomes invalid.


## 4.8.2 When Thereare Less Than 65 Remote Regions

Remove the check in the [Over 65 Regions] check box for [Number of regions] in the Operation Preferences dialog box. The **Modem Support(O)** button appears. Click on it and perform the required settings in the dialog box that appears.




- Using the public phone lines, you can keep track of the data from remote PLCs (max. 64 regions), display the data, perform operations with the data, and save the data as files. Once a remote PLC is connected to the public phone lines, you are able to use all the functions provided with PCWAY.


- Click the **Communication Settings(S)** button for [Network] in the [Operation Preferences] dialog box.  
Choose [MODEM] for [Network Type] and properly set the communication settings.



- There are two types of connections: ongoing connection (where connection is maintained until it is severed off) and single connection (where connection is automatically severed after all the remote PLCs are scanned once).  
Also, you can have the single connection performed all registered remote regions in rotation.
- Connection at the phone line is initiated when the specified event(V) turns ON.





- It is also possible to report errors to PCWAY from remote PLCs using public phone lines. This function can be used even if the PCWAY network type is not set to MODEM (i.e., MEWNET-H, or C-NET (RS232C). However, if the network type is C-NET (RS232C), then two or more COM ports are required.
- Place a check in the [Receive] check box for [Error Reception] in the [Operation Preferences] dialog box and click the  button. Perform the required communication settings at the dialog box that appears.




- The node number for the remote PLC that will inform PCWAY of the error (dial the phone) is restricted to 1.

- Using the public phone lines, it is possible to connect to PCWAY from remote PLCs. This basic functioning is opposite to that when connecting to remote PLCs from PCWAY as described above. Once PCWAY is connected to the public phone lines, you are able to use all the functions provided with PCWAY.
- Click the **Communication Settings(S)** button for [Network] in the [Operation Preferences] dialog box. Choose [MODEM] for [Network Type] and properly set the communication settings.



- Place a check in the [Receive] check box for [Network] in the [Operation Preferences] dialog box and click the  button. Perform the required reception settings at the dialog box that appears.




For more details regarding the reception settings, refer to the module list in **6.1 Setting Operation Preferences**.

#### 4.8.2.1 Surveillance of Remote PLCs(Connection from PCWAY)

##### Operation of Phone Line Connection

Remove the check from the Over 65 Regions check box for Number of regions in the Operation Preferences dialog box. Click the **Modem Support (Q)** button that appears and perform the required settings in the dialog box that appears.



The processes for phone line connection are to be performed in the order given below.

### 1. Start

Phone line connection processing starts when the specified event(V) turns on. Connection is maintained while the specified event(V) remains on. Connection is severed when the specified event(V) turns off.




## ◆ NOTE

**Set the use for the RS232C port on the PLC side to "Perform the computer link".**

### 2. Calls up

PCWAY dials the specified phone number and waits for a response. If a normal response is given, phone line connection is made. If an error response is given, or if a response is not given after a certain period of time, connection is not made.

(The set period time for waiting is set by clicking the  button for [Network] in the [Operation Preferences] dialog box and specifying the desired wait time at [Public Line Timeout].)

### 3. Read the PLC status

After connection is established, PCWAY will read the statuses of the PLC node numbers set at Connection No. (P) in order.

If there is a PLC whose status cannot be read, a retry will be attempted at least once.



## ◆ NOTE

**Regarding the amount of retries:**

**If there is a PLC whose status cannot be read, retries will be attempted until the time set for [Public Line Timeout] elapses. If the status cannot be read by then, that PLC will be considered to be disconnected.**

If the status of none of the set PLC nodes can be read, connection is severed.

### 4. Inform PLC of phone line connection

In order to alert the user that the PLC judged to be connected is connected to the line, the setting for [Relay] specified for the node number registered for Node, which is displayed by pressing [Details (D)] under [Modem Support] is turned off and then goes on.

This relay going on means that the line connection on the PLC side has been confirmed.

(Since it is possible that an error could have occurred at the PLC leaving the informing relay on from the last phone line connection, it is first turned off and then on again.  
The duration the informing relay is turned off can be set at [Relay ON Time] for [Pulse Width Settings] in the [Operation Preferences] dialog box.)

### 5. Turn on the informing event

If an [Informing Event] is set at the [Modem Support] dialog box, the [Informing Event] turns on after the [Informing Relay] turns on.

It is also possible to have internal PCWAY processes (File Processing, etc.) work together with this event.

### 6. PLC surveillance

First the relay link area set with [C-NET Settings] is checked.

If a relay link area that is on is set as a trigger, the corresponding internal processing ([File Processing], etc.) will be carried out.

Then the currently active Microsoft® Excel sheet is updated.

## Operation of Phone Line Disconnection

The processes for phone line disconnection are to be performed in the order given below.

### 1. Start of phone line disconnection

Severing of the phone line connection for ongoing connection starts when the specified event (V) turns off.

For single connection, severing of the phone line connection starts when the displayed sheet data during connection is completely updated.

If information is being communicated back and forth between the trigger device for the internal processing (file processing, etc.) and the information relay between two or more PLCs, however, the cutoff processing does not begin until the communication processing has been completed.

For example if the informing relay turned on because the internal PCWAY processing completed, but the trigger device at the PLC did not turn off. Also, when the PLC data in the currently active Microsoft® Excel sheet is not all updated, disconnection starts after all the data is updated.

### 2. Inform PLC of phone line disconnection

For the node numbers specified at [Node] in the dialog box displayed by clicking the [Details (D)] button at the [Modem Support] dialog box, the informing relay is turned off.

### 3. Phone line disconnection

## Form of Phone Line Connection

### • Single Trigger and Ongoing Trigger

There are two methods for phone line connections: single trigger and ongoing trigger.

#### - Single trigger:

After phone line connection, each PLC is scanned. Then, after the internal processing (file processing, etc.) is performed by relay link areas that are on at the time of the scan, the data in the active Microsoft® Excel sheet is updated.

Then the phone line connection is automatically severed.

The events to start this process is set at the Sin. Trig. column of the [Modem Support] dialog box.

After disconnection, these events are automatically turned off.

#### - Ongoing trigger:

Connection is maintained until it is severed.

Set the events to start this process at the Ong. Trig. column of the [Modem Support] dialog box.

Connection is maintained until these events go off.

You can also set the [Limited Time (min)] for the connection.

When this [limited time] elapses, the connection is severed and the event set as Ong. Trig. are set to off.

- **Rotating connection**

If you wish to automatically rotate among the specified regions and make connections, then click the Modem Support button, All Settings button, and set [Set All Trigger] in the dialog box that appears.

When the event set at Set All Trigger turns on, the Sin. Trig. set for each region are all turned on. (The Ong. Trig. are not turned on.)

Then, a single connection is performed rotating through each region.

The connection interval for each region is set by clicking the [All Settings] button and setting [Next Connection Time] in the dialog box that appears.

After the rotation is completed, the event set at [Set All Trigger] automatically turns off.

- **Interrupting the connection:**

To interrupt (pause) the rotating connection, click on the [All Settings (A)] button in the [Modem Support] dialog box and set the [Interrupt Trigger]. When the event set by the [Interrupt Trigger] turns on, all the Sin. Trig. not yet processed go into the standby state. This will not affect PLC that are connected.

When the event set by the [Interrupt Trigger] turns off, rotating connection resumes.

- **Forced termination:**

To forced the termination of the rotating connection, click on the [All Settings (A)] button in the [Modem Support] dialog box and set the [Terminate Trigger].

When the event set by the [Terminate Trigger] turns on, all the Sin. Trig. not yet processed turn off.

Then the event set by the [Terminate Trigger] automatically turns off.

### **Handling of Connection Errors**

1. If the condition of the phone line becomes faulty during connection and the connection is severed or all the connected PLC node numbers become disconnected, PCWAY considers it a connection error and severs the connection.  
If this occurs, the informing relay at the PLC side remains on.
2. By resuming phone line connection processes afterward, the informing relay at the PLC side turns off and then on again.

#### **4.8.2.2 Reporting of Errors from the PLC(Connection from PLCs)**


---

##### **Operation of Error Reception**

The PLC for informing of errors must adhere to the conditions given below.

- If there is only one remote PLC and it is C-NET connection with a C-NET adapter, then the PLC that dials the phone number must be set to node number 1.
- If the [COM Port] selected for [Communication Settings (S)] for Network is the same as the [COM Port] selected for [Communication Settings (A)] for [Error Reception].  
If the remote PLC is equipped with a MEWNET-H link unit and you also want to access a PLC of the same level with a different node number, place a check in the [Use Link unit No. when connection by RS232C] check box in the dialog box brought up by selecting [Option (O)] from the [Settings (C)] menu of the [Operation Preferences] dialog box.  
This allows access to other PLC node numbers.
- If the [COM Port] selected for [Communication Settings (S)] for [Network] is different from the [COM Port] selected for [Communication Settings (A)] for [Error Reception].  
Basically, only the PLC with the node number 1 can be accessed.  
However, by placing a check in the [Use Link unit No. when connection by RS232C] check box in the dialog box brought up by selecting [Option (O)] from the [Settings (C)] menu of the [Operation Preferences] dialog box, the PLC node number that is accessible can be changed to 0.  
Removing the check makes the PLC with the node number 1 accessible.

1. Place a check in the [Receive] check box for [Error Reception] in the [Operation Preferences] dialog box.
2. Remove the check in the [Over 65 Regions] check box for [Number of regions] in the [Operation Preferences] dialog box. The **Modem Support (Q)** button appears. Click on it and perform the required settings in the dialog box that appears.



- When the PLC dials the phone number and informs of the error, PCWAY reacts by performing the processes given below.

### 1. Recognizes RING

When the PLC calls up, PCWAY receives the RING. After the RING is received, it waits for CONNECT.

### 2. Receives CONNECT

With the reception of CONNECT, it recognizes the reception of an error.

### 3. Reads the read register of node number 1

Reads three words of the PLC data at the [Read Register] set at the dialog box displayed by clicking the [All Settings (A)] button at the [Modem Support] dialog box.

At the PLC, the [Read Register] is necessary to store the values given below.

- 1st word: The [Modem Support] register number is stored as a decimal number (if the register number is 5, store K5).
- 2nd word: The event number that you want to turn on during phone line connection is stored as a hexadecimal number (if the event number is 2F, store H2F). If there is no event number that you want to turn on, then store "H FFFF".
- 3rd word: Fixed to the decimal value 0 (K0).





## ◆ NOTE

**The processes afterward differ depending on the "Operation Preferences" dialog box settings.**

If the modem port is different from the serial port number where the error reception occurred, the [Read Resister] described above is read, and then the event specified for the second word of the [Read Resister] is turned on, and only the file processing specified for the trigger device of that event number is carried out.

Following that, the line of the serial port on the error reception side is cut off.

Please be aware, however, that if any other internal processing has been specified for the trigger informing event for which file processing is being carried out, the line will have already been cut off before that processing is carried out.

Also, be aware that processing other than the file processing which is specified using the event number of the second word for the [Read Resister] will be executed after the line has been cut off.

### Additions

1. The contents of the 1st word for [Read Register] are ignored.
2. This process is only recognized if an error is received.  
If you want to check the contents of the error, it will be necessary to link the event set by the 2nd word of the [Read Register] with the single trigger or ongoing trigger at the [Modem Support] dialog box and resume connection.

Below is the explanation when the same serial port is set for the modem and error reception.

#### 4. The event stored in the 2nd word of the [Read Register] is turned on

If "H FFFF" is stored in the 2nd word of the read register, then it will not be processed.

#### 5. Read the PLC status

From here, operation is based on the contents of numbers registered at [Modem Support] and stored in the 1st word of the [Read Register].

After connection is established, PCWAY will read the statuses of the PLC node numbers set at [Connection No. (P)] in order.

If there is a PLC whose status cannot be read, a retry will be attempted at least once.



## ◆ NOTE

**Regarding the amount of retries:**

**If there is a PLC whose status cannot be read, retries will be attempted until the time set for "Public Line Timeout" elapses. If the status cannot be read by then, that PLC will be considered to be disconnected.**

**If the status of none of the set PLC nodes can be read, connection is severed.**

#### 6. Inform PLC of phone line connection

To inform the connected status to the PLCs that are considered to be connected, for the node numbers specified at [Node] in the dialog box displayed by clicking the [Details (D)] button at the [Modem Support] dialog box, the [Informing Relay] is turned off and then on.

By this relay turning on, the PLC can verify the status of the phone line connection.

(Since it is possible that an error could have occurred at the PLC leaving the informing relay on from the last phone line connection, it is first turned off and then on again.  
The duration the informing relay is turned off can be set at [Relay ON Time] for [Pulse Width Settings] in the [Operation Preferences] dialog box.)

#### 7. PLC surveillance

First the relay link area set with [C-NET Settings] is checked. If a relay link area that is on is set as a trigger, the corresponding internal processing (file processing, etc.) will be carried out. Then the content of currently active Microsoft® Excel sheet is updated.

## 8. Inform PLC of phone line disconnection

For the node numbers specified at [Node] in the dialog box displayed by clicking the [Details (D)] button at the [Modem Support] dialog box, the relay specified at [Informing Relay] is turned off.

## 9. Phone line disconnection

### Concerning the Error Informing PLC

It is important to be aware of the information given below regarding the error informing PLC.

- Before calling, it is necessary to have the RS232C port usage set to [Use Serial Data Communication] (multi-purpose port).

Setting method:

Set using one of the following methods

- Programming tool software
- FP programmer
- Program inside PLC (F144)

- After calling, make sure to immediately change RS232C port usage to the [Computer link] setting after receiving CONNECT.

Setting method:

Set using one of the following methods

- Programming tool software
- FP programmer
- Program inside PLC (F144)

- Set the timeout time until receiving CONNECT to that of the PCWAY [Resend Wait Time] set at the dialog box displayed by clicking [All Settings (A)] at the [Modem Support] dialog box.

(When calling up each other or when making retry attempts, make sure that the retries are not made at the same timing.)


### 4.8.2.3 Connecting from a PLC

#### Operation of Phone Line Connection from a PLC

- Place a check in the [Receive] check box for [Network] in the [Operation Preferences] dialog box to allow phone line connection from PLCs.
- Remove the check in the [Over 65 Regions] check box for [Number of regions] in the [Operation Preferences] dialog box.

The **Modem Support (Q)** button appears.

Click on it and perform the required settings in the dialog box that appears.



When the PLC makes a phone line connection, PCWAY reacts by performing the processes given below.

#### **1. Receive phone call**

When the phone call is received from the PLC, if the [Event] to confirm the connection turns on within the [Waiting time] to confirm the connection, connection is made.

If it does not turn on, connection is not made. Also, if a check is placed in the [Event automatically turn on] check box, connection is made.

#### **2. Reads the read register**

Reads three words of the PLC data at the read register set at the dialog box displayed by clicking the [All Settings (A)] button at the [Modem Support] dialog box. At the PLC, it is necessary to store the values given below.

1st word: The [Modem Support] register number is stored as a decimal number.

2nd word: The event number that you want to turn on (specified in HEX).

3rd word: Fixed to K1.

Since the data value that becomes the event number is stored in the data value of the 2nd word, that event is set to on.

#### **3. Inform PLC of phone line connection**

To inform the connected status to the PLCs that are considered to be connected, you must set the informing relay.

This is done at the dialog box displayed by clicking the [Details (D)] button at the [Modem Support] dialog box.

You can specify more than one node number.

By this relay turning on, the PLC can verify the status of the phone line connection.

#### **4. Phone line disconnection**

When the [Event] to confirm the connection turns off, the phone line is disconnected.

Or, if the [Event] has not been turned on, the line is automatically cut off if the setting of the [Waiting Time] parameter is exceeded.

### **Concerning the Phone Line Connecting PLC**

It is important to be aware of the information given below regarding the phone line connecting PLC.


- Before calling, it is necessary to have the RS232C port usage set to [Use Serial Data Communication] (general-purpose port).  
Setting method:  
Set using one of the following methods
  - Programming tool software
  - FP programmer
  - Program inside PLC (F144)
- After calling, make sure to immediately change RS232C port usage to the [Perform computer link] setting after receiving CONNECT.  
Setting method:  
Set using one of the following methods
  - Programming tool software
  - FP programmer
  - Program inside PLC (F144)

## 4.8.3 When There are More than 65 Remote Regions

Place a check in the [Over 65 Regions] check box for [Number of regions] in the [Operation Preferences] dialog box.


The **Over 65 Regions(Q)** button appears.

Click on it and perform the required settings in the dialog box that appears.



- Using the public phone lines, you can keep track of the data from remote PLCs (max. 4096 regions), display the data, perform operations with the data, and save the data as files. Once a remote PLC is connected to the public phone lines, you are able to use all the functions provided with PCWAY.

- Click the **Communication Settings(S)** button for [Network] in the [Operation Preferences] dialog box. Choose [MODEM] for [Network Type] and properly set the communication settings.




- It is assumed that phone line connection will be performed manually with [Modem Support] by storing the various remote region settings (telephone number, etc.) at [Modem Support]. For more information regarding settings, refer to the Help supplied with [Modem Support].
- Connection at the phone line is initiated when the specified event(V) turns on.

- It is also possible to inform errors to PCWAY from remote PLCs using public phone lines. This function can be used even if the PCWAY network type is not set to modem (i.e., MEWNET-H, or C-NET (RS232C). However, if the network type is C-NET (RS232C), then two or more COM ports are required.

Place a check in the [Receive] check box for [Error Reception] in the [Operation Preferences]

dialog box and click the  button.


Perform the required communication settings in the dialog box that appears.



The node number for the remote PLC that will inform PCWAY of the error (dial the phone) is restricted to 1.


- Using the public phone lines, it is possible to connect to PCWAY from remote PLCs.  
This basic functioning is opposite to that when connecting to remote PLCs from PCWAY.  
Once PCWAY is connected to the public phone lines, you are able to use all the functions provided with PCWAY.

Click the **Communication Settings (S)** button for [Network] in the [Operation Preferences] dialog box. Choose [MODEM] for [Network Type] and properly set the communication settings.





Place a check in the [Receive] check box for [Network] in the [Operation Preferences] dialog box and click the button. Perform the required reception settings in the dialog box that appears.




For more details regarding the reception settings, refer to **6.1 Setting Operation Preferences**.

#### 4.8.3.1 Surveillance of Remote PLCs(Connection from PCWAY)



##### Operation of Phone Line Connection

Place a check in the [Over 65 Regions] check box for [Number of regions] in the [Operation Preferences] dialog box.

The  button appears.

Click on it and perform the required settings in the dialog box that appears.

For more details regarding the settings, refer to **6.1 Setting Operation Preferences**



Line connection is carried out in the sequence described below.

### 1. Start

Phone line connection is performed manually with [Modem Support] by storing the various remote region settings (telephone number, etc.) at [Modem Support].  
For more information regarding settings, refer to the Help supplied with [Modem Support].



#### ◆ NOTE

**Set the use for the RS232C port on the PLC side to "perform the computer link".**

### 2. Calls up

PCWAY dials the specified phone number and waits for a response. If a normal response is given, phone line connection is made. If an error response is given, or if a response is not given after a certain period of time, connection is not made.  
(The waiting time is set at [Modem Support].)

### 3. Read the PLC status

After connection is established, PCWAY will read the statuses of the PLC node numbers set at [Connection No. (P)] in order.  
If there is a PLC whose status cannot be read, a retry will be attempted at least once.




#### ◆ NOTE

**Regarding the amount of retries:**

**If there is a PLC whose status cannot be read, retries will be attempted until the time set for "Public Line Timeout" elapses. If the status cannot be read by then, that PLC will be considered to be disconnected.**

### 4. Inform PLC of phone line connection

To inform the connected status to the PLCs that are considered to be connected, the informing relay specified for node number 1 is turned off first and then turned on again.  
When this relay turns on, the PLC can verify the condition of the phone line connection.  
This [Informing Relay] is set at the dialog box displayed by clicking the [Over 65 Regions (O)] button in the [Operation Preferences] dialog box.

Then click the  button and set the PLC connection node number by placing a check at node number 1 in the dialog box that appears. (Be sure to set the connection node number to 1.)

If an error occurs on the PLC side, it is assumed that the information relay may still be on from the previous connection, so the relay is turned off first and then turned on again.  
The period of time for which the relay is off can be specified using the [Relay ON Time] setting for [Pulse Width Settings] under [Operation Preferences].

### 5. Turn on the informing event

If an [Informing Event] is set at the dialog box displaying by clicking the [Over 65 Regions] button, the informing event turns on after the informing relay turns on.  
It is also possible to have other internal PCWAY processes (file processing, etc.) work together with this event.

### 6. PLC surveillance

First the link relay area set with [C-NET Settings] is checked.  
If a relay link area that is on is set as a trigger, the corresponding internal processing (file processing, etc.) will be carried out.  
Then the currently active Microsoft® Excel sheet is updated.

## Operation of Phone Line Disconnection

The processes for phone line disconnection are to be performed in the order given below.

### 1. Phone line disconnection

Cutting of the phone line connection is performed manually using [Modem Support].

However, if interaction between the trigger device informing relay for internal processing (file processing, etc.) is between PLCs and incomplete, disconnection will not start until that processing is finished.

For example if the informing relay turned on because the internal PCWAY processing completed, but the trigger device at the PLC did not turn off. Also, when the PLC data in the currently active Microsoft® Excel sheet is not all updated, disconnection starts after all the data is updated.

### 2. Inform PLC of phone line disconnection

The informing relay specified for node number 1 turns off.

### 3. Phone line disconnection

## Form of Phone Line Connection

### • Modem Support

Phone line connection is performed manually using [Modem Support].

Connection is made with the contents entered at this screen.

After connection, the processing for the informing relay (for node number 1) and informing event set in the dialog box displayed by clicking the [Over 65 Regions] button for [Number of regions] in the [Operation Preferences] dialog box is performed.

For disconnection, use [Modem Support] and perform the disconnection manually using the same procedures used to for connection.

For more information regarding [Modem Support], refer to the Help supplied with [Modem Support].

## Handling of Connection Errors


1. If the condition of the phone line becomes faulty during connection and the connection is severed or all the connected PLC node numbers become disconnected, PCWAY considers connection has not been made and enters the connection standby state.
2. Perform the disconnection processes with [Modem Support] and then make the connection again with [Modem Support] to turn off the informing relay at the PLC and then turn it on again.

### 4.8.3.2 Informing of Errors from the PLC(Connection from PLCs)

#### Operation If an Error is received


The PLC for informing of errors must adhere to the conditions given below.

- If there is only one remote PLC and it is C-NET connection with a C-NET adapter, then the PLC that dials the phone number must be set to node number 1.
  - If the [COM Port] selected for [Communication Settings (S)] for [Network] is the same as the [COM Port] selected for [Communication Settings (A)] for [Error Reception].  
If the remote PLC is equipped with a MEWNET-H link unit and you also want to access a PLC of the same level with a different node number, place a check in the [Use Link unit No. when connection by RS232C] check box in the dialog box brought up by selecting [Option (O)] from the [Settings (C)] menu of the [Operation Preferences] dialog box.  
This allows access to other PLC node numbers.
  - If the [COM Port] selected for [Communication Settings (S)] for [Network] is different from the [COM Port] selected for [Communication Settings (A)] for [Error Reception].  
Basically, only the PLC with the node number 1 can be accessed.  
However, by placing a check in the [Use Link unit No. when connection by RS232C] check box in the dialog box brought up by selecting [Option (O)] from the [Settings (C)] menu of the [Operation Preferences] dialog box, the PLC node number that is accessible can be changed to 0.  
Removing the check makes the PLC with the node number 1 accessible.
1. Place a check in the [Receive] check box for [Error Reception] in the [Operation Preferences] dialog box.
  2. Place a check in the [Over 65 Regions] check box for [Number of regions] in the [Operation

Preferences] dialog box. The  button appears.

Click on it and perform the required settings in the dialog box that appears.

For more details regarding the settings, refer to **6.1 Setting Operation Preferences**



When the PLC dials the phone number and informs of the error, PCWAY reacts by performing the processes given below.

#### **1. Recognizes RING**

When the PLC calls up, PCWAY receives the RING.  
After the RING is received, it waits for CONNECT.

#### **2. Receives CONNECT**

With the reception of CONNECT, it recognizes the reception of an error.

#### **3. Reads the read register of node number 1**

Reads three words of the PLC data at the read register set at the dialog box displayed by clicking the [Over 65 Regions (O)] button at the [Operation Preferences] dialog box.  
At the PLC, it is necessary to store the values given below.

1st word: Stores the decimal value 1 (K1).

2nd word: The event number that you want to turn on during phone line connection is stored as a hexadecimal number (if the event number is 2F, store H2F)  
If there is no event number that you want to turn on, then store H FFFF.

3rd word: Fixed to the decimal value 0 (K0).



#### **◆ NOTE**

**The processes afterward differ depending on the "Operation Preferences" dialog box settings.**

If the serial ports for the modem and error reception differ, after the above read register is read, the event set in the 2nd word of the read register is turned on, the processing for the file set to be triggered by that event number is executed, and the connection is severed at the serial port on the error reception side.

Please be aware, however, that if any other internal processing has been specified for the trigger device event for which file processing is being carried out, the line will have already been cut off before that processing is carried out.

Furthermore, if the event number of the 2nd word of the read register is used for purposes other than file processing, they will be executed after the connection is severed.

#### **Addition**

1. The contents of the 1st word for read register are ignored.
2. This process is only recognized if an error is received. If you want to check the contents of the error, it will be necessary to execute the file processing with the event set by the 2nd word of the read register and gather the data at the PLC.

Followings are the explanation when the same serial port is set for the modem and error reception.

#### **4. The event stored in the 2nd word of the read register is turned on**

If "H FFFF" is stored in the 2nd word of the read register, then it will not be processed.

#### **5. Read the PLC status**

After connection is established, PCWAY will read the statuses of the PLC node numbers set at [Connection No. (P)] in order. If there is a PLC whose status cannot be read, a retry will be attempted at least once.



## ◆ NOTE

**Regarding the amount of retries:**

**If there is a PLC whose status cannot be read, retries will be attempted until the time set for "Public Line Timeout" elapses. If the status cannot be read by then, that PLC will be considered to be disconnected.**

### 6. Inform PLC of phone line connection

To inform the connected status to the PLC at node number 1, the informing relay for the PLC at node number 1 is turned off and then on.

By this relay turning on, the PLC can verify the status of the phone line connection.

The informing relay is set at the dialog box displayed by clicking the [Over 65 Regions (O)] button for [Number of regions] in the [Operations Preferences] dialog box.

However, if there is a check in the [Use Link unit No. when connection by RS232C] check box in the dialog box brought up by selecting [Option (O)] from the [Settings (C)] menu of the [Operation Preferences] dialog box, the [Informing Relay] PLC node number becomes 0.

You can also set the informing relay by clicking the [Connection No. (P)] button at the dialog box and then placing a check at node number 1.

(Since it is possible that an error could have occurred at the PLC leaving the informing relay on from the last phone line connection, it is first turned off and then on again. The duration the informing relay is turned off can be set at [Relay ON Time] for [Pulse Width Settings] in the [Operation Preferences] dialog box.)

### 7. PLC surveillance

First the relay link area set with [C-NET Settings] is checked. If a relay link area that is on is set as a trigger, the corresponding internal processing (file processing, etc.) will be carried out. Then the currently active Microsoft® Excel sheet is updated.

### 8. Inform PLC of phone line disconnection

The informing relay set for the PLC at node number 1 is turned off. However, if there is a check in the [Use Link unit No. when connection by RS232C] check box in the dialog box brought up by selecting [Option (O)] from the [Settings (C)] menu of the [Operation Preferences] dialog box, the [Informing Relay] PLC node number becomes 0.

### 9. Phone line disconnection

#### Concerning the error informing PLC

It is important to be aware of the information given below regarding the error informing PLC.

1. Before calling, it is necessary to have the RS232C port usage set to Use Serial Data Communication (general-purpose port).

Setting method:

Set using one of the following methods

- Programming tool software
- FP programmer
- Program inside PLC (F144)

2. After calling, make sure to immediately change RS232C port usage to the Perform computer link setting after receiving CONNECT.

Setting method:


Set using one of the following methods

- Programming tool software
- FP programmer
- Program inside PLC (F144)

### 4.8.3.3 Connecting from a PLC

#### Operation of Phone Line Connection

- Place a check in the Receive check box for [Network] in the [Operation Preferences] dialog box to allow phone line connection from PLCs.
- Place a check in the [Over 65 Regions] check box for [Number of regions] in the [Operation Preferences] dialog box. The **Over 65 Regions (Q)** button appears. Click on it and perform the required settings in the dialog box that appears. For more details regarding the settings, refer to **6.1 Setting Operation Preferences**





When the PLC makes a phone line connection, PCWAY reacts by performing the processes given below.

### 1. Receive phone call

When the phone call is received from the PLC, if the [Event] turns on within the [Waiting time], connection is maintained.

If it does not turn on, connection is severed.

Also, if a check is placed in the [Event automatically turn on] check box, connection is made.

### 2. Reads the read register

At the PLC, it is necessary to store the values given below.

1st word: Fixed to K1.

2nd word: The event number that you want to turn on (specified in HEX).

3rd word: Fixed to K1.


Reads three words of the PLC data at the read register set at the dialog box displayed by clicking the [Over 65 Regions (O)] button at the [Operation Preferences] dialog box.

Since the data value that becomes the event number is stored in the data value of the 2nd word, that event is set to on.

### 3. Inform PLC of phone line connection

To inform of the connected status to the PLCs that are considered to be connected, it is necessary to register the informing relay. The [Informing Relay] is set at the dialog box displayed by clicking the [Over 65 Regions (O)] button for [Number of regions] in the [Operations Preferences] dialog box.

Since the informing relay only turns on for the PLC at node number 1, click the [Over 65

Regions (O)] button in the [Operation Preferences] dialog box, click the  button, and then place a check at node number 1 in the dialog box that appears.

However, if there is a check in the [Use Link unit No. when connection by RS232C] check box in the dialog box brought up by selecting [Option (O)] from the [Settings (C)] menu of the [Operation Preferences] dialog box, the [Informing Relay] PLC node number becomes 0.

When this relay turns on, the PLC can verify the condition of the phone line connection.

### 4. Phone line disconnection

When the [Event] turns off, the phone line is disconnected.

Also, if the [Waiting time] elapses before the [Event] turns on, the phone line is automatically disconnected.

## Concerning the phone line connecting PLC

It is important to be aware of the information given below regarding the error informing PLC.

1. Before calling, it is necessary to have the RS232C port usage set to Use Serial Data Communication (general-purpose port).

Setting method:

Set using one of the following methods

- Programming tool software
- FP programmer
- Program inside PLC (F144)

2. After calling, make sure to immediately change RS232C port usage to the Perform computer link setting after receiving CONNECT.

Setting method:

Set using one of the following methods

- Programming tool software
- FP programmer
- Program inside PLC (F144)

## 4.9 Using the E-mail Function

---

The status information of the equipment monitored by the PLC can be sent from/to the specified PC and cellular phone's e-mail address using the e-mail function.

### 4.9.1 Overview

---

(1) E-mail function environment available for PCWAY

- Local area network (LAN) connection
- Dial-up connection (Dial-up connection setting using the PC is required. For details, refer to the operation manual for the PC you use.)

(2) Specifying the recipient address

Use the e-mail address or character string.

When the character string is specified, PCWAY receives the e-mail if the received e-mail includes the specified character string.

(3) Messages that can be sent from PCWAY

- Up to 256 characters (in one-byte characters). One message per e-mail can be sent.
- Microsoft® Excel Sheet data (One specified Microsoft® Excel Sheet range per e-mail. Example: (A1: C3))

(4) Files can be attached to an e-mail using PCWAY

- All files (Book in use with PCWAY can be sent after all Sheets are updated optionally.)
- Compressed files (LZH format self-extracting file) can be sent optionally.

For details concerning the settings above, refer to **6.18 E-mail Setting**.

## 4.9.2 Sending the Error Status Information to the PC and the Cellular Phone via E-mail

---

PCWAY monitors the PLC internal relay (R0) and sends the equipment status information to the PC and the cellular phone via e-mail when the internal relay (R0) changes from OFF to ON.

- When the error signal input from the equipment is "X0":

Internal relay: R0


Informing relay: R10

- Preconditions

Internal relay: It is necessary to have PCWAY recognize "R0" as the relay link "M0".

[ For MEWNET-H: Use the MEWNET-H setting software (Sold separately)  
For MEWNET-P: System register setting is required.  
For C-NET or the Modem: Refer to **6.11 C-NET Settings**. ]

- Program for the PLC



When "X0" turns ON, "R0" will be self-held.

- PCWAY settings

<E-mail Setting>

Trigger Device: M0

Informing relay: R10

For the settings other than "Trigger Device" and "Informing relay," enter the settings for the data you wish to send.

(For details concerning E-mail Setting, refer to **6.18 E-mail Setting**.)

### 4.9.3 Sending Equipment Status Information Periodically to the PC and the Cellular Phone via E-mail

---

Equipment status information can be sent to the PC and the cellular phone via e-mail at the specified day and time or at specified intervals.

- **Specifying the day and time**

E-mails are sent to the PC and the cellular phone at 18:00 on Fridays

- **PCWAY settings**

<Weekly Timer>  
Specified Time: 18:00  
Specified Day: ☒ Friday  
Device: V100

(For details concerning Weekly Timer, refer to **6.9 Weekly Timer.**)

<E-mail Setting>  
Trigger Device: V100

For the settings other than "Trigger Device," enter the settings for the data you wish to send.

(For details concerning E-mail Setting, refer to **6.18 E-mail Setting.**)

- **Specifying the intervals**

E-mails are sent to the PC and the cellular phone at intervals of 2 hours.  
(0:00, 2:00, 4:00, 6:00, 8:00.....22:00)

- **PCWAY settings**

<Interval Timer>  
Interval: 2 hours  
Device: V100


<E-mail Setting>  
Trigger Device: V100

For the settings other than "Trigger Device," enter the settings for the data you wish to send.

(For details concerning E-mail Setting, refer to **6.18 E-mail Setting.**)

#### 4.9.4 Inquiry on the Equipment Status from the PC and the Cellular Phone


The e-mail including the command that "V" (Event) of PCWAY should be turned ON is sent from the PC and the cellular phone to PCWAY. According to the "V" (Event), PCWAY responds the necessary information to them.



- E-mail is sent from the PC and the cellular phone to PCWAY, and the return mail is sent to them by turning the V100 (Event) ON.

##### 1. Sending the V100 to PCWAY.

The following characters are sent to PCWAY.



##### 2. Sending e-mail by entering V100 in Trigger Device

###### - PCWAY settings

###### <E-mail Setting>

Trigger Device: V100

For the settings other than "Trigger Device," enter the settings for the data you wish to send.

(For details concerning E-mail Setting, refer to **6.18 E-mail Setting.**)




## **Chapter 5**

---

### **Operations From the PCWAY Menubar**

## 5.1 Cell Settings

---

- Go to the menu bar->[PCWAY]->[Cell Settings(S)]
- Click 

Perform the settings for [Cell Settings]

### Target:

Select from the items listed below.

Concerning each of the settings, refer to **5.1.1 Setting method**.

- |                        |   |
|------------------------|---|
| (1)Relay               | Displays at real time, the ON/OFF information of the PLC relay. |
| (2)Register            | Displays at real time, based on the PLC register value.         |
| (3)File Data           | Displays the file data.   |
| (4)Event               | This is the internal relay area of the computer.                |
| (5)Connection          | Displays the connection condition of the PLC.                   |
| (6)Connection Settings | Does to Disable or Enable the Connection No. settings.          |

### Attribute:

#### Read Only

Select this when you will have the PLC relay or the register value displayed only. (at the Microsoft® Excel cell)

It is not possible to change the PLC register value or to operate the ON/OFF of the relay from the Microsoft® Excel cell.

#### Read/Write

Select this when you wish to display the PLC relay or the register value on to the Microsoft® Excel cell, or when you would like to operate the PLC relay or the register value directly from the cell.

#### Write Only

Make sure to select this attribute when you would like to specify the area of the data which is displayed on the Microsoft® Excel cell, and then have this downloaded all at once, to the PLC.

(Only [Read Only] can be selected for the file data.)



## 5.1.1 Setting method

### 5.1.1.1 Relay

The screenshot shows the 'Cell Settings' dialog box. It has two main sections: 'Target' and 'Attribute'. The 'Target' section has radio buttons for 'Relay' (selected), 'Register', 'File Data', 'Event', 'Connection', and 'Connection Settings'. The 'Attribute' section has radio buttons for 'Read Only', 'Read/Write' (selected), and 'Write Only'. Below these are several input fields: 'Node No.' with a dropdown menu showing '1' (callout 1), 'Device Code' with a dropdown menu showing 'Y : External Output' (callout 2), 'Device No.' with a text box showing '0' (callout 3), 'Operation Method' with a dropdown menu showing 'Level Operation' (callout 4), and 'Character Change No.' with a dropdown menu showing '1' (callout 5). There is a 'Character Change' button next to the 'Character Change No.' field. At the bottom, there is a checkbox labeled 'Next Time Open On Double-click' which is checked, and three buttons: 'OK', 'Cancel', and 'Delete'.

#### 1. Node No.

Select the node number from: 0 to 254



#### ◆ NOTE

When [Write Only] has been specified before as the attribute, then it is possible to select [All nodes].

This enables the changing of the status all at once, in accordance to all of the currently connected PLC's during the operating and the downloading.

#### 2. Device code

Left-click within [Device Code] and select the device code which you will use.



#### ◆ NOTE

When you have selected "M: Relay link area" at Device Code:

- If MODEM is selected under Network Type for the Network menu item under Operation Preferences, a C-NET No. (1 to 64) should be specified for 1 Node No.
- If anything other than MODEM is selected under Network Type for the Network menu item under Operation Preferences, always set "1" for 1 Node No.

### 3. Device No.

Input the device number.

### When you have selected Read/Write or Write Only at the Attribute

#### 4. Operation method

Select from: Level Operation, Pulse Operation, ON Operation, and OFF Operation.

Level Operation: It is possible to reverse the current status of the specified relay ON will change to OFF; OFF will change to ON


Pulse Operation: This supplies a positive logic pulse to the specified relay. After the relay goes on, it goes off for a specified period of time (the default value is 500 ms). The time period that the relay goes from on to off can be set using Operation Preferences.

ON operation: This will turn to ON, regardless of the current status of the specified relay.

OFF operation: This will turn to OFF, regardless of the current status of the specified relay.

#### 5. Character Change No.

Set the number of the [Character Change No.].

If you cannot recall the number, by left-clicking the  button, the registering window will be displayed.

Select the desired number and finish.

### 5.1.1.2 Register

The screenshot shows the 'Cell Settings' dialog box with the following fields and callouts:

- 1** → Node No. (Dropdown menu showing '1')
- 2** → Device Code (Dropdown menu showing 'DT : Data Register')
- 3** → Device No. (Text input field showing '0')
- 4** → Display Method (Dropdown menu showing 'NUM : Numeric Value')
- 5** → No. of Words (Dropdown menu showing '1')
- 6** → Operation Formula No. (Dropdown menu showing 'None' and an 'Operation Formula' button)
- 7** → Input Range (MIN and MAX text input fields, with a checked checkbox for 'Next Time Open On Double-click')

At the top, there are two sections: 'Target' with radio buttons for Relay, Register (selected), File Data, Event, Connection, and Connection Settings; and 'Attribute' with radio buttons for Read Only, Read/Write (selected), and Write Only.

#### 1. Node No.

Select the node number from: 0 to 254



#### ◆ NOTE

If you have specified this attribute as [Write Only], it is possible to select [All Nodes].

With this, it is possible to change the values all at once for all of the currently connected PLC's during the operating and the downloading.

#### 2. Device Code

Left-click within [Device Code] and select the desired device code.

#### 3. Device No.

Input the device number.

#### 4. Display method

Select the data displaying method.

NUM : Numerical Value	Performs the operation based on the value which has been stored in to the register and then performs Read/Write.
CHR : Character Code	Performs Read/Write with the value which has been stored in to the register as the character code.
MSG : Message Display	Changes the message or the display color and displays based on the value 0 to 4096 which has been stored in to the register. This can be selected only if [Attribute: Read Only] has been selected.
HEX : Hexadecimal Display	Performs Read/Write by hexadecimal, with the value which has been stored in to the register.
BIN : Binary Display	Performs Read/Write by binary, with the value which has been stored in to the register.
MEW : MEW Notation	This is the same specification as the PLC relay number. The 1st digit is described in hexadecimal and the digits after the 2nd digit, is described in decimal.
RAL : Real number	Reads or Writes the Real number of 2 word of PLC register. Real number is IEEE (Institute of Electrical and Electronics Engineers) format.

#### 5. No. of words


Left-click within [No. of Words] and select the number of words which you will use.

Display method	Word numbers
NUM: Numerical value HEX: Hexadecimal Display BIN: Binary Display MEW: MEW Notation	1 word or 2 words
CHR: Character Code	1 word~16 words
MSG: Message Display	1 word
RAL: Real number	2 words


#### 6. Operation Formula No. or Message No.

- When "Display Method" is set to "NUM: Numerical Value", "RAL: Real Number"  
[Operation Formula No.]

Set the number for the operation formula.

When you are not sure of the number, by left-clicking the  button, the registering window will be displayed. With this, select the desired number and finish.

- When "Display Method" is set to "MSG: Message Display"  
[Message No.]

Set the varying numbers for the message. When you are not sure of the number to set, by left-clicking the  button, the registering window will be displayed. With this, select the desired number and finish.

- When "Attribute" is set to "Read/Write" or "Write Only"

#### 7. Input Range

When you would like to check the Min. and Max. range for the value which you will change, then it is necessary for you to set the minimum value and the maximum value at MIN and MAX. When you have done this, only the MIN =<X =< MAX value is imputable.

### 5.1.1.3 File data

Cell Settings

Target

- ☐ Relay
- ☐ Register
- ☒ File Data
- ☐ Event
- ☐ Connection
- ☐ Connection Settings

Attribute

- ☒ Read Only
- ☐ Read/Write
- ☐ Write Only

1 → File No. 1 File No. Reference

2 → Generation Generation 1

3 → Display Method Display All Records At Once


4 → Update Method Update File Contents Each Time

☒ Next Time Open On Double-click

OK Cancel Delete

#### 1. File No.

Set the number for [File Master].

When you are sure of the number to choose, by left-clicking  button, the registering screen will be displayed. Select the file number which you will use and finish.

#### 2. Generation

Left-click within [Generation] and select the desired generation.

#### 3. Display Method

Specify the method on account of reading the file.

If you have selected:

- **[Display All Records At Once]**  
All of the records will be read.
- **[Display Specified Record]**  
Specifies from which record to start reading and also, how many records to read.

When [Display Method] is set to [Display Specified Record]

Start Record: Input which record to start reading from.

No. of Records: Input how many records to read, in all.

#### 4. Update Method

Select whether to redisplay the currently displayed data contents when the file data has been updated.

- **[Update File Contents Each Time]**  
Performs the redisplaying if the file data is updated.
- **[Do Not Update]**  
The displaying will remain as it is, even if the file data has been updated.

#### 5.1.1.4 Event

1 → Event No. 0

2 → Character Change No. 1 Character Change

☒ Next Time Open On Double-click

OK Cancel Delete

##### 1. Event No.

Input the event number.

##### 2. Character Change No.

Set the number for Character Change.

When you do not know the corresponding number, by left-clicking the button, the registering screen will be displayed. With this, select the desired number and finish.


Character Change



#### ◆ NOTE

When operating the event, this will always be operated by level operation (reverses the current status).  
It is not possible to operate by pulse, or to perform the on operation and the off operation.

### 5.1.1.5 Connection



#### 1. Node No.

Select the node number

#### 2. Character Change No.

Set the number for Character Change.

When you do not know the corresponding number, by left-clicking the

Character Change

button, the registering screen will be displayed.  
With this, select the desired number and finish.




#### ◆ NOTE

[Connection Settings] operates the setting status of [Connection No.], or displays.

It doesn't have the function for displaying the connection status with PLC.

### 5.1.1.6 Connection Settings



The image shows a 'Cell Settings' dialog box with a blue title bar and standard window controls. It is divided into two main sections: 'Target' and 'Attribute'. The 'Target' section has radio buttons for 'Relay', 'Register', 'File Data', 'Event', 'Connection', and 'Connection Settings' (which is selected). The 'Attribute' section has radio buttons for 'Read Only' (selected), 'Read/Write', and 'Write Only'. Below these sections, there is a 'Node No.' field with a dropdown menu showing '1', indicated by a red arrow labeled '1'. Further down, there is a 'Character Change No.' field with a dropdown menu showing '1', indicated by a red arrow labeled '2', and a 'Character Change' button. At the bottom, there is a checkbox labeled 'Next Time Open On Double-click' which is checked, and three buttons: 'OK', 'Cancel', and 'Delete'.


#### 1. Node No.

Select the node number from: 0 to 254

#### 2. Character Change No.

Set the number for Character Change.

When you do not know the corresponding number, by left-clicking the button, the registering dialog box for this will be displayed. Select the number which you will use and finish.







## 5.2 Delete Cell Settings

---

It is possible to delete the cell information with one of the methods below:.

- Go to the menu bar ->[PCWAY]->[Delete Cell Settings (X)]
- Click 


Delete the cell information of the specified area.

If the data is that of what has been just deleted, the contents of one cell in all, will be memorized. By selecting [Paste Cell Settings] , it is possible to move to the specified cursor position.


## 5.3 Copy Cell Settings

---

It is possible to copy the cell information by one of the methods below:

- Go to the menu bar->[PCWAY]->[Copy Cell Settings(C)]
- Click 


Write the specified cell on to the clipboard.

Then by selecting the [Paste Cell Settings] , this will be copied to the specified position, and the device number and the event number will be incremented one by one.

However, it is not possible to copy a several number of cells of which the cell range has been specified, or to perform the copying when the [Target] at [Cell Settings] dialog box is specified as [File Data] or [Connection].




## 5.4 Paste Cell Settings

It is possible to paste the cell by one of the methods introduced to you below:

- Go to the menu bar->[PCWAY]->[Paste Cell Settings(V)]
- Click 

Paste the cell deletion or the copied cell information to the specified cell.


Specify the pasting direction by:

go to the menu bar->[PCWAY]->[Set Cell Order(A)]   

- **When performing the pasting of the cell one by one, prioritizing the downwards direction:**


Select one cell as the original for the copying.


Go to [PCWAY]->[Copy Cell Settings(C)] .



It is possible to select a several number of cells which the cell will be copied to.

Go to [PCWAY]->[Set Cell Order (A)]->[Downwards (D)] .


Specify the cell or cells which you will copy to and go to [PCWAY]->[Paste Cell Settings (V)] . With this, the copying will be performed one by one, prioritizing the downwards direction. (When the pasting has reached the very bottom, then the pasting will proceed by going to the very top of the next-right-column.)



- If you prioritize pasting in the rightwards direction:


Choose a primary cell, selected as the original for copying.

Go to [PCWAY] -> [Copy Cell Settings(C)] .



It is possible to select more than one cell for copying.

Go to [PCWAY]->[Set Cell Order(A)]->[To the Right (R)] .

Specify the cell range where you will perform the copying to, and go to [PCWAY]->[Paste Cell Settings (V)] .

With this, the copying will be performed in the rightwards direction.

(when the pasting in the rightwards direction has reached the very end, then the pasting will next proceed to the cell on the very left side of the following row.)






## ◆ NOTE

If the copy source cell is contained within the same cell range as the copy destination cell, the device number is not incremented by 1 the first time that copying is carried out, but is incremented by 1 each time that copying is carried out after that.

If the copy source cell is not contained within the same cell range as the copy destination cell, the device number is incremented by 1 starting from the first time that copying is carried out.

## 5.5 Set Cell Order


Perform the cell operation settings by one of the methods below:

- Go to the menu bar->[PCWAY]->[Set Cell Order (A)]
- Click   


When you will paste the cell information of the original cell for copying to a certain cell range, first set the moving direction which will be prioritized.

When operating the relay and when changing the register value while the monitor is in RUN, then set the continuous moving direction of the cursor.

The following are the 3 options which determines the direction to move.




### No Action

- Go to the menu bar->[PCWAY]->[Set Cell Order(A)]-> [No Action(N)]
- Click 


Only the specified cell position will be pasted, when performing the pasting of the cell information.

### Downwards

- Go to the menu bar->[PCWAY]->[Set Cell Order(A)]->[Downwards (D)]
- Click 

The data will be pasted at the cells one by one in the downwards direction, when performing the pasting of the cell information.


### To The Right

- Go to the menu bar->[PCWAY]->[Set Cell Order (A)]->[To The Right (R)]
- Click 


The data will be pasted at the cells one by one in the right wards direction, when performing the pasting of the cell information.

## 5.6 Run PCWAY

---


- Go to the menu bar->[PCWAY]->[Run PCWAY (D)]
- Click 
- Shortcut key: Ctrl + Shift + B

Start the communication with the PLC.

When  PCWAY is displayed at the Windows® Task bar, then PCWAY can be executed and the monitor is ready for use.

## 5.7 Exit PCWAY


---


- Go to the menu bar->[PCWAY]->[Exit PCWAY(F)]
- Click 
- Shortcut key: Ctrl + Shift + C

Finish the communication with the PLC.  
The operating of the monitor is no longer possible.

## 5.8 Read PCWAY Settings Again

---

- Go to the menu bar->[PCWAY]->[Read PCWAY Settings Again(G)]
- Click 

The registered data will be re-read if you have changed the contents (such as Cell Settings or Character Change) during the running of the monitor .


However, if you change the registered contents at [Operation Preferences] or [Connection No.], this will not be reflected.

Please re-start PCWAY.



## 5.9 Start Monitor

---

- Go to the menu bar->[PCWAY]->[Start Monitor (R)]
- Click 
- Shortcut key: Ctrl + Shift + D

Start the monitor for the cell after the information setting has been done with it.


The contents of what has been displayed onto the cell will change depending on what is changed with the relay or register value of the PLC.

When you have made changes with each registered data, perform [Read PCWAY Settings Again] before the starting of the monitor.

However, it is necessary to re-start PCWAY when you have made any changes to [Operation Preferences] or to the [Connection No.].

## 5.10 Stop Monitor

---

- Go to the menu bar->[PCWAY]->[Stop Monitor (S)]
- Click 
- Shortcut key: Ctrl + Shift + E


Stop the running of the monitor.

The contents of what will be displayed onto the cell will not change even when the relay or the register value of the PLC is changed.

## 5.11 Download Data

---

It is possible to download the cell data with one of the methods below:

- Go to the menu bar [PCWAY]->[Download Data (E)]
- Click 
- Shortcut key: Ctrl + Shift + G

For the cells of which the [Attribute] has been specified as [Write Only] in [Cell Settings], it is possible to specify the cell area and download the contents of the cell to the PLC.



### ◆ NOTE

---

**When the [Target] at [Cell Settings] is [Relay]**

**Input 1 into the cell when wanting to put to on**

**Input 0 into the cell when wanting to put to off**

- In the case when you have chosen "Level Operation" with the operation method of "Cell Settings":
  - By inputting 1 into the cell, the corresponding relay will turn to on, after the downloading.
  - By inputting 0 into the cell, the corresponding relay will turn to off, after the downloading.
- In the case when you have chosen "Pulse Operation" with the operation method of "Cell Settings":
  - By inputting 1 into the cell, after the corresponding relay turns to on after the downloading, the relay will turn to off, after a certain period of time. (default: 500ms).
  - By inputting 0 into the cell, there will be no operating taking place.
- In the case when you have chosen "ON Operation" with the operation method of "Cell Settings":
  - Not relating by the value of the cell, the corresponding relay turns to ON after the downloading.
- In the case when you have chosen "OFF Operation" with the operation method of "Cell Settings":
  - Not relating by the value of the cell, the corresponding relay turns to OFF after the downloading.

## 5.12 Update All Sheet Data


---

With PCWAY, only the currently active sheet can update continuously, the displaying of the PLC information and the file data which has been entered in to the Microsoft® Excel cell.

There will be no changes with information if the sheet is currently not active.

Therefore, when wishing to save the contents of a current book for instance, it will be necessary to update all sheet information (including that of sheets which are not active).

It is possible to update all of the sheet information by one of the methods below:

- Go to the menu bar->[PCWAY]->[Update All Sheet Data (W)]
- Click 
- Shortcut key: Ctrl + Shift + H



---

### ◆ NOTE


---

- [Update All Sheet Data] is unselectable unless PCWAY has been already started.
- With "Update All Sheet Data", the displaying of the PLC relay and register information or the event information, the file data and the communication conditions etc. will be updated.  
Tasks such as changing the color of the chart which is displayed on to the Microsoft® Excel sheet using the macro, is not possible to perform here.

## 5.13 Update Active Sheet Data

---

Use [Update Active Sheet Data] when you would like to update only the sheet information of a currently active sheet for: **5.12 Update All Sheet Data**.

- Go to the menu bar->[PCWAY]->[Update Active Sheet Data (U)]
- Click 
- Shortcut key: Ctrl + Shift + I



### ◆ NOTE

---

- Without PCWAY being started, it is not possible to use "Update Active Sheet Data".
- With "Update Active Sheet Data", the displaying of the PLC relay and the register information, event information, file data and the connection conditions will be updated.  
Tasks such as changing the color of the chart of which has been displayed on to the Microsoft® Excel sheet by the macro, will not be performed here.

## 5.14 Save Excel file

---

By using [Save Excel File], the settings of [Cell Settings] at the corresponding book will be erased, and the following will be added to the file name and will be saved:


**File name before the saving** and YYYYMMDDHHMMSS (year, month, day, hour, minute, second)

The file name will be saved in the folder of which the corresponding book has been opened.

When the corresponding book is that of what has been just newly created, this will be saved in to the PCWAY work folder.

After the book has been saved into the PCWAY work folder, the performances will be done automatically, until the former book is redisplayed.

It is possible to start the Microsoft® Excel file saving by one of the methods below:

- Go to the menu bar->[PCWAY]->[Save Excel File (Q)]
- Click 
- Shortcut key: Ctrl + E

## 5.15 Save HTML File


---

By using "Save HTML File", the settings of "Cell Settings" at the corresponding book will be erased. And, it is preserved with the HTML form.

The file name will be saved in the folder of which the corresponding book has been opened. When the corresponding book is that of what has been just newly created, this will be saved in to the PCWAY work folder.

After the book has been saved into the PCWAY work folder, the performances will be done automatically, until the former book is redisplayed.

It is possible to start the HTML file saving by one of the method below:

- Go to the menu bar ->[PCWAY]->[Save HTML File (L)]
- Click 
- Shortcut key: Ctrl + M



### ◆ NOTE

---

---

**When files and folders have already been saved as HTML, they are overwritten to save.**

**This function works on "Microsoft® Excel 2000" or higher.**

## 5.16 Compile

---

Start the compiling by the following:

- Go to the menu bar->[PCWAY]->[Compile (M)]

Before beginning to explain about Compile, we would like to first give some explanations of PCWAY.

With PCWAY, if you update an active sheet during the running of the monitor, PCWAY will perform the followings:

1. Writes the cell information of an active sheet into the work file.
2. Communicates with the PLC, based on the contents of the work file.

When you have set many cell information at the sheet, the upper no.1 performance will be rather slow.

(This depends of course, on the personal computer type which is in use. Note that with 8000 cells, it will take 40seconds)

When you would like to perform the procedures in high-speed performance omitting the upper no.1 performance, then it is necessary to open the [Operation Preferences] dialog box and go to the [operation Preferences] menu bar->[Settings (C)]->[Option (O)].

At this dialog box, place a check mark at the [Sheet information not updated mode(necessary to compile)] check box.

You must be aware that when this mode is specified, the upper no.1 performance will be omitted and therefore it is compulsory to perform compile.

When you execute compile, all of the sheet information of an active book will be written-in, into the work file.

After this, PCWAY will communicate with the PLC, based on the work file.



### ◆ NOTE

---

---

**When you would like to add, delete, or change the cell information when "Sheet information not updated mode" is specified, you must execute compile. The changed contents will not be reflected with "Read Setting Again".**



## 5.17 Protecting the Sheet

---

If a sheet has been protected by using [Protect Sheet (P)] under [Protection (P)] on the [Tool (T)] in Microsoft® Excel menu, the input password should be noted on the **Protect =** line in the Microsoft® Excel section of the Pctway.ini file found in the folder when PCWAY is installed. For example, if the sheet was protected using a password called MEW, open the Pctway.ini file using the Memopad, and enter the following:

Input...

```
[Excel]
DBLCLICK=1
ToggleSwitch=0
Menubar=1
Toolbar=1
SheetChange=0
Protect=MEW
```

and save this.



### ◆ NOTE

---

If you do not input the above matters, the displayings will not be updated, although the PLC relay or the register contents might be changed.





## **Chapter 6**

---

### **Registering - Module**

## 6.1 Setting Operation Preferences

- Go to the Menu bar [PCWAY] -> [Various Types of Records(O)] -> [Operation Preferences(D)]
- Click 




### Item Explanations


#### 1. PC Type

- **PC Type**  
By clicking within [PC Type], IBM PC/AT will be displayed.

#### 2. Network

- **NET Type**


Click the  button and at the dialog box of which you have entered, select at the [Network Type] drop-down list from the followings:




- MEWNET-H
- C-NET(RS232C)
- No Connection
- MODEM
- Ethernet(Local)
- Ethernet(Remote)
- USB

## Network Type:


If you have not selected [MODEM], [Ethernet(Remote)] at this drop-down list box, then you must specify the PLC node number of which you will connect to.


By clicking the  button, the [Connection No.] dialog box is displayed. With this, place a check mark for the node number which you wish to connect.



## Network Type:

If you have selected [MODEM] at this drop-down list box, and also placed a check mark at

Receive check box, then click the  button and do the settings at this dialog box.



### - Event

This event is the event which enables the line connection.

After you have had the line connected from the PLC, the connection, otherwise disconnection is determined by the on/off status of this event.

### - Waiting time

This is the waiting time for the event to turn on after the PLC lines are connected.

If this event turns on during the specified time, then the line is connected until the event is turned off, however, if the event does not turn on during this specified time, then the line is terminated.


### - Event automatically turn on

If you placed a check mark here, after the line is connected from the PLC, the upper event which was specified, turns on. The line connection condition is continued until this event turns off.

### 3. Error Reception

Place a check mark at the Receive check box when you wish to have PCWAY receive the phone call which is called up from remote PLCs.

Click the **Communication Settings (A)** button and do the communication settings for the modem, for the receiving of an error.




### 4. Number of regions

- **When the number of regions is under 65...**  
the setting of the [Modem Support] dialog box becomes valid. For detailed information **6.14 Modem Support**.

- **When the number of regions is over 65...**

then place a check mark at the **Over 65 Regions (Q)** button, and do the settings at this dialog box.



### - Informing Relay

Do the settings here, if there is a relay which you wish to turn on after the line is connected (by PCWAY). This will turn off after the line is severed. The registerable node number is limited to node number 1.

### - Informing Event

Do the settings here, if there is an event which you wish to turn on after the line is connected (by PCWAY). This event will not turn off after the line is severed.

### - Read Register

Set the data register for the uploading of the PLC information, when the line is connected by the PLC. The node number is limited to node number 1. Up to 3 words of the specified data register starting from the registered order, is uploaded.


1st word: 1 is fixed.

2nd word: the event which you would like to turn on after the line is connected, is set by hexadecimal.

3rd word: 0 is the error reception  
1 is the ongoing connection

Note that when there is a check mark placed at both the [Receive] check box at the [Network] and [Error Reception] check boxes, then only from the 3rd word can PCWAY determine whether the line connected by the PLC is by ongoing connection or the error reception condition.

Now, set the PLC node number.

By clicking the  button, the [Connection No.] dialog box is displayed.

With this, place a check mark for the node number which you wish to connect.

Note:

When a check mark is placed at the "Use link unit No. when connection by RS232C" (for this, go to the file menu R "Settings (C)" R "Option (O)", the registered "Informing Relay" and "Read Register" accesses PLC of node No. 0.

## 5. Pulse Width Setting

### • Relay ON Time

When specifying pulse operation at the relay settings, then you must set your desired pulse width time.

The default setting is 500msec.

## 6. Refresh Interval Settings

### • Display Data

Specify the interval at which PLC data is to be displayed, based on the cell information settings.

### • Relay Link

When this is MEWNET-H, this is the interval which reads the PLC link area.

When the network type is [C-NET] or [Modem], this is the interval which reads the settings of C-NET.

Also, this interval checks the Event Startup.

### • File Processing

This is the interval which checks whether the trigger device which was registered (at [File Processing],) is on.

### • Macro Startup

This is the processing interval at which the system checks to see whether or not the trigger device registered when the auto macro booted is on.

## 7. Event Hold Field

- **Hold Range Start No.**

When the hold type has been set, then the conditions of the events up until this setting, will remain in the same condition. When set as non-hold, then the events will be turned to off. Specify the number which you will start from, for the event hold range from 0 to 100.

0: Hold Entire Range

1 to 99: the numbers only after the number which you have set will be specified as the hold type.

100: Entire Range Not Held

The specifications are the same as those for the hold processing of the PLC internal relays.

## 8. Timeout Settings

- **Retry**

Select on when you wish to confirm the reconnection of the PLC which the line is terminated, due to the turning off of the power.

- **Interval**

If you have selected on at [Retry], then next set the time for the confirming of the reconnection of the PLC which has been line-terminated, due to the power turning off. Set with each 1 minute, within the 1 to 10 minute range.

## 9. Work Folder

Specify the folder where the PCWAY registered files or the operation preference is stored. Concerning the work folder, this does not have to be changed later on, since this will be set at the installing stage.

### Menu bar

- **File**


- **Save**  
Updates the setting contents.
- **Save and Exit**  
The settings contents are updated and the file is exited.
- **Exit**  
Finishes without updating the settings contents.

- **Settings**

- **Option**  
The dialog box for PCWAY options can be changed by entering [Option (O)].



## Item Explanations on Menu bar -> [Settings (C)] -> [Option (O)]



### 1. Double-click for cell settings

When you would not like to have [Cell Settings] displayed whenever you double-click the Microsoft® Excel cell, remove the check mark at this check box.

### 2. ON/OFF Confirmation Message box

When an Microsoft® Excel cell is double-clicked to turn PLC relays and events on and off while monitoring is in progress, a window titled [Change ON/OFF State of Relay] is displayed. Erase this check mark if you prefer that the window not be displayed.

### 3. PCWAY menu bar visible

When you would not like to have the PCWAY menu bar displayed over the Microsoft® Excel screen, then remove the check mark at this check box.

### 4. PCWAY tool bar visible


When you would not like to have the PCWAY tool bar displayed over the Microsoft® Excel screen, then remove the check at this check box.

### 5. Sheet data no-refresh mode (necessary to compile)

Place a check mark when you would like to operate based on the compiled sheet information. For detailed information **5.16 Compile**.

### 6. Use Link unit No. when connection by RS232C

For instance, when you have the CPU of the PLC linked to MEWNET-H and connected to PCWAY by RS232C, and would desire to access other PLCs situated at the same level, place a check mark at this check box.



From the time when you have performed this setting, all accesses to the PLC will be made at the Link Unit No. instead of the CPU Node No.



---

**◆ NOTE**

---

- When you did not place a check mark, the upper PLC 2 will be recognized as Node No. 1.
- By placing a check mark, 2 of the upper figure (which is directly connected to the computer) only, will be recognized as Node No.0, regardless of the Link Unit No.
- If a check mark is placed here and the PLC is accessed, this mode will remain effective until the power supply to the PLC is turned off. The mode can be canceled in the PCWAY settings, but it remains stored in the CPU of the PLC.  
In this case, the power supply to the PLC 2 has to be turned off in order to cancel the mode.
- When FP10SH, only the tool port can be adopted for use.

**7. Communication with the setting unit no. of the Ethernet connection.**

Checked: The PLC is accessed using the Link Unit No.

Unchecked: The PLC is accessed using the home Node No. (EE).

**8. Monitoring command of MEWTOCOL is not used.**

Uncheck this check box when connecting to equipment that does not support the monitoring command.

## MEWNET-H

In order to use this network, it is necessary to use the MEWNET-H link board and the MEWNET-H link software.(both independently sold)

Register Board No.:      Use at 0.

Segment Address No.:      Refer to the chart below

Segment Address No.	SW1	SW2	SW3	SW4	SW5	Memory area for the user
0	ON	ON	ON	ON	ON	C0000 - C0FFF
1	OFF	ON	ON	ON	ON	C1000 - C1FFF
2	ON	OFF	ON	ON	ON	C2000 - C2FFF
3	OFF	OFF	ON	ON	ON	C3000 - C3FFF
4	ON	ON	OFF	ON	ON	C4000 - C4FFF
5	OFF	ON	OFF	ON	ON	C5000 - C5FFF
6	ON	OFF	OFF	ON	ON	C6000 - C6FFF
7	OFF	OFF	OFF	ON	ON	C7000 - C7FFF
8	ON	ON	ON	OFF	ON	C8000 - C8FFF
9	OFF	ON	ON	OFF	ON	C9000 - C9FFF
10	ON	OFF	ON	OFF	ON	CA000 - CAFFF
11	OFF	OFF	ON	OFF	ON	CB000 - CBFFF
12	ON	ON	OFF	OFF	ON	CC000 - CCFFF
13	OFF	ON	OFF	OFF	ON	CD000 - CDFFF
14	ON	OFF	OFF	OFF	ON	CE000 - CEFFF
15	OFF	OFF	OFF	OFF	ON	CF000 - CFFFF
16	ON	ON	ON	ON	OFF	D0000 - D0FFF
17	OFF	ON	ON	ON	OFF	D1000 - D1FFF
18	ON	OFF	ON	ON	OFF	D2000 - D2FFF
19	OFF	OFF	ON	ON	OFF	D3000 - D3FFF
20	ON	ON	OFF	ON	OFF	D4000 - D4FFF
21	OFF	ON	OFF	ON	OFF	D5000 - D5FFF
22	ON	OFF	OFF	ON	OFF	D6000 - D6FFF
23	OFF	OFF	OFF	ON	OFF	D7000 - D7FFF
24	ON	ON	ON	OFF	OFF	D8000 - D8FFF
25	OFF	ON	ON	OFF	OFF	D9000 - D9FFF
26	ON	OFF	ON	OFF	OFF	DA000 - DAFFF
27	OFF	OFF	ON	OFF	OFF	DB000 - DBFFF
28	ON	ON	OFF	OFF	OFF	DC000 - DCFFF
29	OFF	ON	OFF	OFF	OFF	DD000 - DDFFF
30	ON	OFF	OFF	OFF	OFF	DE000 - DEFFF
31	OFF	OFF	OFF	OFF	OFF	DF000 - DFFFF

IRQ No. :                      Refer to the chart below

IRQ No.	SW1	SW2	SW3	SW4	Input
3	ON	ON	ON	OFF	IRQ3
4	OFF	ON	ON	OFF	IRQ4
5	ON	OFF	ON	OFF	IRQ5
6	OFF	OFF	ON	OFF	IRQ6
7	ON	ON	OFF	OFF	IRQ7
9	OFF	ON	OFF	OFF	IRQ9
10	ON	ON	ON	ON	IRQ10
11	OFF	ON	ON	ON	IRQ11
12	ON	OFF	ON	ON	IRQ12
14	OFF	OFF	ON	ON	IRQ14
15	ON	ON	OFF	ON	IRQ15

Timeout:

At the [Operation preferences]-[Communication Settings] dialog box, specify MEWNET-H.  
Then, at Timeout, then specify the expiration time of the communication time with your PLC.  
Set with each 1 second, within the 1 to 60 second range.

## C-NET(RS232C)


Select this when the personal computer and a number of PLCs are connected by 1:N through the C-NET adapter; when the personal computer and the PLC is connected by 1:1 through RS232C, then it is necessary to select this.

Set to the same settings as the communication conditions of the PLC.

For example, when using FP1, match to the value which has been set at System Register No.412 to 415.

1. Set to System Register 412: K1.  
(Purpose of usage)

2. System Register 413 :  
(Transmission format)



3. System Register 414 :  
(Baud Rate)
  - K0=19200bps
  - K1=9600bps
  - K2= 4800bps
  - K3= 2400bps
  - K4= 1200bps
  - K5= 600bps
  - K6= 300bps

4. System Register 415 :  
(Unit No.)
  - K1-K32

Timeout:

At the [Communication Setting]-[Operation Preferences] dialog box, specify [C-NET RS232C]. Then, at [Timeout], then specify the expiration time of the communication time with your PLC. Set with each 1 second, within the 1 to 60 second range.

Parameter for automatic setting:

If you have placed a check mark at the [Baud Rate], [Data Length] and [Parity] check boxes... If the upper items of which you have specified and the PLC communication settings are not the same, this is automatically adjusted at the point of the starting of PCWAY.

## No Connection

The PLC will not be connected.

## Modem

Set to the same communication conditions with the PLCs which are located in distant regions.

Timeout:

At the [Communication Setting]-[Operation Preferences] dialog box, specify [MODEM].

Then, at [Timeout], then specify the expiration time of the communication time with your PLC.

Set with each 1 second, within the 1 to 60 second range.

Dial Mode:

Specify the type of the line to be connected. Please, you can input [Dial Mode] of your modem, when you selected [Others].

Public Line Timeout:

Set the waiting time for the line to be connected.

Modem Init. Command (AT-command)

ATV1E0S0 = 1S2 = 43

V1: Indicates result codes in English words.(changeable)

E0: Does not perform character echo (unchangeable)

S0=1: Means that call signal is issued once. (unchangeable)

S2=43: Character "+" used for the escape code. (changeable)


The upper AT command is due for standard modems, however, if the modem which you are using does not match with this, then you must verify whether the modem type is suitable for the upper AT command.

See your modem manual.

## Ethernet (Local)


### Not using each link path of MEWNET


#### 1. Example of Hardware





- Max. 64 PLCs can be connected.  
Even if using one ET-AN unit, maximum 63 PLCs can connect.  
That means a personal computer itself must have a node number.  
[See detailed explanation in "ET-LAN Unit Introduction Manual".]
- Connect PLC to HUB via our ET-LAN unit or the Ethernet/RS232C converter unit on the market.  
When connecting Ethernet/RS232C converter unit, plug the RS232C cable into TOOL port or COM port of PLCs.  
But connection to FP3 require the Ver.4.4 later converter (corresponding to C-NET)

## 2. Setting method

Go to the Menu bar [PCWAY]->[Various Type of Records (O)]->[Operation Preference (D)], or click the icon  in the Tools bar. Following Operation Preference dialog box is displayed.

For select Ethernet (Local) from network types, Click  under Network. Enter required items with selecting [Ethernet (Local)] from Network Type.



For connected PLCs, click  button to activate [Connection No.], and then check reserved node number. See detail explanation on **6.16 Connection No.**.



### [Computer]

Acquire IP address automatically:

This function is the same as IP address setting of Windows® Network.  
If PCWAY executes, this function gets IP address from Windows®.  
Then, PCWAY executes various processing by using the IP address.

IP Address:

Source IP Address obtained automatically is displayed.  
If displayed, modify the property of TCP/IP at the Network Setting in the Control Panels of each OS.  
Different setting methods depend on each OS.  
See detail explanation in the manual or the online help of each OS.

First Port No.:

Enter the port number within 0 and the range from 1025 to 32767(Default value: 0)  
If you set 0 in the First Port No., you can't use "Full passive" mode of ET-LAN Unit.  
Enter the first port number of following source station number.  
If other programs run, specify the first port number without repetition.

Here entered the first port number (for source) is the source port number opposite to the destination node number 1.  
Excluding the destination node number 1, the source port number is made by the first port number added to the destination node number decreasing by 1.

First port number + (Destination node number -1) = Source port number.

Example) In the case of First Port No.1025,

- if Destination node number is one, adopted source port number is 1025  
by  $1025 + (1 - 1) = 1025$
- else if Destination node number is 10, adopted source port number is 1034  
by  $1025 + (10 - 1) = 1034$
- else if Destination node number is 15, adopted source port number is 1039  
by  $1025 + (15 - 1) = 1039$

Destination station No.	Dest...	Dest.

Computer Port No.

Add... Change... Delete

\* When setting the Open method of the ET-LAN unit (for AFP3790: FP3 for PLC to Full passive mode, above source port number must be entered in Ladder Diagram.  
See "Open, Close Procedure" in "FP3 ET-LAN Unit Introduction Manual" for Open Method of the ET-LAN Unit.

Station No.:

Enter the node number within the range from 1 to 64 (Default value: 64), Ensure that the node number is not the same with the destination node number.  
When not using the ET-LAN unit, the node number is invalid.


Use LinkUnit Station Number:

Do not check it.

Destination station No.	Destination IP address	Destination port


Add... Change... Delete

### Method of enter and modify each setting for the destination:

Click  button to enter new contents for the destination.


Click  button to modify contents which has already been entered.

Enter required contents in each field in following dialog box that is displayed.



The dialog box titled "Entry Destination Parameters" contains the following fields and controls:

- ☒ Use ET-LAN unit
- Station No.:  ( 1-64 )
- IP address:  .  .
- Port No.:  ( 1-32767 )
- Computer port No.:
- Buttons: OK, Cancel

When node numbers are displayed with the button , the smallest node number that is not reserved is automatically displayed.

Entered contents are sorted in ascending order of the node number.

#### Use ET-LAN Unit:

Check it to connect a personal computer (or HUB) via our ET-LAN unit.

#### Station No.:

Enter the node number within the range from 1 to 64.

Ensure, however, that the node number is not the same with the source station number.

#### Note:

In [Connection No.] dialog box, enter node numbers that has been specified here.

Not entered, this node number becomes invalid.

#### IP Address:

Enter the IP address for destinations which you would like to access.

#### Port No.:

Enter the port number within the range from 1 to 32767 (Default value: 1025)

Enter the port number of following source station number.

If other programs run, specify the first port number without repetition.

#### Communication Time-out (Sec):

After establishing the connection, enter the timeout interval every communication within the range from 1 to 950 sec (Default value: 10)

Until establishing the connection, this setting is invalid.


#### Connection Time-out (Sec):

Until establishing the connection, enter the timeout interval every communication within the range from 1 to 180 sec (Default value: 60)

## Using each link path of MEWNET


### 1. Example of Hardware

#### Using Tool port of CPU



- Check number 0, 2, and 3 to enter the node number above.
- Connect No.1 PLC with the node No.0.

#### Using ET-LAN Unit




- No.1 Link Unit must set the CPU right side.
- When you directly connect PCWAY and our ET-LAN Unit, Ethernet cable uses the crossing cable.



### ◆ NOTE

Only top hierarchy level in each link unit of MEWNET can be connected while the second hierarchy level later can not connected.


## 2. Setting method


Go to the Menu bar [PCWAY]->[Various Type of Records (O)]->[Operation Preference (D)], or click the icon button  in the Tools bar.

Following Operation Preference dialog box is displayed.

For select Ethernet (Local) from network types, Click  under Network.

Enter required items with selecting [Ethernet (Local)] from Network Type.



For connected PLCs, click  button to activate [Connection No.], and then check reserved node number.

See detail explanation on **6.16 Connection No.**

First, check "Use Link Unit Station Number".

Communication Setting - Operation Preferences

Network type: Ethernet (Local) [OK]

Computer

☐ Acquire IP address automatically

IP address: 128 . 1 . 1 . 10

First port No.: 1025 ( 0, 1025 - 32704 )

Station No.: 64 ( 1 - 64 )

☒ Use LinkUnit Station Number

Destination

☐ Use ET-LAN unit

IP address: 128 . 1 . 1 . 2

Port No.: 1025 ( 1 - 32767 )

Station No.: 1 ( 1 - 64 )

Communication Time-out (Sec): 5

Connection Time-out (Sec): 60

[Cancel] [Initialize] [Help]

#### [Computer]

Acquire IP address automatically:

This function is the same as IP address setting of Windows® Network.  
If PCWAY executes, this function gets IP address from Windows®.  
Then, PCWAY executes various processing by using the IP address.

IP Address:

Source IP Address obtained automatically is displayed.  
If it does not displayed, modify the property of TCP/IP at Network setting in Control Panels of each OS.  
Different setting methods depend on each OS.  
See detail explanation in a manual or the online helps of each OS.

First Port No.:

Enter the port number within 0 and the range from 1025 to 32767 (Default Value: 0)  
Enter the first port number of following the source station number.  
If other programs run, specify the first port number without repetition.

Station No.:

Enter the node number within the range from 1 to 64 (Default value: 64), Ensure that the node number is not the same with the destination node number.  
When not using the ET-LAN unit, the node number is invalid.

Use Link Unit Station Number:

Check it.

The screenshot shows a configuration window with a title bar. Inside, there is a checked checkbox labeled 'Use LinkUnit Station Number'. Below this is a section titled 'Destination' which contains another checked checkbox labeled 'Use ET-LAN unit'. Under the 'Destination' section, there are three input fields: 'IP address:' with the value '128. 1. 1. 2', 'Port No.:' with the value '1025' and a range '( 1 - 32767 )' in parentheses, and 'Station No.:' with the value '1' and a range '( 1 - 64 )' in parentheses. At the bottom of the window, there are two more settings: 'Communication Time-out (Sec):' with a dropdown menu showing '5', and 'Connection Time-out (Sec):' with a dropdown menu showing '60'.

Use ET-LAN unit:

If you use our ET-LAN Unit, you must check in the Check Box.

IP Address:

Enter the IP address for destinations which you would like to access.

Port No.:

Enter the port number within the range from 1 to 32767(Default value: 1025)

\* Enter the same IP address and port number as the Ethernet/RS232C converter unit marked with A in figure 1 or the ET-LAN Unit marked with B in figure 2 in previous page.

Station No.:

If you use our ET-LAN Unit, Enter the Unit No. of ET-LAN Unit.

Communication Time-out (Sec):

After establishing the connection, enter the timeout interval every communication within the range from 1 to 950 sec (Default value: 10)

Until establishing the connection, this setting is invalid

Connection Time-out (Sec):

Enter the timeout interval until establishing the connection within the range from 1 to 180 sec (Default value: 60)

## Ethernet (Remote)


- **Overview**

Use the Ethernet remote connection, only if necessary for communication with PLC.  
Communication starts when either

- Turning on the event (V) or
  - Informing error from PLC,“ to PCWAY.
- (Usually PLCs are not connected to PCWAY.)

Use Remote connection when user structured system is mainly as follows:

Example 1)



- **Form of connection**

The Remote connection has three types.

- **Send Line**

Connecting to PLCs from PCWAY.

There are two types of Regular Connection method (a method of connection which must be manually cut) and One Scan Connection method (a method of connection which be automatically cut off after scanning over PLCs).

The automatical link connection can be also applied to all destinations entered with the One Scan Connection method.

- **Reception**

Connecting to PCWAY from PLC.

PCWAY can be connecting until specifying wait time.


- **Error Reception**


Connecting to PCWAY from PLC.


As soon as receiving an error, PCWAY automatically cuts off line after only required processing.



- **Setting method**

Go to the Menu bar [PCWAY]->[Various Types of Records (O)]->[Operation Preferences (D)], or click the Icon button  in the Tools bar.  
Following Operation Preference dialog box is displayed.

For select Ethernet (Remote) from network types, click  button under Network to open the Network dialog box.  
Select [Ethernet (Remote)] from Net Type.



Each item for connection must be entered in Ethernet Remote dialog box.


With clicking , Ethernet Remote dialog box is displayed.


For the network type other than [Ethernet (Remote)], the PLC node number you wish to connect should be entered using the Connection No dialog box.

For [Ethernet (Remote)], however, Connect No. is not necessary to be set.

For the PLC node number you wish to connect in [Ethernet (Remote)], enter the number in the [Destination St No.] and place a check mark in the [Execute: Yes] check box.


## • Detail

PCWAY displays the following dialog when you click  button.  
The connection doesn't receive an influence of other connection by this setting.  
If time is required to the connection of other PLC, other connection does not influence.




- Communication Module is started every PLC unit.
  - If you check to the checkbox, PCWAY executes the Ethernet communication module every PLC unit.  
But the Ethernet Communication in File Processing and Auto Macro Startup, C-NET Settings is out of it.
  - If you don't check to the checkbox, PCWAY does the same action with below Ver. 2.4.  
If the communication error occurs with one unit, all communication does influence.  
And the sheet data doesn't renew until fixing the error.
- ☐ module starts.  
You can set 16-64 modules.  
If PCWAY communicates with 17 unit or more in setting 16 modules, PCWAY executes the communication with 2 unit or more into 1 module.

## 6.2 Character Change

- Go to the menu bar [PCWAY] -> [Various Types of Records (O)]-> [Character Change(C)]
- Click 

This is the registering which will change the character and the color bound to be displayed, by turning on/off the bit device.



### Item Explanations

#### 1. No.

Possible to register from: 1 to 100

(When you have registered from the [Character Change] at [Cell Settings]...)

Select the number by clicking at [No.],

- **Select No.** Displays the currently selected number.  
Clears the number which has been selected at [Clear Selection]

#### 2. When On

Input the character which you will have displayed when the bit device is ON. (within: 16 characters)

#### 3. When OFF

Input the character which you will have displayed when the bit device is OFF. (within: 16 characters)

#### 4. Character Input

Input the character of [When ON] ; [When OFF]

#### 5. Edit Display Color

Specify the character color and the background color of [When ON/When OFF].

#### 6. Background Color

Specify whether to have or not, the background color.

## Menu bar

- **File**

- **Save**  
Saves

- **Export**  
Saves the registered data on the text file (CSV format).

(When you have registered from the [Character Change] at [Cell Settings]...)


- **Select current No. and finish**  
Displays the currently selected No. at No. of [Cell Settings] and finishes.
- **Exit**  
Finish registering procedures.

## Registering procedures

### (1) When registering anew


1. Input the character in the [When ON] column for the number you would like to register. By left-clicking [When ON] column of the number which you will input, this will be high-lighted in white, allowing you to do the inputting.

At this point, the character and the background color will not yet be displayed.  
Input in the same manner, at [When OFF] column by the same procedures.



- To add a color to the character and background after the character has been input, either select [Edit display color], and then select the [character color] and [background color], or directly select the character color or background color, which automatically switches to [Edit display color].

Click with the left button of the mouse for the [when ON] or [when OFF] column where character has been input to change the selected display color.



- When all of the inputting has been completed, go to the menu bar->[File]->[Save]->[Exit] or to [Select current No. and finish].


With this, the necessary registering is completed.

However, [Select current No. and finish] can only be selected when you have previously registered at [Character Change] dialog box (enter this with the command button) at the [Cell Settings] dialog box.


The number which has been registered at [Select No.] will be displayed at [Character Change No.] at [Cell Settings].

When you would like to cancel the currently selected number, click the [Clear Selection] command button.

The selection will be canceled, however, it is not possible to perform [Select current No. and finish].



When registered at Character Change.




## (2) When editing

1. Edit the character and the display color of [When ON] and [When OFF].

- When you would like to edit the character only...

Select the [Character Input] radio button and left-click the [When ON] list box. By doing so, this edit box will be highlighted and the character will turn to black, allowing you to input the character.

After you have changed the character by this process, this display color of the character will remain as it is, and the character only will be changed.




- When you would like to edit the display color only...


Select [Edit display color] first, and then select the [character color] or the [background color], or specify directly at [Select character color] or [Select background color].

When the display color is specified, left-click at [When ON] or [When OFF] of the number which you would like to change.


The color will change to the currently selected color.



- When all of the inputting has been completed, by going to the menu bar -> [File] -> [Save] -> [Exit] or to [Select Current No. and finish], the necessary registering will be completed. However, it is only possible to select [Select current No. and finish] when you have registered at the [Character Change] dialog box.  
(enter this with the command button at the [Cell Settings] dialog box.)  
The number which is selected at [Select No.] will be displayed at [Character Change No.] at the [Cell Settings] dialog box.  
When you would like to cancel the selected number, click the [Clear Selection] command button. With this, the selection will be canceled, however the operations of [Select current No. and finish] will not be possible.




When registered at Character Change.






## 6.3 Message

- Go to the menu bar [PCWAY] -> [Various Types of Records (O)] -> [Message (G)]
- Click 

This is about the registering procedures for changing the character and color which will be displayed using the PLC word device value. It is possible to register 0 to 4096 messages for one topic.



### Item Explanations

#### 1. No.

Possible to register from: 1 to 100

If a comment has been inputted, the comment will be displayed after the " : ".

#### 2. Comment

Input comment (up to 16 characters)

#### 3. Data value

Possible to register the value up to: 0 to 4096

#### 4. Message

Possible to register the characters (up to 32 characters)

#### 5. Character input

Input the character of [Message]

#### 6. Edit display color

Specify the character color and the background color of what has been inputted at [Message].

#### 7. Background color

Specify whether or not to have the background color.

## Menu bar

### • File

- **Save**  
Saves
- **Export**  
Saves the registered data on the text file (CSV format).

(When you have registered previously at [Message] at the [Cell Settings] dialog box...)

- **Select current No. and finish**  
Displays the currently selected number at [No.] of [Cell Settings] and finishes.
- **Exit**  
Finish the registering procedures

### • Edit (E)


- **Add Message No. (A)**  
One number is added.  
(Note that only up to 100 numbers can be added.)
- **Delete Message No. (D)**  
One number is deleted.  
(Note that the number which you have registered last, is deleted.)

## Registering procedures

### (1) When registering anew

1. This is about the adding method of the number of [No.].  
To add a number, go to the menu bar to [Edit (E)] -> [Add Message No. (A)].  
By selecting [Add Message No. (A)] the number is added as a No. option.  
However, you must note that the overall registerable number is up to 100 numbers.


In order to delete a number which you have registered, go to the menu bar to [Edit (E)] -> [Delete Message No. (D)]. By selecting this option, the last registered number is deleted.



Next, input a comment, if desired.

After a comment has been input, to display the comment immediately after the colon ":", simply select another comment and then go back to the original one. The input comment is displayed in the [No.] comment column (after the colon).


Comments can also be displayed by selecting [File] on the menu bar and saving the data.




2. Input the character at [Message].

By left clicking within [Message], where you would like to input the [Data value], the area will be highlighted, and the character will be imputable.


At this point, the character color and the background color will not yet be displayed.




- To add a color to the text and background after the text has been input, either select the display color editing function, and then select the text color and background color, or directly select the text color or background color, which automatically switches to the editing function. Click with the left button of the mouse for the [Message] column where text has been input to change the selected display color.



- When all of the inputting has been completed, finish the registering procedures by going to the menu bar->[File]->[Save]->[Edit] or to [Select current No. and finish]. However, [Select current No. and finish] is selectable only when you have registered from the [Message] dialog box of the [Cell Settings] dialog box (enter this with the command button). The currently displayed number will be also displayed at [Message No.] at the [Cell Settings] dialog box.




When registered at Message.




## (2) When editing

1. Select the number which you would like to edit at [No.]  
Left-click within [No.] and select.  
Next, when you would like to change the comment, change this directly at [Comment].  
When you would like to have the comment displayed right after the [No.], then do this by the following procedure:  
Select a temporary different number, and then return to the former area.  
The changed comment will be displayed after [No.] (after the " : ").  
Otherwise, perform the saving procedures of; menu bar->[File].




## 2. Perform the editing of [Message]

- When you would like to edit the character only...  
By selecting [Character input] and clicking the message edit box under [Message], the edit box will be highlighted in white, and the character will turn to black.  
With this, the characters can be inputted. Now, re-input the character.  
After you have changed the character by this process, this display color of the character will remain as it is, and the character only will be changed.



- When editing the display color only...  
Select [Edit display color] first, and then select the character color and the background color, or specify directly the color at [Select character color] or [Select background color].  
When the display color has been specified, click at [Message] of the data value which you would like to change.  
The color will change to the currently selected color.




3. When all of the inputting has been completed, go to the menu bar -> [File] -> [Save] -> [Exit] or to [Select current No. and finish] and the registering procedures will be completed.


However, [Select current No. and finish] is selectable only when you have registered at [Message] at the [Cell Settings] dialog box.

The number which is displayed at [No.] will be also displayed at [Message No.] at the [Cell Settings] dialog box.

## 6.4 Operation Formula

- Go to the menu bar->[PCWAY]->[Various Types of Records(O)]-> [Operation Formula (E)]
- Click 

When you will perform an operation when you will display/operate the value of the PLC word device; when you will store this in to the file data, then it is necessary to register the operation formula.



1 → No. 1 :

2 → Comment

3 → Read

4 → Write

### Item Explanations

#### 1. No.

Possible to register from: 1 to 100

#### 2. Comment

Input comment (up to 80 characters)

#### 3. Read

Input the formula when you will perform an operation to the value (X), which will be read. (Up to 80 characters)

#### 4. Write

Input the formula when you will perform an operation and then write the cell value (X). (Up to 80 characters)



## Specification of formula

### • Inputting the device

- when PLC1 word node number + device name
- when PLC2 words W + node number + device name

(when the node is "?" )

This will be equivalent to the node number of the information settings of which each of the No.'s has been specified.

(device name)

DT: data register	WR: Internal Relay
LD: link data register	WX: External Input
FL: file register	WY: External Output
SV: timer / counter setting value	WL: Link Relay
EV: timer / counter elapsed value	
dt: special data register	
m: data link area	



### ◆ EXAMPLE

**13DT10** (node number:13; no. 10 of the data register)

**W15DT30** (node number:15; uses 2 words of no.30;31 of the data register)

**?LD20** (node number: the node is of the node of Cell Settings-no.20 of the link register)

### • Formula (usable)

+	[addition]	-	[subtraction]
*	[multiplication]	/	[division]
%	[modulus]	( )	[parenthesis; negative value]
INT	( ) [integer]	< > <= >=	[comparative]
=	!	[equal; not equal]	
	[OR]	&&	[AND]
^	[exponential]	SQR	[square root]
ln	[natural log]	log	[logarithm]

### • Formula of which operations cannot be performed

- Operations of which the answer is 0
  - 0 division
  - "0" to the "0" power
  - logarithm; natural logarithm of 0
  - "0" to the minus power
  - square root of a negative value
  - exponential of a negative value
- Operations of which the answer becomes:1
  - Zero power of the positive value
- **Please do not use the following operation formula:**
  - Formula of which the answer is over "10<sup>39</sup>".

## Menu bar

### • File

- **Save**  
Saves

- **Export**  
Saves the registered data on the text file (CSV format).

(When you have registered from the [Operation Formula] dialog box of [Cell Settings]...)

- **Select current No. and finish**  
Displays the currently selected number at the [Operation Formula] entering from the corresponding command button [Cell Settings], and finishes.

- **Exit**  
Finish the registering procedures


### • Compile

- **Run**  
Execute compile

- **Error List**  
If there is an error, both the error contents and the area of the error will be displayed.

## Registering procedures

1. Select the number which you will register.  
Either left-click at [No.] area or select by using the scroll bar on the very right side where [Comment];[Read];[Write] is.



2. When the number has been specified, then input the comment.

- Next, if any kind of operation processing is to be carried out on the value that has been read, and the result displayed, enter the operation formula in the [Read] column.  
The value to be read (the PLC word device value) should be indicated by "X" (upper-case, half-width) when the operation formula is input.



### ◆ EXAMPLE

X/100

X\*100

Operation Formula	
File(F) Compile(C) Help(H)	
No. 1 :Sample	
Comment Sample	
Read	X/100
Write	

- Next, if any kind of operation processing is to be carried out on the value being written, and the data is to be processed, enter the operation formula in the [Write] column.  
The value to be written (the value input to the cell) should be indicated by "X" (upper-case, half-width) when the operation formula is input.



### ◆ EXAMPLE

X\*100


X/100

Operation Formula	
File(F) Compile(C) Help(H)	
No. 1 :Sample	
Comment Sample	
Read	X/100
Write	X*100


- When all of the inputting has been completed, perform compile.  
Go to the menu bar of [Operation Formula] -> [Compile(C)] -> [Run (X)]

Operation Formula	
File(F) Compile(C) Help(H)	
Run(X) Error List(D)	
No. 1 :Sample	
Comment Sample	
Read	X/100
Write	X*100


When [Successfully completed] is displayed, go to [File] -> [Save] -> [Exit] or to [Select current No. and finish] and the registering procedures will be completed. However, [Select current No. and finish] is selectable only when you have registered from [Operation Formula] of [Cell Settings]. The currently displayed number will be next displayed at [Operation Formula No.] of [Cell Settings].




When you have registered from Operation Formula.




The possible error reasons will be listed, here.



## 6.5 File Master

- Go to the menu bar -> [Various Types of records (O)] -> [File Master (F)]
- Click 



The screenshot shows the 'File Master' dialog box with the following fields and callouts:

- 1: File No. (dropdown menu)
- 2: Comment (text field)
- 3: File name (text field)
- 4: Record quantity (text field)
- 5: Write mode (dropdown menu)
- 6: Display renewal event (checkbox)
- 7: Continue processing (checkbox)
- 8: Set the event to turn on when full (checkbox)
- 9: Type (dropdown menu)
- 10: Method (dropdown menu)
- 11: Digits after decimal point (dropdown menu)
- 12: Table with 3 columns: No., Type, Comment
- 13: Table with 3 columns: No., Type, Comment

### Item Explanations

#### 1. File No.

Possible to register from: 1 to 600.

When there is a comment, the comment will be displayed after the " : ".

It adds ' \* ' before No. after saving the data of File Master.

#### 2. Comment

Input the comment (up to 16 characters).

#### 3. File name

Input the name of the file which you will create.

If only the file name has been inputted (TEST, etc.), then the file will be created under [Work Folder] which has been specified at [Operation Preferences], on the occasion when the file processing has been executed.

When the file name is input using the full path (C:\My Documents\TEST, etc.), the file is created under the specified folder.

#### 4. Record quantity

Set the quantity of records which you will use, ranging from 1 to 30,000 records.

#### 5. Write mode

Select how to write in data in to the file.

##### - Insert at beginning of file

Writes in the newest data at the most beginning of the file.

##### - Insert at end of file

Writes in the newest data at the very end of the file.

#### 6. Display renewal event

Set the event number in order to re-display the File Data.

## 7. Treatment when file data is full

Select whether to continue processing or not, when the file data numbers have reached the specified number.

- **Continue Processing**  
Continues the processing in order to constantly have the newest record numbers saved.
- **Stop processing**  
Finishes the file processing

## 8. Set the event to turn ON when full

Set if there is an event which you would like to turn ON when the data is full.

## 9. Type

Select the field type which you will specify for each of the fields.

Date : month / day / year(4digits) (MM/DD/YYYY)  
Time : hour / minute / second (HH:MM:SS)  
Integer : Long(-2147483648 - 214748483648 range)  
Real num.: Double(1.7E-308 - 1.7E+308 range)  
Char. : storable up to 32 characters.

## 10.Method

If the field type selected with the [Type] is to be assigned to the field in the lower column on the [File Master] dialog box, select the method by which that is to be done.

- **Only specified**  
Set only the field type of the specified No. at [Type] in [File Master] dialog box.
- **All after specified field**  
Set all of the field types after the specified No.'s at [Type] at the very bottom of the [File Master] dialog box.

## 11.Digits after decimal point (real number)

Set the digit numbers below the decimal point.

The settings here will influence all of the fields of real number type.

When the field type is the real number or the character, then it is applicable.

## 12.Type

By left-clicking this, the field type which has been selected at [specify field type] will be specified.

## 13.Comment

Input the comment

## Menu bar

- **File (F)**

- **Save**  
Saves

- **Export**

Saves the registered data on the text file (CSV format).

(When you have registered at [File No. Reference] command button at the [Cell Settings] dialog box, or at [Specify corresponding file] at the [File Processing] dialog box...

- **Select current No. and finish (L)**

Displays the currently selected number at [File No.] of the [Cell Settings] dialog box or at the [File No.] at the [File Processing] dialog box, and then finishes.

- **Save and Exit (E)**

Saves and then finishes the registering procedures.

- **Exit (X)**

Finishes the registering procedures.

- **Edit (E)**

- **Paste saved contents (P)**

Pastes the memorized contents at [registered contents copy].  
The file name will also be pasted, therefore change the file name.

- **Copy saved contents (C)**

Memorizes the contents of the currently displayed file number.

- **Delete saved contents (D)**

Deletes the contents of the currently displayed file number.

- **Delete File (K)**

Instead of deleting the registered contents, since the file processing will be executed with PCWAY, the file data which has been made will be deleted.  
(This file of the [File Master] registering only, will be deleted.)



## Registering procedures

### • File base setting

(Basic settings for the file which you will create)

The screenshot shows a 'File base setting' dialog box. It contains the following fields and controls:

- 1** points to the 'File No.' dropdown menu.
- 2** points to the 'File name' text input field.
- 3** points to the 'Record quantity' text input field, which contains the value '1'.
- 4** points to the 'Write mode' dropdown menu, which is set to 'Insert at beginning of file'.
- 5** points to the 'Display renewal event' dropdown menu, which is set to 'No'.

#### 1. File No.

Select the file number which you would like to register.

Left-click within [File No.] and select. Then input the comment.

After you have inputted the comment, when you would like to have the comment displayed right after the " : " of the [File No.], you must select temporarily, a different number and then return to the former area. With this, the comment which you have inputted will be displayed after the " : " of the [File No.].

#### 2. File Name

Input the file name

#### 3. Record Quantity

Input the quantity of records within 1 to 30,000 record ranges.

#### 4. Write Mode

Select the mode to write. By left-clicking within [Write Mode], [Insert at beginning of file];[Insert at end of file] will be displayed.

Select which write mode you will use.

#### 5. Display renewal event.

Set the display renewal event.

This will be used dominantly with [Update Method] when set as [Do not update] at [Cell Settings: File data].

When set as [Do not update], then the event will not be displayed despite the file data being renewed.

Therefore, when [Display renewal event] which has been set is turned ON, the file data will be redisplayed.

When there is no need to redisplay the file data, then there is no need to do the settings.

The screenshot shows a 'Cell Settings' dialog box. It contains the following fields and controls:

- Target:** Radio buttons for Relay, Register, File Data (selected), Event, Connection, and Connection Settings.
- Attribute:** Radio buttons for Read Only (selected), Read/Write, and Write Only.
- File No.:** A dropdown menu set to '1'.
- File No. Reference:** A button.
- Generation:** A dropdown menu set to 'Generation 1'.
- Display Method:** A dropdown menu set to 'Display All Records At Once'.
- Update Method:** A dropdown menu set to 'Do Not Update', which is circled in red.
- Next Time Open On Double-click:** A checked checkbox.
- Buttons:** OK, Cancel, and Delete.

- **Treatment when file data is full**

(The processing for when the data has surpassed the specified number for the record)

1. Left-click within [Continue processing] and select either the [Continue processing] or the [Stop processing] option.
2. Set the event which you will turn ON when the file data is full.  
When you would like to use another processing with this when the records of the file data has reached the specified record number, set the event number which will be the trigger device for the other processings.  
Set the event and turn this to ON.



## ◆ NOTE

When the upper [Continue processing] has been selected, concerning the event which you would like to turn ON whenever the file data has become full after the occasion when it has once been full, this will turn to ON.

- **Specify field type**

(The settings for each of the fields)

1. Select the field type at [Type]. Left click within [Type] and select.  
Next, select the method of specification for this.  
Left-click within [method] and select either [Only specified] or [All after specified] option.
2. [Digit after decimal point]  
Select the digit after the decimal point.  
This selection will be applicable when the real number type;  
character has been selected at [Type].

3. When the (1) and (2) settings has been completed, do the settings for each of the numbers. Left-click the field type (under [Type]) for the type which has been registered already at (1) and (2).

Specify field type

Type  Method  Digits after decimal point

No.	Type	Comment
1	Date	
2	None	
3	None	
4	None	
5	None	

However, if [None] has been set before for the field type, this field type cannot be selected for the current field type which you would like to set. Change the former field type settings to something else.

The field number is from: 1 to 256

Change the field number using the scrawl bar located at the very right side.


Input a simple comment for the processing which you have set.




#### ◆ NOTE

After you have performed the file processing, the field type can be added, however for the field type which has been already specified, this cannot be altered.

## 6.6 File Processing

- Go to the menu bar->[PCWAY]->[Various Types of Records(O)]-> [File Processing (O)]
- Click 



The screenshot shows the 'File Processing' dialog box with the following fields and controls:

- 1** Execution No. (dropdown menu)
- 2** Comment (text field)
- 3** Execute (checkbox)
- 4** File No. (dropdown menu) and Reference (button)
- Filename (text field)
- Record quantity (text field) and Write mode (text field)
- 5** Select contents of process (dropdown menu)
- 6** File execution startup timing and action afterward (text area)
- 7** Trigger device (dropdown menu) and M:Relay link (checkbox)
- 8** Informing relay (checkbox) and Execute After The execution, Node (dropdown menu)
- 9** Informing event (checkbox) and Execute After the execution, event (dropdown menu)
- 10** Message during execution (text field)
- 11** Table with columns: No, Type, Subject, Access method, M:Message No, F:Formula No, Node, Code, Address, Word, Fixed char.

### Item Explanations

#### 1. Execution No.

Possible to register from: 1 to 2000

If it's checking mark at the Yes check box, it adds ' \* ' before No. after saving the data of File Processing.

#### 2. Comment

Input the comment

#### 3. Execute

Place a check mark at the [Yes] check box, when you would like to execute.

#### 4. File No.

Select the file number which has been created at the [File Master] dialog box. With the [Reference] command button, the [File Master] dialog box will be displayed. By going to [File] -> [Select current No. and finish], it is possible to select from here also.

## 5. Contents of execution

Left-click within [Contents of execution], and select out of what will be displayed.

---

- **PLC->Collect data to this file.**

Writes in the data read from the PLC to the specified file.

By executing this processing, at the first execution, the first generation (initial) file (~.1) will be made and data will be gathered to this.

After the second execution, the gathered data only will be executed.

- **1st generation file (\*.1)-> moved to 2nd generation file (\*.2).**

Transfers 1st generation file (newly created) to the 2nd generation file.

(The first generation file will be deleted.)

- **1st generation file (\*.1)->copied to 2nd generation file (\*.2).**

Copies the 1st generation file (newly created) to the 2nd generation file.

(The first generation file will remain as it is.)

- **1st generation file (\*.1)->moved to 3rd generation file (\*.3).**

Transfers the first generation file (newly created) to the 3rd generation file.

(The first generation file will be deleted.)

- **1st generation file (\*.1)-> copied to 3rd generation file (\*.3).**

Copies the first generation file (newly created) to the 3rd generation file.

(The first generation file will remain as it is.)

- **2nd generation file (\*.2)-> moved to 3rd generation file (\*.3).**

Transfers the 2nd generation file (newly created) to the 3rd generation file.

(The 2nd generation file will be deleted.)

- **2nd generation file (\*.2)-> copied to 3rd generation file (\*.3).**

Copies the 2nd generation file (newly created) to the 3rd generation file.

(The 2nd generation file will remain as it is.)

- **Initialize 1st generation.**

Initializes the 1st generation file after the file has been created.

(The 1st generation file will be deleted.)

- **Initialize 2nd generation.**

Initializes the 2nd generation file after the file has been created.

(The 2nd generation file will be deleted.)

- **Initialize 3rd generation.**

Initializes the 3rd generation file after the file has been created.

(The 3rd generation file will be deleted.)

---

## 6. Trigger device

Set the device for starting the file processing.

M: Relay link    0 to 255F (max.)

V: Event        0 to 99F

## 7. C-NET No.

[Reference] command button.

This will only be displayed when the [Network Type] of [Operation Preferences] is specified as [Modem].

Choose the number of C-NET No. at [C-NET Settings](enter with the command button).

## 8. Informing relay

Set this when there is a PLC relay which you would like to turn ON after the file processing.

You must set this when the [Trigger device] is specified as [Relay link].

## 9. Informing event

Set this when there is an event which you would like to turn ON after the file processing.

## 10. Message during execution

Input the message to display during the file processing.

## 11.Settings of each of the fields

According to the setting for the field type, each of the setting items will differ.  
There is no need to do the settings for date and time since the date and time of the computer will be downloaded as data.

- **Subject:**  
Select which data to process
- **Access method:**  
Set the processing when writing in PLC data.
- **No.(M: Message No. F: Formula No.):**  
Set the register number which has been chosen for the access method.
- **Specify partners:**  
Set when the PLC has been chosen for the processing at [Subject].
- **Fixed char:**  
Input when fixed char has been chosen for the processing at [Subject]. (Within 16 characters)

<b>Date</b>	10 digits	99/99/99
<b>Time</b>	8 digits	99:99:99
<b>Character</b>	Subject:	
	-None	Nothing is written, in to the file
	-PLC	Writes, in to the file, the device data which has been selected at [Specify partners].
	-Fixed Char.	Writes into the file, the character which has been inputted at [Fixed Char.]
	Access method	
	-Numeric	Processes the data which has been read as the numeric value. Input the formula No. (the No. of the next item below)
	-Message	Processes the data which has been read at the specified Message. Input the message No. (the No. of the next item below)
	-Char.	Processes the data which has been read as the character code.
	No.:	
	-Formula No.	If any kind of operation is to be carried out on the PLC data being read and the data is then to be written to a file, select the No. in [Operation Formula].
	-Message No.	To write the contents of [Message] in the PLC data being read to a file, select the No. in [Message].
	Specify partner:	Set the PLC device number which you will read.
	Fixed Char.:	
	Input when [Subject: Fixed Char.] (Input within 8 characters) When you would like to input more than 8 characters, set [Subject: Fixed Char.] again.	

<b>Integer</b>	Subject:	
	-None	Nothing will be written, in to the file.
	-PLC	Writes, in to the file, the device data which has been specified at [Specify Partner].
	Access method	
	-Numeric value	Processes the data which has been read, as the numerical value (integer). Input the formula No. at No. (No. at the item below).
<b>Real Number</b>	No.:	
	-Formula No.	If any kind of operation is to be carried out on the PLC data being read and the data is then to be written to a file, select the No. in [Operation Formula].
	Specify partner: Set the PLC device number which you will read.	
	Subject	
	-None	Nothing will be written, in to the file.
	-PLC	Writes the device data which has been registered at [Specify partner], in to the file.
	Access method	
	-Integer	Processes the data which has been read, as the numerical value (integer).
	-Real number	Processes the data which has been read as the numerical value (real number). Input the formula No. (at the No. of the next item).
	No.	
	-Formula No.	If any kind of operation is to be carried out on the PLC data being read and the data is then to be written to a file, select the No. in [Operation Formula].
	Specify partner: Set the PLC device number which you will read.	


## Menu bar

- **File(F)**


- **Save(S)**  
Saves
- **Export**  
Saves the registered data on the text file (CSV format).
- **Save and Exit(E)**  
Saves and exits registering procedures.
- **Exit (X)**  
Finishes registering procedures.

- **Edit (E)**

- **Paste saved contents(P)**  
Pastes the memorized contents of the Register Contents Copy.
- **Copy saved contents (C)**  
Memorizes the contents of the currently displayed number.
- **Delete saved contents(D)**  
Deletes the contents of the currently displayed number.
- **Field Copy(C)**  
It is possible to copy to another field, based on the settings of a certain field.  
It is also possible to specify the increased address.



## Registering



1. Choose the execution number which you would like to register.  
Left-click [Execution No.] and choose the number.  
It is not possible to choose several numbers of the [File No.] (located under [Specify corresponding file]) for the same [Execution No.].  
When the file of [Specify corresponding file] will be changed, make sure to register a different number for [Execution No.].  
Beware that the file number of [Execution No.] and [Specify corresponding file] is always of a 1:1 relationship.
2. Next, input a comment.  
After inputting a comment, when you would like to display this comment after the ":" right after the number, do as the following:  
Select different temporary number and then return to the former area.  
By doing so, the inputted comment will be displayed after the ":".  
Otherwise, do the saving procedures from [File] located in the menu bar.
3. When performing this file processing, place a check mark at the [Yes] check box.  
When there is no check mark, this file processing will not be executed, although the Trigger device turns to ON.



- **Specify corresponding file**

(Specification of the file created at [File Master])

1 →

Choose a file which has been set at [File Master].

Either left-click [File No.], or go to the [File Master] dialog box, entering this with the [Reference] command button and go to [File]->[Select current No. and finish].

By doing so, the file number will be specified and will return to the [File processing] dialog box.

- **Select contents of process**

(Select the processing method for the file.)

Select the processing method for the file which has been specified.

Left-click [Contents of execution] and choose how to do the processing.

- **File execution startup timing and actions afterward**

(Specifications for the file trigger.)

1 →

3 →

5 →

2 ←

1. Do the settings of when starting the file processing.

Left-click [Trigger device] and select.

Then input the relay link number or the event number .

2. It is possible to specify [C-NET No.] if the [Network Type] has been specified as [Modem] at the [Operation preferences] dialog box.

With the [Reference] command button, the [C-NET settings] dialogbox will be displayed.

By going to [File] of [C-Net Settings] dialog box->[Select current No. and finish], the corresponding number will be chosen and will return to the [File processing ]dialog box.

3. Next, after the file processing, if there is a relay or event which you would like to turn to ON, do the settings of [Informing Relay] and [Informing Event]. However, if you have chosen [M:Relay link] before at [Trigger device], make sure to set the informing relay.

4. If there is a message which you would like to display during the file processing, input this at [Message during execution].

When wishing to register (file execution startup timing and action afterward) only, set this at the [File Trigger] dialog box.

• Settings for each of the fields

No	Type	Subject	Access method	M:Message No F:Formula No	Specify partner				Fixed char.
					Node	Code	Address	Word	
1	None								
2	None								
3	None								
4	None								
5	None								


1 →



2

3 ←

1. The specified field type set at the file which has been selected at [Specify corresponding file] will be displayed.
2. There are necessary settings for each of the field types.  
For further information, refer to each of the corresponding field settings at: Item explanations.
3. Change the field number using the scroll bar on the very right.

## 6.7 File Trigger

- Go to the menu bar->[PCWAY]->[Various types of records(O)]-> [File Trigger(H)]
- Click 



## Item Explanations

### 1. Execute

Place a check mark when you will execute the selected number.

### 2. Trigger

Set the device for starting the file processing.

[M:Relay link] 0 to 255F

[V:Event] 0 to 99F

### 3. C-NET No.

This will be displayed when the [Network Type] of [Operation Preferences] is [Modem].  
Choose the number from [C-NET Settings].

### 4. Informing Relay

Set this if there is a PLC relay which you would like to turn ON after the file processing.  
However, you must make sure to set this when M(Relay link) has been specified at [Trigger].

### 5. Informing Event

Set this if there is an event which you would like to turn ON after the file processing.

### 6. Executing Message

Input the message to be displayed during the file processing.

## Menu bar

### • File(F)

- **Save(S)** Saves
- **Export** Saves the registered data on the text file (CSV format).
- **Save and Exit (E)** Saves and finishes the registering procedures
- **Exit (X)** Finishes the registering procedures


## Registering procedure

Set whether or not to perform the processing directly from the overview window (figure below). Click the box which is on the left side of [No.].

If there is a check mark the processing will be performed.


Concerning on how to do each of the settings, first choose the row for the number which you would like to register.

By left-clicking the [Details] command button, the details window of [File Trigger] will be displayed. Do the necessary settings.




### • Details window


1. Place a check mark at [Execute] when executing the registered matters.




- Do the settings when to start file processing.  
Left-click [Trigger] and select.  
Input the number of the relay link or the event.



- It is possible to specify [C-NET No.], when the [Network Type] is specified as [Modem] at [Operation Preferences].  
[C-NET Settings] will be displayed after clicking the [Browse] command button. With this, by going to [File] of [C-NET Settings] ->[Select current No. and finish], the number will be selected and will return to the [File Processing] dialog box.  
Concerning the registering details **6.11 C-NET Settings**.




- After performing the file processing, if there is a relay and event which you would like to turn ON, do the settings for each [Informing relay] and [Informing event].  
You must specify [Informing relay] when M(Relay link) has been selected at [Trigger].




- Input the message which you would like to display during the file processing at [Executing Message].

6. To exit this screen when all of the settings have been entered, click on the [Exit (E)] button. This closes the screen and returns to the list screen, which shows the updated settings.  
To continue entering settings, use the [PageUp] and [PageDown] buttons to change the number, and enter the settings.

## 6.8 Event Startup

- Go to the Menu bar [PCWAY]->[Various Types of Records(O)]->[Event Startup (V)]
- Click 

It is possible to turn the event to ON, by the changing of the status (ON->OFF;OFF->ON) of relay link area:M





## Item explanations

### 1. Execute

Place a check mark when you will execute the selected number

### 2. Trigger

Set the number of the relay link area which watches the changing of the status.

### 3. C-NET No.

This will be displayed only when the [Network Type] of [Operation preferences] is [Modem].

Set the C-NET No. which has already been set at [C-NET Settings].

After clicking the [Browse] command button, the [C-NET Settings] window will be displayed.

With this, by going to [File] -> [Select current No. and finish], it is also possible to choose from here.

### 4. Start Condition

Select when to turn the informing event to ON;

when the relay link (which is set at [Trigger]) goes from OFF->ON, or ON->OFF.

### 5. Informing Event

Set the event which you would like to turn ON at the upper [Start condition].

### 6. Initialize by sheet name

Check this if the status of the previous start condition is not to be changed when the specified sheet is displayed (has become active), but you simply want to view the on or off status and turn on the event.

When the sheet registered under the [Sheet Name] noted below has become active, if the relay link specified for only the first trigger is on, it is considered to have gone from on to off, and the event is turned on.

Subsequently, changes in the status are viewed and the event is turned on in the normal manner.

This function is used in cases such as when a specific sheet is displayed and you want to boot a macro using the initial function.



## ◆ NOTE

**When you have placed a check mark at [Initialize by sheet name] the relay link which has been set at [Trigger] will be watched only when the sheet (registered at [Sheet Name] below) becomes active.**

**When a different sheet is active, then the informing event which was registered here will not be turned to ON.**

### 7. Sheet Name

Input the sheet name which you will check.

### 8. Comment

Imputable: up to 80 characters

## Menu bar


- **File (F)**

- **100 Records Added**  
Adds the registered records, 100 at a time.  
It is possible to add up to 1000 number of registers.
- **Save(S)**  
Saves
- **Export**  
Saves the registered data on the text file (CSV format).
- **Save and Exit(E)**  
Saves and finishes the registering procedures.
- **Exit(X)**  
Finishes the registering procedures.

## Registering procedures

Do the settings which will specify whether to execute from the overview window, or not.  
Click the box on the left of the [No.] This will be executed only when there has been placed a check mark, here.

In order to do each of the settings, first choose the row where you would like to do the settings.  
By left-clicking the [Details] command button, the details window of [Event Startup] will be displayed. With this, do the necessary settings.



- **Details window**

1. When performing the execution of the registered contents, place a check mark at [Execute].

The screenshot shows the 'Event Startup' dialog box. The 'Execute' checkbox is checked and circled. The 'No.' field is set to 1. The 'Trigger' field is set to M 0. The 'C-NET No.' field is set to 1, with a 'Browse(B)' button next to it. The 'Start Condition' is set to OFF -> ON. The 'Informing Event' field is set to v 0. There is an unchecked checkbox for 'Initialize by sheet name'. Below this are text boxes for 'Sheet Name' and 'Comments'. At the bottom are buttons for 'PageUp(U)', 'PageDown(D)', 'Exit(E)', and 'Help(H)'.


2. Set at [Trigger], the device which will start the execution.
3. [C-NET No.] will be displayed only when [Modem] has been specified at [Operation Preferences].  
Choose the number which has been set at [C-NET Settings], for C-NET No.  
After clicking the [Browse] command button, the [C-NET Settings] window will be displayed.  
With this, by going to [File] of [C-NET Settings] [Select current No. and finish], this C-NET No. will be chosen, and will return to the [Event Startup] window.  
Concerning the registering details **6.11 C-NET Settings**.

This is an identical screenshot of the 'Event Startup' dialog box as shown above. The 'Execute' checkbox is checked and circled. The 'No.' field is set to 1. The 'Trigger' field is set to M 0. The 'C-NET No.' field is set to 1, with a 'Browse(B)' button next to it. The 'Start Condition' is set to OFF -> ON. The 'Informing Event' field is set to v 0. There is an unchecked checkbox for 'Initialize by sheet name'. Below this are text boxes for 'Sheet Name' and 'Comments'. At the bottom are buttons for 'PageUp(U)', 'PageDown(D)', 'Exit(E)', and 'Help(H)'.


4. The [Start Condition] specifies whether or not the next specified informing event is to be turned on when the status of the [Trigger] specified at changes, and the manner in which it changes.
5. Set the event which you would like to turn ON according to the former [Start Condition] at [Informing Event].
6. Input a simple comment.

7. To exit this screen when all of the settings have been entered, click on the [Exit] button. This closes the screen and returns to the list screen, which shows the updated settings. To continue entering settings, use the [PageUp] and [PageDown] buttons to change the number, and enter the settings.

## 6.9 Weekly Timer

- Go to the Menu bar [PCWAY]->[Various Types of Records(O)]-> [WeeklyTimer (W)]
- Click 

Based on the clock of the computer, the bit device will turn ON by pulse or level at the specified time and day.



## Item Explanations

### 1. Execute

Select whether to execute the chosen number at [No.], or not.

### 2. Specified Time

Set the time when you would like to turn the device ON.  
Set by 24 hours.

### 3. Specified Day

Checks the date when the device will be turned to ON.

### 4. Node

Select the node number for the device.

### 5. Device

Set the device which you will turn ON.

### 6. Output Format

Select from [Pulse] or [Level].  
When you have chosen V (Event) at [Device], you can only specify [Level].

### 7. Comment

Imputable: up to 24 characters.

## Menu bar


### • File(F)

- **Save(S)** Saves
- **Export** Saves the registered data on the text file (CSV format).
- **Save and Exit(E)** Saves and finishes the registering procedures.
- **Exit(X)** Finishes the registering procedures.

## Registering procedures

Do the settings which will specify whether to execute from the overview window, or not.  
Click the box on the left side of [No.]. If there has been placed a check mark, then the execution will be performed.

In order to do each of the settings, first select the row of the No. where you would like to do the settings. By left-clicking the [Details] command button, the details window of [Weekly Timer] will be displayed. Do the necessary settings.



- **Details window**

1. Place a check mark at [Execute] when you will execute the registered contents.

Weekly Timer

No.

Execute ☒ Yes

Specified Time

Specified Day ☐ Mon ☐ Tue ☐ Wed ☐ Thu ☐ Fri ☐ Sat ☐ Sun

Node

Device

Output Format

Comments

PageUp (U) PageDown (D) Exit (E) Help (H)

2. Set the time and day when you will have the device turned ON at [Specified Time] and [Specified Day].
3. Set the device which you will turn ON.  
Select [Node]; [Device] and input the device number.

Weekly Timer

No.

Execute ☒ Yes

Specified Time

Specified Day ☐ Mon ☐ Tue ☐ Wed ☐ Thu ☐ Fri ☐ Sat ☐ Sun

Node

Device

Output Format

Comments

PageUp (U) PageDown (D) Exit (E) Help (H)

4. Select either [Pulse] or [Level] at [Output Format].  
However, when the device is V (event), only [Level] can be specified.

Weekly Timer

No.

Execute ☒ Yes

Specified Time

Specified Day ☐ Mon ☐ Tue ☐ Wed ☐ Thu ☐ Fri ☐ Sat ☐ Sun

Node

Device

Output Format


Comments

PageUp (U) PageDown (D) Exit (E) Help (H)


5. Input a simple comment for the registered execution.
6. To exit this screen when all of the settings have been entered, click on the [Exit] button. This closes the screen and returns to the list screen, which shows the updated settings. To continue entering settings, use the [PageUp] and [PageDown] buttons to change the number, and enter the settings.



## 6.10 Interval Timer

- Go to the menu bar [PCWAY]->[Various Types of Records(O)]->[Interval Timer (T)]
- Click 

Turn the bit device to ON at a certain interval with pulse or level.



## Item explanations

### 1. Execute

Select whether to execute the chosen No., or not.

### 2. Interval

Select the interval of the time when you will have the device turned to ON.

### 3. Node

Select the device node number.

### 4. Device

Select the device which you will to turn ON.

### 5. Output Format

Select either [Pulse] or [Level].

When you have chosen V(Event) at Device, you can only select [Level].

### 6. Comments

Imputable: up to 24 characters.

## Menu bar

### • File(F)

- **Save(S)** Saves
- **Export** Saves the registered data on the text file (CSV format).
- **Save and Exit(E)** Saves and finishes the registering procedures.
- **Exit(X)** Finishes the registering procedures.

## Registering procedures

Set whether to execute directly from the initial overview window, or not.


Click the box on the left side of [No.].

If there has been placed a check mark, the execution will be performed.

In order to do each of the settings, first choose the row of the No. where you would like to do the settings.


By left-clicking the [Details] button, the details window of [Interval Timer] will be displayed.

With this, do the necessary settings.




- **Details window**


1. When you will perform the execution of the registered contents, place a check mark at [Execute].




2. Set the interval of the time when you will turn ON the device at [Interval].  
By left-clicking the setting items will be displayed.  
Select the desired option.



3. Do the settings for the device which you will turn to ON.  
Select the Node and Device and input the device number.



4. Select either [Pulse] or [Level] at [Output Format].  
However, when the device is V(Event), you can only select [Level].




The screenshot shows a dialog box titled "Interval Timer". It contains the following fields and controls:


- No.:** A text box containing the number "1".
- Execute:** A checkbox labeled "Yes" which is checked.
- Interval:** A dropdown menu showing "1Sec".
- Node:** A dropdown menu showing "1".
- Device:** A dropdown menu showing "R" and a text box containing "0".
- Output Format:** A dropdown menu showing "Pulse".
- Comments:** A text box containing "Level".

At the bottom of the dialog box, there are four buttons: "PageUp (U)", "PageDown (D)", "Exit (E)", and "Help (H)".

5. Input a simple comment for the registered execution.
6. To exit this screen when all of the settings have been entered, click on the [Exit] button. This closes the screen and returns to the list screen, which shows the updated settings. To continue entering settings, use the [PageUp] and [PageDown] buttons to change the number, and enter the settings.

## 6.11 C-NET Settings

- Go to the menu bar [PCWAY]->[Various Types of Records(O)]->[C-NET Settings(N)]
- Click 



### Item Explanations

#### 1. C-NET No.

This will be displayed only when [Modem] has been specified as the [Network Type] at [Operation Preferences].  
Registerable numbers (with each modem number): 1 to 64

#### 2. Comment

Input comment.  
Inputable: up to 32 characters.

#### 3. Execute

Select [Yes] in order to make the execution possible.

#### 4. Comment

Input comment for No.

#### 5. Relay link range

Register the range which you will use as the relay link.  
Select [Node] within the 0 to 64 range.  
Select [WR](Internal relay) or [WL](Link relay), and input the first number.  
Select the word numbers of the range.

#### 6. Setting range

Displays the contents which has been set at the relay link range.

## 7. PCWAY Notation

The setting range is displayed using the PCWAY notation method.

If the [Network Type] has been set to [MODEM] in [Operation Preferences], setting item (6), [Setting range], to 1R0-1R15F sets 1M0-1M15F as the PCWAY notation method. The "1" in "1M0" is the number selected with the (1)[C-NET No.] parameter.

In other words, if C-NET No. 2 has been selected, 2M0-2M15F will be set as the setting range, and if C-NET No. 3 is selected, the range will be 3M0-3M15F.

If the [Network Type] has been set to anything other than [MODEM] in [Operation Preference], however, "1" will be set for the [C-NET No.] parameter.


### Menu bar

#### • File(F)

- **Save(S)** Saves
- **Export** Saves the registered data on the text file (CSV format).
- **Save and Exit(E)** Saves and finishes the registering procedures.
- **Exit(X)** Finishes the registering procedures.

### Registering procedures

1. When the [Network Type] of [Operation Preferences] is the [Modem], select the C-NET No. which you would like to register. (Otherwise, the displaying is not possible.)  
Left-click within [C-NET No.] and select.



Next, input a comment.

After inputting a comment, when you would like to reflect a comment after the{:}, choose another temporary C-NET No. and return.

Then, the inputted comment will be displayed.

- Next, select whether to execute or not, the contents which has been set at [execute].

C-NET Settings

File(F) Help(H)

C-NET No. 1 :

Comment

No.	Execute	Comment	Relay link range	Setting range
1	<input checked="" type="radio"/> No <input type="radio"/> Yes		Node 1 WR 0 From 1 Word	1R0 - 1RF
2	<input checked="" type="radio"/> No <input type="radio"/> Yes		Node 1 WR 0 From 1 Word	1R0 - 1RF
3	<input checked="" type="radio"/> No <input type="radio"/> Yes		Node 1 WR 0 From 1 Word	1R0 - 1RF
4	<input checked="" type="radio"/> No <input type="radio"/> Yes		Node 1 WR 0 From 1 Word	1R0 - 1RF
5	<input checked="" type="radio"/> No <input type="radio"/> Yes		Node 1 WR 0 From 1 Word	1R0 - 1RF

- Input comment

- Select the node number at [Node], then select whether you will use [WR] (internal relay) or [WL] (relay link area), and input the first number which you would like to register as the relay link area.

Select the number of words which you will register.

C-NET Settings

File(F) Help(H)

C-NET No. 1 :

Comment

No.	Execute	Comment	Relay link range	Setting range
1	<input type="radio"/> No <input checked="" type="radio"/> Yes		Node 1 WL 0 From 1 Word	1R0 - 1RF
2	<input checked="" type="radio"/> No <input type="radio"/> Yes		Node 1 WR 0 From 1 Word	1R0 - 1RF
3	<input checked="" type="radio"/> No <input type="radio"/> Yes		Node 1 WR 0 From 1 Word	1R0 - 1RF
4	<input checked="" type="radio"/> No <input type="radio"/> Yes		Node 1 WR 0 From 1 Word	1R0 - 1RF
5	<input checked="" type="radio"/> No <input type="radio"/> Yes		Node 1 WR 0 From 1 Word	1R0 - 1RF

5. When you would like to change the number at [No.], use the scroll bar on the very right.


No.	Execute	Comment	Setting range
1	<input checked="" type="radio"/> No	Relay link range	PCWAY notation
	<input checked="" type="radio"/> Yes	Node 1 WR 0 From 1 Word	1RO - 1RF
2	<input checked="" type="radio"/> No		1RO - 1RF
	<input checked="" type="radio"/> Yes	Node 1 WR 0 From 1 Word	
3	<input checked="" type="radio"/> No		1RO - 1RF
	<input checked="" type="radio"/> Yes	Node 1 WR 0 From 1 Word	
4	<input checked="" type="radio"/> No		1RO - 1RF
	<input checked="" type="radio"/> Yes	Node 1 WR 0 From 1 Word	
5	<input checked="" type="radio"/> No		1RO - 1RF
	<input checked="" type="radio"/> Yes	Node 1 WR 0 From 1 Word	


It is possible to register from: No.1 to 600.

6. When all of the settings have been completed, save the file and finish.



## 6.12 Auto Macro Startup

- Go to the menu bar [PCWAY]->[Various Types of Records (O)]->[Auto Macro Startup (A)]
- Click 



### Item Explanations

#### 1. Execute

Select whether to execute the selected No., or not.

#### 2. Trigger

Set the device which will start the execution.

#### 3. C-NET No.

Displays only when the [Network Type] of [Operation Preferences] is [Modem].

Set the number which has been set at C-NET Settings.

After clicking the Browse command button, the C-Net Settings window will be displayed.

With [File]->[Select current No. and finish], it is also possible to select from here.

#### 4. Node

Select the node of [Informing Relay].

#### 5. Informing Relay

Set this when there is a device which you would like to turn ON after the executing has been performed.

Make sure to set this when the M (Relay link) has been selected for the [Trigger].

## 6. Informing Event

Set this when there is an event which you would like to turn ON after the executing has been performed.

## 7. Macro Name

Input the macro name which you would like to start.

### Menu bar

#### • File(F)

- **100 Records added**  
Adds 100 records at a time. It is possible to add up to 1000 registrations.
- **Save(S)**  
Saves
- **Export**  
Saves the registered data on the text file (CSV format).
- **Save and Exit(E)**  
Saves and finishes the registering procedures.
- **Exit(X)**  
Finishes the registering procedures.

### Registering procedures


Do the settings whether to execute directly from the initial overview window, or not.

Click the box on the left side of [No.].

If there has been placed a check mark, then the execution will be performed from this window.

In order to do each of the settings, first select the row of [No.] which you would like to set at.

By left-clicking the [Details] command button, the details window of [Auto Macro Startup] will be displayed. With this, do the necessary settings.



## • Details Screen

1. Place a check mark at [Execute], if you would like to execute the contents which you have registered before.

The screenshot shows the 'Auto Macro Startup' dialog box. The 'Execute' checkbox is checked and circled. The 'No.' field is set to 1. The 'Trigger' dropdown is set to 'M'. The 'Informing Relay' checkbox is checked and labeled 'Notify'. The 'Informing Event' checkbox is checked and labeled 'Notify'. The 'Node' dropdown is set to 1, and the 'Relay' dropdown is set to 'R'. The 'Macro Name' field is empty. At the bottom, there are buttons for 'PageUp (U)', 'PageDown (D)', 'Exit (E)', and 'Help (H)'.

2. Set the device which starts the execution at [Trigger].

This screenshot shows the 'Auto Macro Startup' dialog box with the 'Trigger' dropdown menu open. The 'M' option is selected and circled. The other fields and buttons are the same as in the previous screenshot.

3. Select the number which has been set at [C-NET Settings] for [C-NET No.].  
The settings will be displayed only when the net [Network Type] of [Operation Preferences] is [Modem].  
When this is not MODEM, then the setting items will not be displayed.  
After clicking the Browse command button, the [C-NET Settings] window will be displayed.  
By going from [File] at [C-NET Settings] [Select current No. and finish], this number will be chosen and will return to the [Auto Macro Startup] window.  
Concerning the details for each of the registrations **6.11 C-NET Settings**.

This screenshot shows the 'Auto Macro Startup' dialog box with the 'C-NET No.' field added. It is set to 1, and there is a 'Browse (U)' button next to it. The 'Trigger' dropdown is still set to 'M'. The other fields and buttons are the same as in the previous screenshots.

4. After the executing has been completed, if there is a relay; event which you would like to turn to ON, do the settings for [Informing Relay] and [Informing Event]. However, if you have selected M(Relay link) at [Trigger], make sure to set [Informing Relay].

Auto Macro Startup

No. 1

Execute ☒ Yes

Trigger M 0

Informing Relay ☒ Notify Node 1 Relay R 0

Informing Event ☒ Notify V 0

Macro Name

PageUp (U) PageDown (D) Exit (E) Help (H)

5. Input the macro name which you will start when the trigger turns ON.

Auto Macro Startup

No. 1

Execute ☒ Yes

Trigger M 0

Informing Relay ☒ Notify Node 1 Relay R 0


Informing Event ☒ Notify V 0


Macro Name

PageUp (U) PageDown (D) Exit (E) Help (H)

6. To exit this screen when all of the settings have been entered, click on the [Exit] button. This closes the screen and returns to the list screen, which shows the updated settings. To continue entering settings, use the [PageUp] and [PageDown] buttons to change the number, and enter the settings.

## 6.13 Sound Startup

- Go to the menu bar [PCWAY]->[Various Types of Records(O)]->[Sound Startup(S)]
- Click 



## Item Explanations

### 1. Execute

Select whether to execute the selected number, or not.

### 2. Trigger

Set the device which will start the execution.

### 3. C-NET No.

This will be displayed only when the [Network Type] of [Operation Preferences] is [Modem]. Do the settings of [C-NET No.] which have been set at [C-NET Settings].

After clicking the [Browse] command button, the [C-NET Settings] window will be displayed. With this, by going to [File]->[Select current No. and finish], it is also possible to select from here.

Concerning on the registering details **6.11 C-NET Settings**.

### 4. Sound Name

Do the settings for the sound file.

It is possible to select the file using the [Browse(B)] command button. Play the sound file which has been set by the [Play(P)] command button.

### 5. Comments

Imputable up to: 40 characters.

## Menu bar

### • File (F)

#### - 100 Records Added

Adds 100 records at a time. It is possible to add up to 1000 of these registerings.

#### - Save (S)

Saves

#### - Export

Saves the registered data on the text file (CSV format).

#### - Save and Exit (E)

Saves and finishes the registering procedures.

#### - Exit(X)

Finishes the registering procedures

## Registering procedures

Set whether to execute from the initial overview window, or not.


Click the box on the left side of [No.].

If there has been placed a check mark here, then the executing will be performed.

In order to do each of the settings, first select the row of [No.] which you would like to set at.

By left-clicking the [Details] command button, the details window of [Sound Startup] will be displayed.

With this, do the necessary settings.



- **Details window**

1. Place check mark at [Execute] when you will execute the registered contents.

Sound Startup

No.

Execute ☒ Yes

Trigger

Sound Name

Comments

Play (P) Browse (B)

PageUp (U) PageDown (D) Exit (E) Help (H)

2. Set the device which will start the execution at [Trigger].

Sound Startup

No.

Execute ☒ Yes

Trigger

Sound Name

Comments

Play (P) Browse (B)

PageUp (U) PageDown (D) Exit (E) Help (H)

3. Select the number which has been set at [C-NET Settings] for [C-NET No.].  
This is selectable only when the [Network Type] is specified as [Modem] at [Operation Preferences].  
When this is not [Modem], then the setting items will not be displayed.  
After clicking the Browse command button, the [C-NET Settings] window will be displayed.  
If you go to [File] of [C-NET Settings]->[Select current No. and finish], the C-NET number will be selected and will return to the [Sound Startup] window.  
For further information on the registrations **6.11 C-NET Settings**.

Sound Startup

No.

Execute ☒ Yes

Trigger   C-NET No.  Browse (B)

Sound Name


Comments

Play (P) Browse (B)

PageUp (U) PageDown (D) Exit (E) Help (H)



4. Set the file which you would like to have sound generated from, when the trigger turns ON at [Sound Name].  
Either input directly the file name or select from the window of which you can enter with the [Browse(B)] button.  
With the [Play(P)] command button, it is possible to test the sound of the sound file.




## ◆ NOTE

**When the sound name is displayed at the details window, but not at the overview window, this means that the sound file does not exist.  
Register for a new sound file.**


5. Input a simple name for the execution contents which you have set at [Comments].
6. To exit this screen when all of the settings have been entered, click on the [Exit] button.  
This closes the screen and returns to the list screen, which shows the updated settings.  
To continue entering settings, use the [PageUp] and [PageDown] buttons to change the number, and enter the settings.

## 6.14 Modem Support

- Go to the menu bar->[PCWAY]->[Various Types of Records (O)]->[Modem Support (M)]
- Click 

This is the registering for watching PLC's located in distant regions, using the public phone line. It is possible to register up to 64 different regions (telephone number).

For further information on the operations, refer to: **4.8 Using the Public Phone Line.**



## Item Explanations

### • [Details]

The screenshot shows the 'Modem Support' dialog box with the following controls:

- No.:** A text box containing '1'.
- Execute:** A checkbox labeled 'Yes'.
- C-NET No.:** A text box containing '1' and a 'Browse (U)' button.
- Connection No.:** A text box containing '1' and a 'Browse (P)' button.
- Single Trigger:** A checked checkbox 'Yes' and a value '0'.
- Ongoing Trigger:** A checked checkbox 'Yes' and a value '0'.
- Limited Time:** A checked checkbox 'None' and a value '0' with a 'Min' label.
- Tel. No.:** An empty text box.
- Informing Relay:** A checked checkbox 'Notify' and a value '0'.
- Informing Event:** A checked checkbox 'Notify' and a value '0'.
- Comments:** An empty text box.
- Node:** A list box showing nodes 0 through 15.
- PageUp (U), PageDown (D), Exit (E), Help (H):** Buttons at the bottom.

#### 1. Execute

Select whether to execute the selected No., or not.

#### 2. C-NET No.

The C-NET No. will be displayed.

(This C-NET No. is the same as the Modem No.)

With the [Browse] button, the [C-NET Settings] dialog box will be displayed.

It is possible to check or set the setting contents.

Concerning on the registering details **6.11 C-NET Settings**.

#### 3. Connection No.

The number set at [Connection No.] will be displayed.

(This Connection No. is the same as the Modem No.)

With the [Browse] button, the [Connection No.] dialog box will be displayed. It is possible to check and set the setting contents.

Concerning on the registering details **6.16 Connection No.**

#### 4. Single Trigger

When this trigger is turned ON, it...

- rings up the phone number of [Tel. No.], and connects the lines
- checks the ON/OFF of the relay link area and the event, which has been set at C-NET No., and then performs the internal processing (such as file processing and the automatic starting of the macro)
- refreshes all of the currently displayed Microsoft® Excel sheet data
- automatically cuts the line and turns off this trigger

#### 5. Ongoing Trigger

When this Trigger is turned ON, it...

- rings up the phone number of [Tel. No.], and connects the line
- maintains the ongoing state of the line connection precisely until this Trigger is turned OFF

## **6. Limited Time**

When the line is connected by the ongoing trigger, make sure to register the connecting time for the purpose of prevention, in case that the line has been forgotten to be turned off.

The connection time should be registered by minutes.

When the time has expired, according to the time which has been registered, the line will be cut-off automatically, and the [ongoing Trigger] will be turned OFF.

## **7. Tel. No.**

Input the telephone number for the line which you would like to connect.

## **8. Informing Relay**

After the line has been connected, register the relay to be turned on. This is primarily used to check the line connection on the PLC side.

Also, to recover any PLC errors in progress before turning on the line, turn the relay off and wait the amount of Relay ON Time of Pulse Width Settings (this is set in the [Operation Preferences] settings; for detailed information **6.1 Setting Operation Preferences**).

After waiting the set amount of time, turn on the relay.

## **9. Informing event**

Register the event which you would like to turn on after the line has been connected. At this point that the line has been connected, if you will execute file processing or the Microsoft® Excel macro, use this informing event as the trigger

## **10. Comment**

Input comment (up to: 40 characters)

## **11. Node**

When the line has been connected between the PCWAY and PLC, select the node for which the informing relay is to be turned on.

Multiple nodes may be selected.

• [All Settings]

**Modem Support**

1 → Set All Trigger    V  ☐ Yes

2 → Interrupt Trigger    V  ☐ Yes

3 → Terminate Trigger    V  ☐ Yes

4 → Read Register    DT

5 → No. of Retries     Times

6 → Resend Wait Time     Sec (90 - 999)

7 → Next Connection Time     Sec (0 - 999)

Exit (E)    Help (H)

**1. Set All Trigger**

When the event number registered here turns ON, then all of the [Single Trigger] set at [Details] will be turned ON.

([Ongoing Trigger] will not be turned ON)

After this, the [Set All Trigger] will be turned OFF automatically.

Use this when you would like to connect all of the registered regions sequentially in a rotating manner (rotates and connects only once) automatically.

**2. Interrupt Trigger**

When there are a several [Single Trigger] under [Details] which are ON at the same time and when the event number registered here turns ON, all of the [Single Trigger] which have not been executed yet, will be put to hold.

(This does not influence the node numbers which are currently connected.)

When the [Interrupt Trigger] turns OFF, the [Single Trigger] will be executed once again.

**3. Terminate Trigger**

When there are a several [Single Trigger] under [Details] which are on at the same time and when the event number registered here turns on, all of the [Single Trigger] which have not been executed yet, will be turned off.

After this, the [Terminate Trigger] will turn off automatically.

**4. Read Register**

Register the data register for reading the PLC information for the occasion of an error reception, when the line has been connected from the PLC to PCWAY.

Starting from the specified data register, 2 words will be read.

Store the values noted below on the PLC side.

1st word:    Store the number for registering of [Modem Support] by decimal.  
(Example: when the registered number is 5, then K 5)

2nd word:    Store the event number which you would like to turn ON after the line has been connected by hexadecimal.

When there is no need to turn on the event, store: FFFF (H FFFF) by hexadecimal.

(Example: when the event No. is 2F, then H 2F)

**5. No. of Retries**

Set how many times you would like to retry connecting the line when a call attempt has failed, due to a faulty connection.

Set within the 0 to 9 times range.

**6. Resend Wait Time**

Set the waiting time until the line is reconnected after the line has failed to be connected.

Set within the 90 to 999sec. range.

## 7. Next Connection Time

If the [Single Trigger] parameter under [Details] has been set to on simultaneously for numerous times, specify the time period that the system is to wait between hanging up and connecting the line to another node. Any value between 0 and 999 may be set.

### Menu bar

#### • File (F)

- **Save (S)** Saves
- **Export** Saves the registered data on the text file (CSV format).
- **Save and Exit (E)** Saves and finishes the registering procedures.
- **Exit (X)** Finishes the registering procedures

### Registering procedures

Set whether to execute directly from the overview window, or not.


Select the check boxes on the left side of the [No.].

If there has been placed a check mark, then the executing will be performed.

In order to do the settings of each of the items, first select the row of the [No.] which you would like to set, and then click on the [Details] command button.

When you will do more general settings, then click on the [All Settings] command button.

The respective [Modem Support] screens, containing detailed information, are displayed. Enter the necessary settings.



- **Registering procedures of [Details]**

1. Place a check mark at [Execute] when you will execute the contents of what was registered.

The screenshot shows the 'Modem Support' dialog box. The 'Execute' checkbox is checked and circled. The 'C-NET No.' is set to 1, and the 'Connection No.' is also set to 1. The 'Single Trigger' and 'Ongoing Trigger' are both checked and set to 'Yes'. The 'Limited Time' is set to 'None'. The 'Tel. No.' field is empty. The 'Informing Relay' and 'Informing Event' are both checked and set to 'Notify'. The 'Node' list on the right contains numbers 0 through 15. At the bottom, there are buttons for 'PageUp (U)', 'PageDown (D)', 'Exit (E)', and 'Help (H)'.

2. At [C-NET No.], the number which has been registered at [C-NET Settings] will be displayed.  
With the [Browse] command button, the [C-NET Settings] dialog box will be displayed.  
With this, it is possible to confirm the registered contents or to simply register, here.  
For further information on the registering **6.11 C-NET Settings**.

This screenshot is identical to the first one, but the 'C-NET No.' field and its 'Browse (B)' button are circled. This highlights the option to browse for a different C-NET number.

3. For the [Connection No.], the number which has been registered at the [Connection No.] dialog box, will be displayed.  
After clicking the [Browse] command button, the [Connection No.] dialog box will be displayed.  
With this, set the node numbers which will be watched in accordance to the PLC network used at distant regions.  
For further information on the registering **6.16 Connection No..**

The screenshot shows the 'Modem Support' dialog box with the following fields and controls:

- No.:** 1
- Execute:** ☒ Yes
- C-NET No.:** 1 **Browse (U):** [Button]
- Connection No.:** 1 **Browse (P):** [Button] (highlighted with a red oval)
- Single Trigger:** ☒ Yes **V:** 0
- Ongoing Trigger:** ☒ Yes **V:** 0
- Limited Time:** ☒ None **0 Min**
- Tel. No.:** [Empty text box]
- Informing Relay:** ☒ Notify **R:** [Dropdown] **0**
- Informing Event:** ☒ Notify **V:** 0
- Comments:** [Empty text box]
- Node List:** 0, 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15
- Buttons:** PageUp (U), PageDown (D), Exit (E), Help (H)

4. Set the [Single Trigger]  
When this trigger is turned to ON, the registered telephone number will be rung up, the line will be connected, and then the line will be cut-off, automatically.
5. Set the [ongoing Trigger]  
When this trigger turns to ON, the registered telephone number will be rung up, and the line will be connected.  
The line will not cut-off unless this trigger is turned to OFF, or until the time (registered below at [Limited Time]) has expired.
6. When the line is connected with an ongoing trigger, the [Limited Time] should be specified to prevent the user from forgetting to hang up the line. To make this function valid, erase the check mark from the [None] box, and register a time, in minute units.
7. Input the telephone number of the line which you will connect.



8. Set at [Informing Relay] and [Informing Event], for the relay and event which you will turn to ON after the line has been connected.

9. Input a simple name for the comment.

10. At [Node], select the PLC node number from the list box, which has turned ON the informing relay when PCWAY and the PLC has been line connected.  
It is possible for the PLC to check whether the line has been connected by this relay.


11. To exit this screen when all of the settings have been entered, click on the [Exit] button.  
This closes the screen and returns to the list screen, which shows the updated settings.  
To continue entering settings, use the [PageUp] and [PageDown] buttons to change the number, and enter the settings.


#### • Registering procedures of [All Settings]

1. The [Set All Trigger] sets the trigger that turns on all of the [Single Trigger] registered under [Details].
2. If numerous single triggers are on, the [Interrupt Trigger] sets any triggers not currently being processed to the standby state.  
If numerous single triggers are on, the [Terminate Trigger] turns off all triggers not currently being processed.
3. At [Read Register], set the data register which PCWAY will read, when the line has been connected from the PLC side.  
Only the Unit No.1 node number will be read.  
Concerning the contents of the data register, refer to the [Read Register] at the [Item explanation].
4. Next, specify the number of times that a connection is to be redialed if the telephone is dialed and a connection error occurs on the line. The time that the system waits before retrying the connection is specified under [Resend Wait Time].

5. Specify the amount of time to be waited before the next connection, when numerous single triggers are on, a line is disconnected from one node and then connected to the next node.
6. When all of the items have been finished being registered, click on the [Exit] button. This dialog box will be closed.

## 6.15 Application Startup

- Go to the menu bar->[PCWAY]->[Various Types of Records (O)]->[Application Startup(U)]
- Click 



## Item Explanations

### 1. Execute

Select whether to execute the selected No., or not.

### 2. Trigger device

This specifies the device that boots the system.

[M: Relay link] 0 to 255F

[V: Event] 0 to 99F

### 3. Informing relay

If there is a PLC relay to be turned on after an application has been executed, specify the relay using this item.

If the relay link has been selected with the [Trigger device], however, always make sure a setting is entered for this parameter

### 4. Informing event

If there is an event to be turned on after an application has been executed, specify the event using this item.

### 5. Application File Name

This is used to register the name of the application to be executed. Either select the file with the [Reference] button, or input it directly.

### 6. Argument

If there are any values that are necessary for processing after an application has been executed, they can be entered using this item.

### 7. Comment

Input comment (up to: 40 characters)

## Menu bar

#### • File (F)

- **Save (S)**  
Saves

- **Export**  
Saves the registered data on the text file (CSV format).

- **Save in CSV Format (C)**  
This saves data in the CSV format.

Note:

With this method of saving data, the data is only saved in the CSV format, but no setting contents are registered. Use "Save" or "Save and Exit" to register items.

- **Print (P)**  
This prints out data.

- **Print Preview (V)**  
This displays an image of the data to be printed, before printing it.

- **Printer Setup (R)**  
Settings such as the model of printer being used and the printing method are specified here.


- **Save and Exit (A)**  
Saves and finishes the registering procedures.

- **Exit (X)**  
Finishes the registering procedures.

## Registering procedures


The list screen is used to specify whether or not processing is to be carried out. Click on the box at the far left to select it. If there is a check mark in the box, the processing is carried out, and if there is no check mark, the processing is not carried out.

To enter a setting, first select the row of the [No.] for which a setting is to be entered. Clicking with the left button of the mouse on the [Details] button display the [Application Startup] screen where detailed booting registrations can be specified for external applications. Enter the necessary settings.



### • [Details]

1. Place check mark at [Execute] when you will execute the registered contents.



2. These settings are used to boot applications. Click with the left button of the mouse on a [Trigger device] to select it, and enter the relay link and event numbers.

Application Startup

No. 1

Execute ☒ Yes

Trigger device M 0

Informing relay M 0 Relay R 0

Informing event ☒ Notify V 0

Application File Name Reference(R)


Argument Reference(E)



Comment

PageUp(U) PageDown(D) Exit(E) Help(H)

3. If there are any relays and events that you want to turn on after an application has booted, specify the relevant informing relays and informing events. If a relay link has been selected with a [Trigger device], however, always enter a setting for the informing relay.
4. Enter the name of the application to be booted under [Application File Name]. The name can either be input directly, or can be selected using the [Reference] button.
5. Enter any necessary arguments.
6. Enter a comment that will make it easy to identify the specified processing.
7. To exit this screen when all of the settings have been entered, click on the [Exit] button. This closes the screen and returns to the list screen, which shows the updated settings. To continue entering settings, use the [PageUp] and [PageDown] buttons to change the number, and enter the settings.

## 6.16 Connection No.

- Go to the menu bar->[PCWAY]->[Various Types of Records(O)]->[Operation Preferences]
- Click   
It is possible to enter the [Connection No.] dialog box from the [Operation Preferences] dialog box.



## Item Explanations

### 1. Comment

Input comment

### 2. Node number

Place a check mark at the check box for the node number which you want to connect.



## ◆ NOTE

- The node number 0 cannot be used when the network type is MEWNET-H. The registering itself will not cause errors, however it would not be possible to have PCWAY runned.
- The node number 0 cannot be used when the network type is [C-NET] or the [Modem] building a [C-NET] network, using the C-NET adapter. In this case, errors are not displayed for registration and PCWAY booting, but the PCWAY may malfunction or may abort.

## Menu bar


- File (F)
  - Save Saves
  - Save and Exit (E) Saves and finishes the registering procedures
  - Exit (X) Finishes the registering procedures.



## Registering procedures


### 1. Enter a comment.


If the setting was made using the [Browse] button for the [Connection No.] specified for [Details] under [Modem Support], to display the comment immediately after it has been entered, select a different number and then select the original number again. The input comment is displayed in the "Comment" column shown below, right after the colon.



- Place a check mark at the PLC node number which you wish to connect to.  
Do this by left clicking the check box of your desired number from 0 to 99. The number which you have specified here, is the connected node number.
- After all of the necessary items for registering is completed, save this before you exit [Connection No.].

## 6.17 Ethernet Remote

- Go to the Menu bar [PCWAY] -> [Various Types of Records(O)] -> [Ethernet Remote].
- Click 



## Item Explanations

### • [Details window]

The screenshot shows the 'Ethernet Remote' dialog box with the following fields and settings:

- 1 → Destination St No.: 1
- 2 → Execute: ☐ Yes
- 3 → Destination Name: (empty text box)
- 4 → Single Trigger: ☒ Yes, V 0
- 5 → Ongoing Trigger: ☒ Yes, V 0
- 6 → Limited Time: ☒ None, 0 Min
- 7 → ET-LAN Unit: ☒ Use
- 8 → Timeout: Communication 10 Sec, Connection 60 Sec
- 9 → Destination IP address: 0 . 0 . 0 . 0
- 10 → Destination port No.: 1025 (1025 - 32767)
- 11 → Source port No.: 0 (0, 1025 - 32767)
- 12 → Source St No.: 64
- 13 → Informing Relay: ☒ Notify, R 0
- 14 → Informing Event: ☒ Notify, V 0
- Reception Details(R) button (indicated by arrow 15)
- PageUp(U), PageDown(D), Exit(E), Help(H) buttons at the bottom.

#### 1. Destination St No.

Fixed destination station number is displayed.

If check the Yes check box at the Execute for each node number, these node numbers must be selected in "Connection No." dialog box.

#### 2. Execute

Select whether executing the above destination node numbers or not.

When executing, check this check box to enter the above destination station numbers into [Connection No.] dialog box.

#### 3. Destination name

Enter the destination name (40 characters enabled)

#### 4. Single Trigger

When turning on this trigger, following set destination PLCs connect to line.

Then check ON/OFF of the relay area and events entered at C-NET Settings and execute adopted internal procedure (such as file processing, auto macro start).

Later, after refreshing all sheet data of Microsoft® Excel displayed currently, the line is automatically cut off and this trigger is turned off.

#### 5. Ongoing Trigger

When this trigger turned on, following set destination PLCs connect, the line connection remains until this trigger is turned off.

#### 6. Limited Time

When connecting the line with the Usual Trigger, enter the connecting time by the minute unit to prevent forgetting to cut off line.

When the specified time is expired, the line is automatically cut to turn off the usual trigger.

#### 7. ET-LAN Unit

Check the check box when communicating with a personal computer via our ET-LAN Unit.

## 8. Timeout

- **Communication**

Enter the timeout interval every communication within the range from 1 to 950 sec (default value: 10) after established the connection.  
This setting is invalid until establishing the connection.

- **Connection**

Enter the timeout interval until establishing the connection within the range from 1 to 100 sec (default value: 60).

## 9. Destination IP address

Enter the IP address for the line that you would like to connect.

## 10. Destination port No.

Enter the port number within the range from 1025 to 32767. (default value : 1025)

## 11. Source port No.

Enter the port number of a personal computer.

## 12. Source St No.

Enter the station number of a personal computer.

Do not enter the station number, however, without our ET-LAN unit.

**Note:**

Enter the different node number from the Reception Source St No. in the Reception Details dialog box

## 13. Informing Relay

After connecting the line, enter the relay turned on.

Mainly use it to check connecting the line for PLCs.

And once the relay is turned off, turn it on after waiting for the system pulse width time (entered in Operation Preferences dialog box. See section **6.1 Setting Operation Preferences** for setting details.)

## 14. Informing Event

After connecting the line, enter the event turned on.

Use this Informing Event as the trigger when you would like to execute the file processing and the macro of Microsoft® Excel after connecting the line.


## 15.Reception Details

Set a personal computer configuration required for connection of the line from PLC to the computer.

Click  button to specify each item.

- **[Reception Details]**

Here settings is activated with checking the "Receive" check box at "Reception" or "Error Reception" under <Receive All Settings> in [All settings(A)] dialog box.



### 1. Destination port No.

Enter the port number of the personal computer receiving communication from PLCs.

**Note:**

The port number is not required without checking the "ET-LAN unit" check box in previous [Details window] Entry of the port number is required only in use of the ET-LAN unit for PLCs. Enter different node number from the Source St No. in Detail window.

-----Following settings from 1 to 3 are applied in Reception mode.

**The settings are invalid in Error Reception mode.-----**

### 2. Reception Connection Permission Event

Line ON/OFF is inferred from this event ON/OFF after connecting line from PLCs.

### 3. Reception Connection Permission Wait Time

It is time of waiting for above Reception Connection Permission Event turned ON. The event turned ON within this setting time remains on-line until the event turned OFF, while the event not turned ON cut the line with achieving limited time.

### 4. Event automatically turn on

With checking the check box, the Reception Connection Permission Event set above is turned on and the connection is remained until the event turned off.

• [All Settings]

The screenshot shows the 'Ethernet Remote' dialog box with the following settings and callouts:

- Send All Settings:**
  - 1 → Set All Trigger: V 0 ☐ Yes
  - 2 → Interrupt Trigger: V 0 ☐ Yes
  - 3 → Terminate Trigger: V 0 ☐ Yes
  - 4 → No. of Retries: 0 Times
  - 5 → Resend Wait Time: 90 Sec (0 - 999)
  - 6 → Send Line: 1
- Receive All Settings:**
  - 7 → Reception: ☐ Receive
  - 8 → Error Reception: ☐ Receive
  - 9 → Read Register: DT 0
  - 10 → Receive Line: 0
  - 11 → Reception Port No.: (1025 - 32767) with navigation buttons >> and <<

Buttons at the bottom: Exit (E), Help (H).

### Send All Settings

Setting for connection from a personal computer to PLCs.

#### 1. Set All Trigger

When event number entered here is turned ON, all [Single Trigger] specified in the main window are turned ON.

(The ongoing trigger is not turned on.)

Later this set all triggers are automatically turned OFF.

Use the trigger to link connect all entered destinations automatically.

#### 2. Interrupt Trigger

If each [Single Trigger] in [Details window] is turned ON, entered event number, that is turned ON, sets any current [Single Trigger], that has not yet executed, wait.

(The node number during connecting is not affected.)

As soon as this interrupt trigger is turned off, the [Single Trigger] re-start processing.

#### 3. Terminate Trigger

If each [Single Trigger] in [Details window] is turned ON, entered event number, that is turned ON, sets any current [Single Trigger], that has not yet executed, turned off.

#### 4. No. of retries

Enter how many retries for connection when line connection meets with failure.

Enter the times of retry within the range from 0 to 9.

#### 5. Resend Wait Time

Enter the waiting time from above failure of line connection to re-connection.

#### 6. Send Line

Enter the number of line via which data is sent at a time from a personal computer to each PLC. This number of line, especially, is required mainly when using ISDN line.

When using both of the ISDN line for sending, the number of line is 2, and when using one line for following reception line, the number is 1.

Be sure to keep following condition.

Total number of line = the number of line to send + the number of line to receive

## Receive All Setting

Setting for connection from PLCs to a personal computer (a personal computer receives)

### 7. Reception

Check it when PCWAY is connected to PLC if receiving the reception from PLC.

### 8. Error Reception

Check it when PCWAY is connected to PLC if receiving the reception from PLC.

#### \* Different from Reception and Error Reception

- Action of PCWAY

[Reception]

Continuous connection can be active until specifying.

See descriptions from 1 to 3 in former Reception Details.

[Error Reception]

Immediately only required processing (turning on the event number saved in two WORD of Read Register and this event performing as the trigger) to cut off connecting line automatically.

- In PLC, the value saved in three WORD of following Read Register is different.

### 9. Read Register

In connecting line from PLCs (When receiving), define the data register to read information of PLCs

First specified data register and subsequent 3 WORDS are read.

Save following value in PLCs

1 WORD: 1 fixed

2 WORD: Save the event number turned on after connection hexadecimally.  
When not turning on the event, save FFFF (H FFFF) hexadecimally.  
(i.e. Event No. 2F is H 2F)

3 WORD: Reception for 1  
Error Reception for 0

If checked "Receive" check box at either reception type, checked processing is executed irrespective of above values.

### 10.Receive Line

Enter a number of lines via which a personal computer can take reception from PLCs.

This number of lines is required mainly in use of the ISDN line Specify 2 if using two lines of the ISDN line for reception.

Specify 1 if using one line for former the sending line.

Be sure to keep following condition.

Total lines = A number of sending line + A number of receiving line


### 11.Reception port No.

Enter the port number at which a personal computer can take reception from PLCs.


The port number less than a number of receiving line cause error.

The port number more than a number of receiving line, The port number same with specified number of reception line only is available.


#### Setting method




1. Enter the number registered as Reception Port No.

2. With clicking  the setting is displayed in the right field to complete the registration.

## Deleting



1. For deleting settings, select deleted port number in the right field to click .
2. Selected port number move to Reception Port No. field, and then delete it there.


## Menu bar


### • File(F)

- **Save(S)** Saves
- **Export** Saves the registered data on the text file (CSV format).
- **Save and Exit (E)** Saves and finishes the registering procedures.
- **Exit (X)** Finishes the registering procedures.



## 6.18 E-mail Setting

- Go to the Menu bar [PCWAY] -> [Various Types of Records(O)] -> [E-mail Setting(L)].
- Click 



### Item Explanations

#### 1. Executes E-mail

Place a check mark in this check box when sending and receiving the e-mail is executed. When a check mark is not placed in this box, e-mail processing is not executed even if the required data are entered.

## • [Operation Preferences]

The screenshot shows the 'PCWAY E-mail Configuration' dialog box. It is divided into several sections: 'Server', 'Incoming Mail Server', 'Operation Preferences', 'Private', 'Connection settings', and 'Folder settings'. Numbered callouts point to the following elements:

- 2: SMTP field
- 3: POP3 field
- 7: Send interval time (1 min)
- 8: Retries the E-mail checkbox
- 9: Private checkbox
- 12: Mail address field
- 13: Name field
- 14: Send file folder field
- 15: Sent file folder field
- 16: Preservation period of the executed E-mail file (2 days)
- 17: This Checkbox attaches after compressing the attachment-file to the own restoring file checkbox
- 4: Receives the E-mail checkbox
- 5: Account name field
- 6: Password field
- 10: Use Dial-up connections checkbox
- 11: Connection name dropdown

### Server

#### 2. SMTP

Enter the server name for outgoing e-mails.

#### 3. POP3

Enter the server name for incoming e-mails.

### Incoming Mail Server

#### 4. Receives the E-mail

Place a check mark in this check box when e-mails are received.

E-mails can be received from the PC and the cellular phone and, as a result, "V" (Event) of PCWAY can be turned ON.

For details, refer to **4.9.4 Inquiry on the Equipment Status from the PC and the Cellular Phone**.

#### 5. Account name

Enter the account name for the e-mail used.

#### 6. Password

Enter the password for the e-mail used.

## **Operation Preferences**

### **7. Send interval time**

Enter the interval for checking newly arrived e-mails and sending e-mails during dial-up connection.

### **8. Retries the E-mail**

Place a check mark in this check box when you wish to resend the e-mail due to an error.

E-mail is resent at the interval specified in "Send interval time" above.

During LAN connection, the error e-mail is resent while another e-mail is sent.

### **9. Delete (Retry Data)**

Pressing this button deletes the error e-mail when sending e-mails.

The error e-mail is stored in the Retry folder, which is in the "Send file folder", until it is resent.

## **Connection settings**

### **10. Use Dial-up connections**

Place a check mark in this check box when using dial-up connection.

### **11. Connection name**

Select the desired connection name from the pulldown menu which includes dial-up connection names registered in the PC. When a check mark is not placed in "Use Dial-up connections" check box, the dial-up connection name cannot be selected.

## **Private**

### **12. Mail address**

Enter the e-mail address of the PC in which PCWAY is used.

The address specified here is displayed in the "From" section on the received e-mail.

### **13. Name**

Enter the name of the person who sends the e-mail. The name specified here is displayed in the "From" section on the received e-mail.

## **Folder settings**

### **14. Send file folder**

E-mails which have not been sent yet are stored in this folder.

The folder of the e-mail with the sending error is transferred to the Retry folder in this folder.


## 15.Sent file folder

Files for sent and received, error log e-mails are stored in this folder.


Sent e-mail file is stored in the Send folder in this folder.

Received e-mail file is stored in the Retry folder in this folder.

- File name for the send e-mail



- File name for the received e-mail



- Error log File  
NAIS\_MewmIIErr.log

The error contents saves into the file.

Please confirm the contents by the text editor (NotePad etc).

### Example)

Date : Fri, 10 Jan 2003 12:46:36 RECEIVE\_ERROR (or SOCKET\_ERROR)

-ERR [AUTH] Password supplied for "TEST" is incorrect.

→ the error details contents from windows®

Case RECEIVE\_ERROR:

-Please confirm the setting contents in [Account name], [Password], [SMTP], [POP3].

Case SOCKET\_ERROR:

-Please confirm the setting contents in [SMTP], [POP3], [Dial-up].

-The SMTP Server or the POP3 Server is busy.

Exception:

-Maybe it's the disk error. Please confirm the hard disk.

## 16.Preservation period of the executed E-mail file

Enter the desired preservation period for the file stored in Sent file folder.

## 17.This Checkbox attaches after compressing the attachment-file to the own restoring file (For the old version's add-in send program)

This function is limited for the user who uses the old version Microsoft® Excel add-in software (PCWAYMAIL.xla). In order to compress the attachment file, place a check mark in this check box.

• [Details]

The screenshot shows the 'E-mail Setting' dialog box with the following fields and options:

- 1. No.:** A text box containing the number '1'.
- 2. Execute:** A checkbox labeled 'Yes'.
- 3. Comment:** A large text area for entering a comment.
- 4. Trigger Device:** A dropdown menu showing 'M' and a text box containing '0'.
- 5. Subject:** A text box for entering the subject of the email.
- 6. Address:** Three text boxes for 'To:', 'Cc:', and 'Bcc:'. An 'Address Select' button is next to the 'Bcc:' field.
- 7. Send Message:** A text box for entering the message content.
- 8. Sends the data in the Cell:** A checkbox. To its right are fields for 'Sheet Name', 'Cell Area', and a colon-separated field, with an example '(Example. A1:C3)'.
- 9. Attach File:** A section containing three checkboxes:
  - 'Attaches the book of the Excel in PCWAY now.' with radio buttons for 'Update ALL Sheet Data' and 'No Update ALL Sheet Data'.
  - 'Attaches the designated file.' with a text box and a 'Reference' button.
  - 'This Checkbox attaches after compressing the attachment-file to the own restoring file.'
- 12. Informing relay:** A checkbox labeled 'Execute'. To its right are dropdowns for 'Node' (showing '1') and 'R' (showing 'R'), and a text box containing '0'.
- 13. Informing event:** A checkbox labeled 'Execute'. To its right are a dropdown for 'V' (showing 'V') and a text box containing '0'.

At the bottom of the dialog are buttons for 'PageUp', 'PageDown', 'Exit', and 'Help'.

**1. No.**

The processing No. to be executed is displayed. (1 to 100)

**2. Execute**

Select whether the processing for the specified No. is executed or not.

**3. Comment**

Input any comment.

**4. Trigger Device**

Specify the device to start the e-mail function.

M: Relay link 0 to 255F  
V: Event 0 to 99F

When you register "M", you are sure to register "informing relay" please.

**5. Subject**

Enter the subject of the e-mail to be send.

Up to 256 characters (in one-byte characters) can be entered.

## 6. Address


Enter the addresses in "To", "Cc", or "Bcc". There are no limitations of e-mail address number. The address can be selected from the Address List that will appear by clicking

**Address Select** button.

### How to select the address from the Address List


1. Clicking **Address Select** button displays the following dialog box on which the pre-registered addresses are listed. A new address can be added on the List using **Add...** button.

\* For details concerning the addition of a new address, refer to "Adding a New Address to the Address Book" as shown below.



2. From the Address List, select the addresses to which you wish to send e-mail(s), and click **<< Select To: >>**, **<< Select Cc: >>**, and/or **<< Select Bcc: >>** in Address Select. Then, the selected addresses will be added under the field(s) of **<< Select To: >>**, **<< Select Cc: >>**, and/or **<< Select Bcc: >>**.

To delete the address in Address Select, select the address you wish to delete and click [Delete] button.



## 7. Send Message

Enter the message you wish to send within 256 characters (in one-byte characters).

## 8. Sends the data in the Cell

Place a check mark in the check box here. Then, enter the Sheet Name and Cell Area of the Microsoft® Excel Sheet you wish to send.

When "Send Message" is entered, the data in the Cell Area is sent following the message specified in "Send Message".

### Example:

Sheet Name: Sheet1

Cell Area: C2:F4

<input checked="" type="checkbox"/> Sends the data in the Cell    Sheet Name <input type="text" value="Sheet1"/> Cell Area <input type="text" value="C2"/> : <input type="text" value="F4"/> (Example. A1:C3)						
	A	B	C	D	E	
1						
2			A	B	C	
3		Success	10	30	51	
4		Error	1	2	3	
5						
6						



Message to be send

A,B,C  
10,30,51  
1,2,3

## 9. Attaches the book of the Microsoft® Excel in PCWAY now.

Place a check mark in this check box when you wish to send the Microsoft® Excel book used in PCWAY as the attachment file.

Before sending it, whether all Sheet data is updated or not can be selected.

For details on this function, refer to **5.12 Update All Sheet Data**.

## 10. Attaches the designated file.

Place a check mark in this check box when you wish to send a file other than the one specified in "Attaches the book of the Microsoft® Excel in PCWAY now" as the attachment file.

## 11. This Checkbox attaches after compressing the attachment-file to the own restoring file.

Place a check mark in this check box when you wish to send the attachment files specified in "Attaches the book of the Microsoft® Excel in PCWAY now" and "Attaches the designated file" above by compressing them to self-extracting LZH format files.

## 12. Informing relay

Place a check mark in the Execute check box when you wish to turn ON the PLC contact in the status that the e-mail sending processing is completed. Be sure to place a check mark, however, when you have selected "M" (Relay link) for the Trigger Device.

## 13. Informing event

Place a check mark in the Execute check box when you wish to turn ON the event in the status that the e-mail sending processing is completed.



### ◆ NOTE

When Dial-Up connection is used, an e-mail is sent at the intervals specified in the "Send interval time" under Operation Preferences, which is in the E-mail Configuration dialog box, after the e-mail sending processing is completed.

When LAN is used, an e-mail is sent soon after the e-mail sending processing is completed.

Even if an error occurs while the e-mail is being sent, the processing "Informing relay" and "Informing event" are executed.

## Menu bar


- **File**


- **Save** Saves the data.
- **Export** Saves the registered data on the text file (CSV format).
- **Save and Exit** Saves the data and then completes the registration processing.
- **Exit** Terminates the registration processing.


- **Edit**


- **Copy saved contents** Copies the current position No. of the cursor.
- **Paste saved contents** Pastes the data copied in "Copy saved contents."
- **Cut saved contents** Deletes the current position No. of the cursor.
- **Address** Adds a new e-mail address to the Address Book.


## Adding a new address to the Address Book

- When selecting Address from Edit in the E-mail Setting dialog box, the following dialog box will appear. Then, click  button.



When  button is clicked, the following dialog box will appear. Enter the necessary information in the Name and Address fields.

Then, click  button.





- Changing the registered address and name

Clicking **Edit...** button displays the following dialog box.  
Change the contents in the Name and Address fields.



The image shows a dialog box titled "E-Mail". It contains two text input fields. The first field is labeled "Name" and contains the text "Sample". The second field is labeled "Address" and contains the text "aaa@bbb.co". At the bottom of the dialog box, there are two buttons: "OK" and "Cancel".

- Deleting the registered address and name

Select the registered data (address and name) that you wish to delete, and click

**Delete** button.


Then, the message box asking you "May I delete the registered Data?" will appear. Then, click [Yes] button.

## • Option

### Permitted Reception Mail Address Setting

Mails with the addresses registered here can be received.

When selecting [Permitted Reception Mail Address Setting] from [Option] in [E-mail Setting] dialog box, the following dialog box will appear.



The image shows a dialog box titled "E-mail Setting - Permitted Reception Mail Address Setting". It features a check box labeled "Uses the permitted reception" which is checked. To the right of the check box are four buttons: "Close", "Add...", "Edit...", and "Delete". Below the check box is a large empty rectangular area.


When you place a check mark in the "Uses the permitted reception" check box, only e-mails with the addresses that have been registered previously are received.

When a check mark is not placed in the check box, this function does not work even if there are some registered addresses. In other words, all messages set for PCWAY are received.

## Registering a new address

To register a new address, place a check mark in the "Uses the permitted reception" check box and click **Add...** button.


Then, the following dialog box will appear. Enter the necessary information in the Address field. Then, click **OK** button.



\* Only the Address field is active.

- Changing the registered address

Clicking **Edit...** button displays the following dialog box. Change the registered address into a new one.



- Deleting the registered address

Select the registered address that you wish to delete, and click **Delete** button. Then, the message box asking you "Do you want to delete?" will appear. Then, click [Yes] button.

## **Chapter 7**

---

### **Overview List for Reference**

## 7.1 Notation method of the Memory area in PCWAY

Memory area name		Number of point	Number	PCWAY notation method
Relay	External input relay(X)	8192	0-511F	X0-X511F
	External output relay(Y)	8192	0-511F	Y0-Y511F
	Internal relay(R)	14192	0-886F	R0-R886F
	Special Interval Relay(R)	176	9000-910F	R9000-R910F
	Link relay(L)	10240	0-639F	L0-L639F
	Timer Contact(T) *1	3072	0-3071	T0-T3071
	Counter Contact(C) *1	3072	0-3071	C0-C3071
	Relay link area(M)	4096	0-255F	M0-M255F
	Event(V)	1600	0-99F	V0-V99F
Memory area	Data register(DT)	10240	0-10240	DT0-DT10240
	Link data register(LD)	8448	0-8447	LD0-LD8447
	File register(FL)	32765	0-32764	FL0-FL32764
	Special data register(DT)	256	9000-9255	dt0-dt255
		256	90000-90255	dt0-dt255
	Timer/Counter set value(SV)	3072	0-3071	SV0-SV3071
	Timer/Counter elapsed value(EV)	3072	0-3071	EV0-EV3071
	Data link area *2	4096	0-4095	m0-m4095
	External Input(WX)	512	0-511	WX0-WX511
	External Output(WY)	512	0-511	WY0-WY511
	Internal Relay(WR)	887	0-886	WR0-WR886
	Link Relay(WL)	640	0-639	WL0-WL639

The above number is restricted in the area of PLC regarded as the object of connection.



### ◆ NOTE

\*1. The timer and counter can be used only if being used with the MEWNET-H.

\*2. The data link area can be used only when MEWNET-H is used.

## 7.2 Use file name list

---

Character Change File	W_BITCHR.PLC
Message File	W_WRDMSG.PLC
Operation Formula File	W_WRDCAL.PLC
Operation Formula Comment File	W_WRDCAL.CMT
File Master File	W_USRFFL.PLC
File Master Comment File	W_USRFFL.CMT
File master intermediate cord File	W_USRREC.PLC
File Processing File	W_FSRKFL.PLC
File Processing Comment File	W_FSRKFL.CMT
File processing intermediate cord File	W_FSRITR.PLC
File Trigger File	W_FLTRIG.PLC
Event Startup File	W_VINTER.PLC
Weekly Timer File	W_TIMSET.PLC
Interval Timer File	W_CYCSET.PLC
C-NET Setting File	W_RELAY.PLC
C-NET Setting Comment File	W_RELAY.CMT
Auto Macro Startup File	W_MACRO.PLC
Sound Startup File	W_SOUND.PLC
Modem Support File	W_PCTEL.PLC
Application Startup File	W_WINEXE.PLC
Connection No.File	W_PCUNIT.PLC
Event Condition File	W_EVENT.PLC
Ethernet Remote File	W_ETHER.PLC
E-mail Setting File	W_MAILDATA.PLC
E-mail Address Book File	W_ADDRBOOK.PLC
E-mail Permitted Reception File	W_PERMITADDR.PLC

## 7.3 Incorporation macro name list

---

### Input method

1. When Sub Procedure: Call Application.Run("Function name", Argument 1,...)

Example) Download Data

Call Application.Run("PCWAYsubDownLoad")

2. When Function Procedure: Return value = Application.Run("Functionname", Argument 1,...)

Example) Specified saving process of Microsoft® Excel file name. (File name : TEST)

Dim Filename as String

Filename= Application.Run("PCWAYfncFileSaveNameType", "TEST")

### Menubar Toolbar registration function

- |  |                              |
|--|------------------------------|
| • Cell Settings                          | Sub PCWAYsubSetCell          |
| • Delete Cell Settings                   | Sub PCWAYsubCellDel          |
| • Copy Cell Settings                     | Sub PCWAYsubCellCopy         |
| • Paste Cell Settings                    | Sub PCWAYsubCellPaste        |
| • Set Cell Order: No Action              | Sub PCWAYsubCellMoveNo       |
| • Set Cell Order: Down word              | Sub PCWAYsubCellMoveDown     |
| • Set Cell Order: To the Right           | Sub PCWAYsubCellMoveRight    |
| • Start PCWAY                            | Sub PCWAYsubShellPcwayStart  |
| • Exit PCWAY                             | Sub PCWAYsubExecuteStop      |
| • Read PCWAY Settings Again              | Sub PCWAYsubExecuteRestart   |
| • Start Monitor                          | Sub PCWAYsubRunStart         |
| • Stop Monitor                           | Sub PCWAYsubRunStop          |
| • Download Data                          | Sub PCWAYsubDownLoad         |
| • Update All Sheet Data(with message)    | Sub PCWAYsubRefresh          |
| • Update All Sheet Data(without message) | Sub PCWAYsubRefreshNoMessage |
| • Update Active Sheet Data(with message) | Sub PCWAYsubSheetRefresh     |
| • Update Sheet Data(without message)     |                              |

Sub PCWAYsubSheetRefreshNoMessage(Argument 1 as String)

Argument1: Sheet name that renews information

In the case that argument 1 was omitted or in the case that "" was specified, the active sheet is renewed.

**Example) Renews the information of Sheet no.2.**

Call Application.Run("PCWAYsubSheetRefreshNoMessage", "Sheet2")

- SaveExcel File(fixed File name : Present file name+YYMMDDHHMMSS)

Sub PCWAYsubFileSave

- **Save Excel File**(possible to specify file name)

Function PCWAYfncFileSaveNameType \_

(Argument 1 as String, Argument 2 as Integer) As String

Argument1: Specified file name (File expansion (xls) is not included)  
When you registered only the file name, the HTML file is saved to the same folder as the Microsoft® Excel book file.

Argument2: 0:Saves the original book.  
1:Original book is not saved.  
(It is 0 in the case of omission.)

Return value:File name which was saved (Folder name accompaniment)

**Example) The name called TEST is attached when saving the present book.  
The original book is not saved.**

**Dim strFilename as String**

**strFilename=Application.Run("PCWAYfncFileSaveNameType", "TEST" ,1)**

- **Save HTML File**(fixed File name : Present file name)

Sub PCWAYsubHTMLFileSave

- **Save HTML File**(possible to specify file name)

Function PCWAYfncHTMLFileSaveNameType \_

(Argument 1: As String, Argument 2: As Integer) As String

Argument1: Specified file name (File expansion (htm) is not included)  
When you registered only the file name, the HTML file is saved to the same folder as the Microsoft® Excel book file.

Argument2: 0:Saves the original book.  
1:Original book is not saved.  
(It is 0 in the case of omission.)

Return value:File name which was saved (Folder name accompaniment)

- |                                |                                |
|--------------------------------|--------------------------------|
| • <b>Operation Preferences</b> | Sub PCWAYsubShellEnvironUpdate |
| • <b>Character Change</b>      | Sub PCWAYsubShellDisplayChange |
| • <b>Message</b>               | Sub PCWAYsubShellMessage       |
| • <b>Operation Formula</b>     | Sub PCWAYsubShellCalc          |
| • <b>File Master</b>           | Sub PCWAYsubShellFileMaster    |
| • <b>File Processing</b>       | Sub PCWAYsubShellFileLog       |
| • <b>File Trigger</b>          | Sub PCWAYsubShellFileTrigger   |
| • <b>Event Startup</b>         | Sub PCWAYsubShellEventTrigger  |
| • <b>Weekly Timer</b>          | Sub PCWAYsubShellWeeklyTimer   |
| • <b>Interval Timer</b>        | Sub PCWAYsubShellIntervalTimer |
| • <b>C-NET Settings</b>        | Sub PCWAYsubShellCNetEntry     |
| • <b>Auto Macro Startup</b>    | Sub PCWAYsubShellEventMacro    |
| • <b>Sound Startup</b>         | Sub PCWAYsubShellSound         |
| • <b>Application Startup</b>   | Sub PCWAYsubShellRunExec       |
| • <b>Modem Support</b>         | Sub PCWAYsubShellModem         |
| • <b>Application Startup</b>   | Sub PCWAYsubShellRunExec       |
| • <b>Ethernet Remote</b>       | Sub PCWAYsubShellEthernet      |
| • <b>E-mail Setting</b>        | Sub PCWAYsubShellEMail         |
| • <b>Help display</b>          | Sub PCWAYsubHelpDisp           |
| • <b>Compile</b>               | Sub PCWAYsubCompile            |

## Internal treatment function

- Confirm the currently connected node number

Sub PCWAYsubMyAppSetUnitState

- Function for obtaining PCWAY execution folder

Function PCWAYfncExecDirectory as String

Return value: Execution folder

**Example) Dim strFolder as String**

**strFolder= Application.Run("PCWAYfncExecDirectory" )**

- Function for obtaining PCWAY work folder

Function PCWAYfncWorkDirectory as String

Return value: Work folder

**Example) Dim strFolder as String**

**strFolder= Application.Run("PCWAYfncWorkDirectory")**

- Obtains sheet protection password

Function PCWAYfncGetProtect as String

Return value:Password

**Example) Dim strPassword as String**

**strPassword= Application.Run("PCWAYfncGetProtect")**

### Supplement example)

This is the example of the removing of the sheet protection of the sheet (for example Sheet1). After the above function is inputted, the following function is inputted.

Worksheets("Sheet1").UnProtect StrPassword

The next is the example of the protecting of the sheet, once again. After the above function is inputted the following function is inputted.

Worksheets("Sheet1").Protect StrPassword

- Changing the interval timer settings temporally

Function PCWAYfncSetIntervalChange

(Argument 1 as Integer, Argument 2 as Integer, Argument 3 as Integer) as Integer

Argument1: Interval Timer No.(1 to 100)

Argument2: Execution flag      0: End  
   1: Execute

Argument3: Interval time(every seconds)

Return value:    0 :Normal  
                     -1:Interval timer no. and specified error of folder to be executed  
                     -2:Specified error of execution flag  
                     -3:Specified error of interval time

**Example)Execute the interval timer processing of No. 1 at every 3 second interval.**

**Dim intRet as Integer**

**intRet= Application.Run("PCWAYfncSetIntervalChange" ,1,0,3)**



- Processing for obtaining the event number status

Function PCWAYfncEventRead(ByVal Argument 1 as String) As Integer

Argument 1:        Event no.  
                       Example) For V21, the argument is "21".

Return value:      0: OFF  
                       1: ON

**Example) To obtain the status of event V21**

```
Dim intRet as Integer
intRet = Application.Run("PCWAYfncEventRead","21")
'If intRet is 1, the event is on, and if 0, the event is off.
```

- Processing for setting the event number status

Function PCWAYfncEventWrite(ByVal Argument 1 as String, ByVal Argument 2 as Integer) As Integer

Argument 1:        Event no.  
                       Example) For V21, the argument is "21".

Argument 2:        1: ON  
                       0: OFF

Return value:      0: Normal  
                       Any other value: Error

**Example) To turn V21 on**

```
Dim intRet as Integer
intRet = Application.Run("PCWAYfncEventWrite","21",1)
```

- Processing for double click operation

Function PCWAYsubDoubleClickEntry

**Example) When cell "D5" is clicked.**

```
Range("D5"). Select
Call Application Run("PCWAYsubDoubleClickEntry")
```

#### ■ Attention point on use

With PCWAY add-in programs, procedures are executed automatically when an event takes place.

When the properties of the procedures below are changed, the PCWAY Add-In program will not operate correctly. Please be careful.

#### Procedure various kinds of settings

With Application

```
.OnSheetActivate = "PCWAYsubAutoSheet" 'Sheet activate
.OnDoubleClick = "PCWAYsubDoubleClick" 'Double click
.OnData = "PCWAYsubDDEAddinEvents" 'DDE Link
.DisplayNoteIndicator = True 'Memo mark
.ActiveCell.NoteText = "=MEW(" 'Memo
.ScreenUpdating = True 'Screen display renewal
```

End With

### Event procedure relation function

-Sheet data notice processing	Sub PCWAYsubAutoSheet
-Double click processing	Sub PCWAYsubDoubleClick
-Cell input processing	Sub PCWAYsubCellEntry
-DDE Event arrival of the post processing	Sub PCWAYsubDDEAddinEvents



### ◆ NOTE

---

Attention when you use "PCWAYsubDoubleClick" of Event procedure relation function into Microsoft® Excel Macro.

Use "PCWAYsubDoubleClickEntry", when you want to use "PCWAYsubDoubleClick".

Ex.) Operating ON/OFF the relay of Microsoft® Excel Cell "B2".  
Range("B2").Select  
Call Application.Run("PCWAYsubDoubleClickEntry")

## 7.4 API Function for Event(V) Access

---

This section describes the API functions used to obtain and convert the on/off status of events (V) being managed internally in the PCWAY with other applications created with VC and VB.

### 7.4.1 Obtaining the Status of the Specified Event Number (VC Function)

---

#### PCWAYapiEventRead

- **Function**

Obtain the status of the specified event number.

- **Construction**

```
short FAR PASCAL PCWAYapiEventRead (  
char * pcEventString  
);
```

- **Parameter**

pcEventString

Specifies the character string of the event number ending with NULL.

- **Return value**

When the event turns on, 1 is returned, and when it turns off, 0 is returned. If an event number that does not exist is specified for the argument, ?1 is returned.

- **Explanation**

Reads the status of event 19E (V19E).

```
Short sResult;  
Sresult = PCWAYapiEventRead ("9E"); // Reads status of V19E  
if (1 == sResult) {  
    MessageBox (NULL, "V19E is on", "EVENT", MB_OK);  
}  
else if (0 == sResult) {  
    MessageBox (NULL, "V19E is off", "EVENT", MB_OK);  
}  
else {  
    // An error results if the return value is anything other than 1 or 0  
    MessageBox (NULL, "The event number specified at the argument is invalid", "EVENT",  
    MB_OK);}
```

- **Applicable information**

Microsoft Visual C++: Version 6.0 or later

Header: Declared within pcwayapi.h

Import library: Uses w\_mcrdpc.lib

DLL: Uses w\_mcrdpc.dll

Since it is using the same DLL as PCWAY, make sure to use the program that uses this function from the same directory that PCWAY is executed from.

## 7.4.2 Obtaining the Status of the Specified Event Number (VB Function)

---

### PCWAYapiEventRead

- **Function**

Obtain the status of the specified event number.

- **Construction**

PCWAYapiEventRead (strEventNo)

- **Configuration**

The PCWAYapiEventRead function construction is made up of the arguments given below.  
strEventNo Specifies the character string of the event number.  
Insert NULL (Chr (0)) at the end of the specified event number.

- **Return value**

When the event turns on, 1 is returned, and when it turns off, 0 is returned. If an event number that does not exist is specified for the argument, -1 is returned.

- **Explanation**

Reads the status of event 19E (V19E).

Declare Function MyAppGetEventState Lib "W\_MCRDPC.dll" Alias  
"PCWAYapiEventRead" (ByVal strEventNo As String) As Integer

```
Sub Macro1( )
    Dim IntEventState As Integer
    ' Reads status of V19E
    IntEventState = MyAppGetEventState ("19E" & Chr (0))
    If 1 = IntEventState Then
        MsgBox ("V19E is on")
    Else If 0 = IntEventState Then
        MsgBox ("V19E is off")
    Else
        ' An error results if the return value is anything other than 1 or 0
        MsgBox ("The event number specified at the argument is invalid")
    End If
End Sub
```

- **Applicable information**

DLL: Uses w\_mcrdpc.dll

Since it is using the same DLL as PCWAY, make sure to use the program that uses this function from the same directory that PCWAY is executed from.

### 7.4.3 Changing the Status of the Specified Event Number (VC Function)

---

#### PCWAYapiEventWrite

- **Function**

Change the status of the specified event number.

- **Construction**

```
short FAR PASCAL PCWAYapiEventWrite (  
char * pcEventString      // Event number  
short sOnOffSwitch        // Data value to change  
);
```

- **Parameter**

pcEventString

Specifies the character string of the event number ending with NULL.

sOnOffSwitch

Specify 1 when you want to turn the specified event on and specify 0 when you want to turn it off. If any value other than 0 or 1 is set, processes are carried out as if 1 was specified.

- **Return value**

When the event is changed as desired, 0 is returned. If an event number that does not exist is specified for the argument, -1 is returned.

- **Explanation**

Reverses the status of event 19E (V19E).

```
short sResult;  
sResult = PCWAYapiEventRead ("9E");      // Reads status of V19E  
if(1 == sResult) {                       //V19E is on  
    if(0 == PCWAYapiEventWrite("19E", 0 )) { // Turns V19E off  
        MessageBox (NULL, "Turned V19E off", "EVENT", MB_OK);  
    }  
    else  
        MessageBox (NULL, "The event number specified at the argument is invalid"  
"EVENT",MB_OK );  
}  
else if (0 == sResult) {                 // V19E is off  
    if (0 == PCWAYapiEventWrite ("19E", 1)) { // Turns V19E on  
        MessageBox (NULL, "Turned V19E on", "EVENT", MB_OK);  
    }  
    else  
        MessageBox (NULL, "The event number specified at the argument is invalid",  
"EVENT",MB_OK);  
}  
}
```

- **Applicable information**

Microsoft Visual C++: Version 6.0 or later

Header: Declared within pcwayapi.h

Import library: Uses w\_mcrdpc.lib

DLL: Uses w\_mcrdpc.dll

Since it is using the same DLL as PCWAY, make sure to use the program that uses this function from the same directory that PCWAY is executed from.

## 7.4.4 Changing the Status of the Specified Event Number (VB Function)

---

### PCWAYapiEventWrite

- **Function**

Change the status of the specified event number.

- **Construction**

PCWAYapiEventWrite (strEventNo, intModeState)

- **Configuration**

The PCWAYapiEventWrite function construction is made up of the arguments given below.

StrEventNo

Specifies the character string of the event number. Insert NULL (Chr(0)) at the end of the specified event number.

IntModeState

Specify 1 when you want to turn the specified event on, and specify 0 when you want to turn it off.

If any value other than 0 or 1 is set, processes are carried out as if 1 was specified.

- **Return value**

When the event is changed as desired, 0 is returned. If an event number that does not exist is specified for the argument, -1 is returned.

- **Explanation**

Reverses the status of event 19E (V19E).

```
Declare Function MyAppGetEventState Lib "W_MCRDPC.dll" Alias "PCWAYapiEventRead"  
(ByVal strEventNo As String) As Integer
```

```
Declare Function MyAppSetEventState Lib "W_MCRDPC.dll" Alias  
"W_MCRDPC_W_sEventWrite" (ByVal strEventNo As String, ByVal intMode As Integer) As  
Integer
```

```
Sub Macro1()  
    Dim IntEventState As Integer  
    ' Reads status of V19E  
    IntEventState = MyAppGetEventState ("19E" & Chr(0))  
    If 1 = IntEventState Then ' V19E is on  
        ' Turns V19E off  
        If 0 = MyAppSetEventState ("19E" & Chr(0), 0) Then  
            MsgBox ("Turned V19E off")  
        Else  
            MsgBox ("The event number specified at the argument is invalid")  
        End If  
    Else If 0 = IntEventState Then ' V19E is off  
        ' Turns V19E on  
        If 0 = MyAppSetEventState ("19E" & Chr(0), 1) Then  
            MsgBox ("Turned V19E on")  
        Else  
            MsgBox ("The event number specified at the argument is invalid")  
        End If  
    Else  
        MsgBox ("The event number specified at the argument is invalid")  
    End If  
End Sub
```

- **Applicable information**

DLL: Uses w\_mcrdpc.dll

Since it is using the same DLL as PCWAY, make sure to use the program that uses this function from the same directory that PCWAY is executed from.

## 7.4.5 Obtaining the Status of All Events (VC Function)

---

### PCWAYapiEventAllRead

- **Function**

Obtain the status of all events.

- **Construction**

```
short FAR PASCAL PCWAYapiEventAllRead (  
short * psEventNo //Event numbers V0 to V99F  
);
```

- **Parameter**

psEventNo

Specifies the short form 1600-piece arrangement. 1 is stored for this variable when the event is on and 0 is stored when the event is off.

- **Explanation**

The 1600 (0 to 1599) events V0 to V99F are prepared.

99F = 99 x 16 + 15 = 1599 (only the lower one digit is hexadecimal)

Reads the contents of all events (V)

```
short sEvent [1600];  
int iIndex;  
// Reads the contents of all events (V)  
PCWAYapiEventAllRead (sEvent);  
// Changes the arrangement number to "19E"  
iIndex = (19 * 16) + (('E' - 'A' + 10);  
if (1 == sEvent[iIndex])  
    MessageBox (NULL, "V19E is on", "EVENT", MB_OK);  
}  
else  
    MessageBox (NULL, "V19E is off", "EVENT", MB_OK);  
}
```

- **Applicable information**

Microsoft Visual C++: Version 6.0 or later

Header: Declared within pcwayapi.h

Import library: Uses w\_mcrdpc.lib

DLL: Uses w\_mcrdpc.dll

Since it is using the same DLL as PCWAY, make sure to use the program that uses this function from the same directory that PCWAY is executed from.

The function is not for a VB function.



## 7.5 Functions Upgraded in PCWAY Ver. 2.5

---

### 7.5.1 PCWAY macro auto record

---

- Recording new macros in Microsoft® Excel  
From the menu bar, select [Tools] -> [Macro] -> [Record New Macro].  
PCWAY macros are automatically recorded in the Microsoft® Excel macro using shortcut keys as shown below.  
Recorded macros and shortcut keys:

Run PCWAY	Ctrl + Shift + B
Exit PCWAY	Ctrl + Shift + C
Start Monitor	Ctrl + Shift + D
Stop Monitor	Ctrl + Shift + E
Download Data	Ctrl + Shift + G
Update All Sheet Data	Ctrl + Shift + H
Update Active Sheet Data	Ctrl + Shift + I
Save Excel File	Ctrl + E
Save HTML File	Ctrl + M



#### ◆ EXAMPLE

---

When [Ctrl + Shift + B], [Ctrl + Shift + D], and [Ctrl + E] are pressed in recording new macros, the following macros are automatically recorded in "Module", respectively.

```
Application.Run "PCWAYsubShellPcwayStart"  
Application.Run "PCWAYsubRunStart"  
Application.Run "PCWAYsubFileSave"
```

### 7.5.2 Available for WR, WX, WY and WL devices

---

- WR, WX, WY and WL devices can be used for [Cell Settings] and file processing.  
When [Register] is specified for [Target] in [Cell Settings], followings are added in the device code.

```
WR: Internal Relay  
WX: External Input (Can be selected only in "Read")  
WY: External Output  
WL: Link Relay
```

When "PLC" is selected for [Subject] in [File Processing], WR, WX, WY and WL are added in the [Specify partner] code.

### 7.5.3 Available for [Decimal point] ([Real number]) data

---

- Data in PLCs can be used as [Decimal point] ([Real number]) data in [Cell Settings] and file processing.

When [Register] is specified for [Target] in [Cell Settings], the following is added in [Display Method].

RAL: Real number

When [Real num.] is selected for [Access method] under the condition that the real number is specified in [File Processing], the real number data is output to the file.

([Digits after decimal point] must be specified in [File Master].)

To process the data as [Real num.] in the previous version (in other words, to display calculation results using the real number data), specify [Integer] for [Access method].



#### ◆ NOTE

---

Real number data is described in IEEE (Institute of Electrical and Electronics Engineers) format.

Therefore, valid number of digits for real number data are 6 to 7 and the data cannot be correctly displayed in the designated number of decimal places.

The value in the last number of decimal places is rounded off.

When the designated number of decimal places is not displayed correctly in Microsoft® Excel, specify the number of digits to display by selecting [Format Cells...] -> [Number] -> [Category].

### 7.5.4 High-speed data communication

---

- Reading and writing the data at higher speed by specifying [Cell Settings] and file process data in sequence.
- The number of cells to be downloaded is increased from 1024 to 8191.  
In addition, other multiple cells than the selected contiguous cells can be downloaded.

#### Comparison in reference speed

Number of data	: [Cell Settings] ([Register], 1 word) X 8191 cells (DT0 to DT8190)
C-NET connection (19200bps)	: Approx. 3 min. (Previous version) Approx. 1.5 min. (Ver. 2.5)
Ethernet connection	: Approx. 3 min. (Previous version) Approx. 45 sec. (Ver. 2.5)
Number of data	: File processing (2 words) X 256 (DT0 to DT510)
C-NET connection (19200bps)	: Approx. 8 sec. (Previous version) Approx. 1 sec. (Ver. 2.5) (The time to display file data on cells is not included for the time above.)

## PC specifications used for comparison

OS : Windows® XP Professional Version 2002  
CPU : Mobile Intel® Pentium® III  
Clock : 1200 MHz  
Memory : 512 Mb  
Microsoft® Excel : Microsoft® Excel 2000  
PLC : FP2SH



### ◆ NOTE

---

The comparison above is used as reference. Therefore, the aforementioned processing time is not necessarily guaranteed.

The processing time may vary depending on a use environment.

When a large amount of cell information setting is assigned for one book in Microsoft® Excel, the processing speed largely differs from the one shown above because memory consumption is large.

## 7.5.5 AND and OR with calculation functions

---

- Operators && and || in the previous version are processed as && (AND) and || (OR) in Ver. 2.5, respectively.  
For this operation, bit values of WR, WX, WY and WL devices in file processing can be obtained.

### Example of obtaining bit values:

When obtaining the 4<sup>th</sup> bit (R1004) of WR100 at Station No. 1

Example of entering an operation expression:

Read item X && 16 / 16

Results:

0 : R1004 is OFF

1 : R1004 is ON

## 7.5.6 Saving Microsoft® Excel books as HTML

---

- Active books can be saved as HTML by selecting one from the following three options:
  - 1) [HTML File Save] icon on the PCWAY tool bar
  - 2) PCWAY menu
  - 3) Shortcut key "Ctrl + M"

Microsoft® Excel books can also be saved as HTML by calling from the user-created macro in [Auto Macro Startup].

### Built-in macros:

File name automatically saving process: Sub PCWAYsubHTMLFileSave

File name designation saving process: Function PCWAYfncHTMLFileSaveNameType\_  
(Argument 1: As String, Argument 2: As Integer) As String


Argument 1: File name to be saved (An extension is not included.)

Argument 2: 0: Original book is saved.  
1: Original book is not saved.  
(When "Argument 1" is set but "Argument 2" is not set,  
the case "0" above is applied.)

Return value: Saved HTML file name (with full path)

### What to be careful of when saving the HTML format

1. When there happens to exist a several number of sheets in a book, it is necessary to do the settings at [Update All Sheet Data] before saving the book.

Either click the  of [Update All Sheet Data] or go to the menu bar -> [PCWAY] -> [Update All Sheet Data]

2. For a file name saved in "File name automatically saving process" above, the extension ".htm" is added to the target book name, and the file is created in the same folder as the target file. At this time, the target book is also overwritten.

To specify file names and folders, use "File name designation saving process" above.

When files and folders have already been saved as HTML automatically, they are overwritten to save.

When a book is newly created, ".xls" and ".htm" files are saved in PCWAY work folder.

### 7.5.7 Enable/Disable selection for the connecting station No. during PCWAY monitoring

---

- PLC connection can be temporarily disabled when;  
power is shut down during monitoring, or there are no PLCs which need monitoring.  
The disabled connection can also be returned to the enable connection.

#### Setting "Enable" and "Disable"

Double-click the [Connection] cell assigned in [Cell Settings]. The message saying "Is it OK to enable (disable) the designated station No?" is displayed.

When the [OK] button is pressed, the designated station number is switched to Enable/Disable.  
When the [Cancel] button is pressed, switching to Enable/Disable is not performed.



#### ◆ NOTE

---

To use this function, the PLC station No. to be connected must be specified beforehand in "Connection No." of "Operation Preferences".

This function toggles the mode enable and disable from the start of monitoring (after PCWAY is started up) until PCWAY stops.

## 7.6 Upgrade items of Ver2.74

---

- **Supports Microsoft® Windows Vista**

The PCWAY can run on Microsoft® Windows Vista.

- **Supports Microsoft® Excel 2007**

The PCWAY can run on Microsoft® Excel 2007.

- **Supports the USB for GT32**

The USB is selectable for the network type of operation preferences.

Selecting the USB for the network type enables the USB connection with PLCs connected to the GT32.

\* Only one GT32 can be connected. Multiple GT32 connected to the USB cannot be connected.

For the details, refer to the USB connection of hardware construction.

- **Supports special data registers of PLC (FP-X)**

Special data registers in the 90000s of a PLC (FP-X) can be specified by the PCWAY.

- **Supports for the equipment that does not support the monitoring command**

It can be connected to the equipment that does not support the monitoring command.

For using this function, select [Settings]→[Option] of Operation Preferences, and check the check box of [Monitoring command of MEWTOCOL is not used. ].

- **Monitoring when a password is omitted by the sheet-protection function of Microsoft® Excel**

When a password is omitted by the sheet-protection function of Microsoft® Excel, the obtained data is displayed as well as a normal sheet.

- **Provides up to the COM15 as usable COM ports for the PCWAYLogger**

For each function of PCWAYLogger, usable COM ports are provided up to the COM15 as well as the PCWAY.

- **In the PCWAYLogger function, the same COM port as the PCWAY can be used without changing the COM port setting.**

When uploading/downloading the PCWAYLogger, the COM port that is being used by the PCWAY can be automatically used by specifying -1 for the COM port.

Use the following function to get only the COM port being used by the PCWAY.

Function name: PCWAYLoggerfncGetComNo

Return value: COM port number being used by the PCWAY

For the details of the PCWAY Logger function that is available in this function, refer to 8.6 PCWAY Logger.

- **Supports to hide the bar graph message to be displayed during execution of PCWAYLogger function**

The function has been added, which hides the bar graph message to be displayed when uploading/downloading the PCWAYLogger.

For the details of the PCWAY Logger function that is available in this function, refer to 8.6 PCWAY Logger.

## Chapter 8

---

## Appendix

## 8.1 Applications

---

The application file "SampleListEng.xls" is in the Sample folder, which is included in the PCWAY-installed folder (normally, the folder is under "\Program Files\PCWAY").

Customers are requested to use the following macros on your own responsibilities.

(keyword "macro" record macro (Microsoft® Excel) etc.)

Based on the macro created from [Tools] -> [Record macro] -> [Record new macro] or etc., change the macro by typing the letters on the keyboard if necessary.

Topic 1	Automatically Starting and Finishing PCWAY	Auto Start Finish
Topic 2	Changing the Worksheet Using the Command Button	Change Sheet
Topic 3	Setting the Colors Inside the Squares on the Worksheet by Turning the PLC Relays On and Off (Part 1)	Setting Color (Part 1)
Topic 4	Setting the Colors Inside the Squares on the Worksheet by Turning the PLC Relays On and Off (Part 2)	Setting Color (Part 2)
Topic 5	Moving the Graphic Figure by the PLC Data Area	Moving Graphic
Topic 6	Displaying the Chart Using the PLC Data Area	Drawing Graph
Topic 7	Displaying the Chart Using the File Data of PCWAY	File Graph
Topic 8	Turn the Event On/Off Using the Command Button	Event Set
Topic 9	Printing Out the Report of the Contents of the Sheet	Print Out
Topic 10	Ladder sample program for ET-LAN Unit	ETLAN
Topic 11	Data downloading with Form button	DownLoad
Topic 12	Updating other data sheet from this sheet	Sheet Update
Topic 13	Saving Generation 1 file, which is accumulated in the file processing, in another file with the File Save button	File Save




## 8.2 PCWAY Manager

For those who do not want to have to go through the same procedures of adding-in PCWAY in to the Microsoft® Excel.


(However, the PCWAY manager will always be added-in.)

To add in PCWAY Manager, first click on [Add-in Registration and Control] under Tools on the Microsoft® Excel menu bar, and then press the [Reference] button and double-click on the PcwayMgr.xla file in the folder used to install PCWAY (usually this is located under \Program Files\PCWAY).

A tool bar like that shown below is displayed.



By clicking the  on the left-side, PCWAY will be added-in to the program.


By clicking the  on the right, the add-in of PCWAY will be removed.

## 8.3 PCWAY Utility

The PCWAY add-in provides you with optional tools.

To add in PCWAY Manager, first click on [Add-in Registration and Control under] Tools on the Microsoft® Excel menu bar, and then press the [Reference] button and double-click on the PcwUty.xla file in the folder used to install PCWAY (usually this is located under \Program Files\PCWAY).


A tool bar like that shown below is displayed.



[1]Utility for the changing of the node number

By clicking the  icon, the following dialog box will be displayed.


It is possible to change the node number of the cell information which has been registered at this dialogbox.



### ◆ NOTE

1. When you have registered [FF (broadcast address)] at PLC No. after the changing, only the cell registered under [WRITE Only] is valid.
2. This is not valid with the file data or the event.

[2] Saves in the CVS format the content of the Cell Settings of the Active Sheet.

By clicking the  icon, the cell information of the active sheet will be out-putted to the CSV file.

The folder which will be out-putted is the book which is currently saved, and the file name which is out-putted is the active sheet name.CSV.



---

#### ◆ NOTE

---

**Carrying out this processing on a newly created book (a book that has never been saved) creates a CSV file in the root directory. Before carrying out this processing, first save the book.**

If the CSV file that has been created is opened in Microsoft® Excel, a document is produced. To view this document, refer to the Cellinfo.xls file in the folder used to install PCWAY (usually this is located under \Program Files\PCWAY).

## 8.4 Concerning the copying of the system created with PCWAY

---

- **When copying to another folder:**

1. Create the folder where you will perform the copying to.
2. After saving and compressing the current PCWAY environment by the procedures of the Back-up Utility dialog box, please decompress this at the folder which you have created at the upper No.1 folder.  
Already the file of PCWAY is in a restoration folder, And when the file of the restoration folder is newer than the file of the backup, it is not able to restore PCWAY.  
At the time, Restore after deleting the file of PCWAY(.plc, .cmt) in a restoration folder.  
For further details **8.5 Back-up Utility**.
3. Start [Operation Preferences] of PCWAY, and change the work folder to the upper No. 1 folder.

- \* The procedures is the same as above, when copying to other personal computers.  
When there is the possibility that PCWAY has been technically versioned up, please install PCWAY in to the upper No.1 folder, after you have completed the upper No.1 and No.2 procedures.  
(The file will be converted automatically.)

- **When you will configure the system initially:**


1. Create the folder which you will perform the copying to.
2. Usually, the \PLC folder is made under \Program Files\PCWAY.  
All of the files which have been newly made are stored in to \PLC.  
Copy all of the files (of all which are new) to the upper No.1 folder.
3. Start [Operation Preferences] of PCWAY and change the work folder to the upper No.1 folder.

## 8.5 Back-up Utility


Compress and divide the currently selected file so that you can copy this to another floppy disk.

### Operating Procedures

1. Enter the [Back-up Utility] dialog box from the Windows® [Start] menu.



2. Double-click on the [Back-up Utility] option, the following dialog box is displayed.



3. Select your drive (See A) and folder (See B) where the data is stored.  
The standard method is to select the work folder at the [Operation Preferences] dialog box. In order to select your type of file, either select your target file type or input the wild card at the (See C) drop-down list box.
4. The file which is contained in the specified drive and folder will appear at the middle (See D).
5. Select the file wish you wish to back-up
  - When you wish to back-up only a certain file.  
Select up to one file at the D area and click the **Add(S) ->** button.  
With this, the selected file will be transferred to [Backup Files].  
Because files can only be selected individually, if there are several files to be backed up, repeatedly select a file and press **Add(S) ->**.
  - After you have transferred the folder, if there is a file which you wish to not back-up, select the file at [Backup Files], and click **<- Delete(D)** button.  
This will be added as a selection at the very end of the (D) area drop-down list box.

- When you wish to back-up all existing files which are displayed

Click the **Select All(A)** button. With this, the files which were displayed at the (See D) area is transferred to the [Backup Files].

- After the files are transferred, when you wish not to back-up the files all of the files at [Backup Files], then click the **Delete All(E)** button.  
With this, all of the files are transferred to the (See D) area.

6. After finishing your selecting of your files for back-up, then click the **OK(O)** button. After the compressing is finished, if one floppy disk is enough, the PCBackup.EXE file is created at the currently selected folder. If you will need more than 2 floppy disks, PCBackup.bat, PCBackup.001, PCBackup.002 files are created.

(When the PCBackup.bat, PCBackup.001 and PCBackup.002 files are created, you will need more than 2 floppy disks.  
Therefore, copy PCBackup.bat and PCBackup.001 files to the first floppy disk, and PCBackup.002 to the 2nd floppy disk.)

### In order to decompress the compressed file which you created...

- When there is only one floppy disk at this point, execute PCBackup.EXE
- When there is more than 2 floppy disks at this point, copy all of the files of the floppy disks to the hard disk and then execute PCBackup.bat

With this, the following dialog box is displayed. Select the folder which you will decompress to, and then execute.



### Item explanations

#### 1. Add

The selected file from the middle file list which is contained in the specified drive and folder is displayed at [Back Files].

#### 2. Delete

The file which is selected at the [Backup Files] area is displayed at the middle file list which is contained in the specified drive and folder.

#### 3. Select All

All of the files of the middle file list which is contained in the specified drive and the folder is displayed at the [Backup Files].

#### 4. Delete All

All of the files of [Backup Files] is displayed at the middle file list which is contained in the specified drive and folder.

#### 5. OK

All of the files of [Backup Files] is back-upped.

#### 6. Cancel

The process is ended.

## 8.6 PCWAY Logger

When you would like to access continuous area in PLC by full speed, And when you would like to read the IC Card for FP2 and the extension memory for FP  $\Sigma$ , Please use this PCWAY Logger Add-in software.

This PCWAY Logger Add-in software is need to Microsoft® Excel 97 or upper version.



### ◆ NOTE

**It is necessary to start PCWAY before you execute this Add-in software.**

**This Add-in software is not able to use any registering - module of PCWAY.(For example, "Character Changing", "Message", "Operation Formula" ,etc.)**

To add in PCWAY Logger, first click on **Add-in Registration and Control** under **Tools** on Microsoft® Excel menu bar, and then press the **Reference** button and double-click on the "PCWAY Logger.xla" file in the folder used to install PCWAY (usually this is located under \Program Files\PCWAY).

When you would like to know how to use this Add-in software, please refer to sample Macro program of "LoggerSample.xls" file. Usually, this file is located under \Program Files\PCWAY\Sample.

When you would like to execute this Macro program, it is necessary for you to register at the **Automatic Macro Startup** or relate to the button on the Microsoft® Excel Form.

Basic flow to display the PLC data to Microsoft® Excel sheet

1. Upload the data from PLC to PCWAY LOGGER Internal memory
2. Copy the value from PCWAY LOGGER Internal memory to Clipboard
3. Paste the value from Clipboard to Microsoft® Excel sheet

### PCWAY Logger function List

- Download data to the continuous area in PLC (In case of Ethernet)

Function PCWAYLoggerfncDownloadEthernet (Argument 1 As Integer, Argument 2 As String, Argument 2 As String, Argument 4 As Integer, Argument 5 As Long, Argument 6() As Integer) As Long

Argument 1	:	PLC Station No.
Argument 2	:	Device Code (WR/ WL/ DT/SV/EV/LD/FL/IC)
Argument 3	:	Device No. (If you access IC card, please design by Hexadecimal.)
Argument 4	:	File Register(FL) Bank No. (FL in FP2SH: 0/1/2, Else : -1)
Argument 5	:	Number of words
Argument 6	:	Data value
Return Value	:	0 : Normal
		-1 : Fatal Error
		-2 : PCWAY is not started.
		-3 : Device No. is out of range.
		Else: Others

- Upload data from continuous area in PLC (In case of Ethernet)

Function PCWAYLoggerfncUploadEthernet (Argument 1 As Integer, Argument 2 As String, Argument 3 As String, Argument 4 As Integer, Argument 5 As Long) As Long

Argument 1	:	PLC Station No.
Argument 2	:	Device Code (WR/ WL/ DT/SV/EV/LD/FL/IC)
Argument 3	:	Device No. (If you access IC card, please design by Hexadecimal.)
Argument 4	:	File Register(FL) Bank No. (FL in FP2SH: 0/1/2, Else : -1)
Argument 5	:	Number of words
Return Value	:	0 : Normal
		-1 : Fatal Error
		-2 : PCWAY is not started.
		-3 : Device No. is out of range.
		Else: Others

This function only store the data value in internal memory of PCWAY LOGGER. When you would like to display the data value, you have to paste function after copy to clipboard.

In case of Ethernet uses Ethernet(Local) of PCWAY.

Register the destinations to Ethernet(Local) of [Communication Settings].

• **Download data to the continuous area in PLC (Except Ethernet)**

Function PCWAYLoggerfncDownloadEX (Argument 1 As Integer, Argument 2 As Integer, Argument 3 As String, Argument 4 As String, Argument 5 As Integer, Argument 6 As Long, Argument 7() As Integer) As Long

Argument 1 : COM Port No. (1 - 5)  
Argument 2 : PLC Station No.  
Argument 3 : Device Code (WR/ WL/ DT/SV/EV/LD/FL/IC)  
Argument 4 : Device No. (If you access IC card, please design by Hexadecimal.)  
Argument 5 : File Register(FL) Bank No. (FL in FP2SH: 0/1/2, Else : -1)  
Argument 6 : Number of words  
Argument 7 : Data value  
Return Value : 0 : Normal  
                  -1 : Fatal Error  
                  -2 : PCWAY is not started.  
                  -3 : Device No. is out of range.  
                  Else: Others

• **Upload data from continuous area in PLC (Except Ethernet)**

Function PCWAYLoggerfncUploadEX(Argument 1 As Integer, Argument 2 As Integer, Argument 3 As String, Argument 4 As String, Argument 5 As Integer, Argument 6 As Long) As Long

Argument 1 : COM Port No.(1 - 5)  
Argument 2 : PLC Station No.  
Argument 3 : Device Code (WR/ WL/ DT/SV/EV/LD/FL/IC)  
Argument 4 : Device No. (If you access IC card, please design by Hexadecimal.)  
Argument 5 : File Register(FL) Bank No. (FL in FP2SH: 0/1/2, Else : -1)  
Argument 6 : Number of words  
Return Value : 0 : Normal  
                  -1 : Fatal Error  
                  -2 : PCWAY is not started.  
                  -3 : Device No. is out of range.  
                  Else: Others

This function only store the data value in internal memory of PCWAY LOGGER. When you would like to display the data value, you have to paste function after copy to clipboard.

• **Upload data from continuous area in PLC (Except Ethernet)**

Function PCWAYLoggerfncUpload(Argument 1 As Integer, Argument 2 As Integer, Argument 3 As String, Argument 4 As String, Argument 5 As Integer, Argument 6 As Long) As Long

Argument 1 : COM Port No.(1 - 5)  
Argument 2 : PLC Station No.  
Argument 3 : Device Code (WR/ WL/ DT/SV/EV/LD/FL/IC)  
Argument 4 : Device No. (If you access IC card, please design by Hexadecimal.)  
Argument 5 : File Register(FL) Bank No. (FL in FP2SH: 0/1/2, Else : -1)  
Argument 6 : Number of words  
Return Value : 0 : Normal  
                  -1 : Fatal Error  
                  -2 : PCWAY is not started.  
                  -3 : Device No. is out of range.  
                  Else: Others

This function is necessary to keep the compatible with old version.

This function only store the data value in internal memory of PCWAY LOGGER. When you would like to display the data value, you have to paste function after copy to clipboard.



### • Upload data from extension area in PLC (Except Ethernet)

Function PCWAYLoggerfncUploadMemory(Argument1 As Integer, Argument2 As Integer, Argument3 As Integer, Argument4() As Byte, Argument5() As Integer, Argument6() As Integer) As Long

Argument1 : COM Port No. (1 - 5)  
 Argument2 : PLC Station No.  
 Argument3 : SLOT No.  
 Argument4 : Read Flag 0:Not Read 1:Read  
 Argument5 : Start Address No.(0 - 1023)  
 Argument6 : Read Number( 1 - 1024)  
 Return Value : 0 : Normal  
                   -1 : Fatal Error  
                   -2 : PCWAY is not started  
                   -3 : Device No. is out of range  
                   Else : Other

You should get the area data of 256 array in Argument 4 and 5, 6.

This function only store the data value in internal memory of PCWAYLOGGER. When you would like to display the data value, you have to paste function after copy to clipboard.



### ◆ EXAMPLE

This sample displays on the cell "A1" the data that read 200 word from the address 100 in 0 - 255 even number bank of the slot 1 in PLC Unit No.1.

```
Dim bReadFlag(0 To 255) As Byte
Dim iStartAddress(0 To 255) As Integer
Dim iReadCount(0 To 255) As Integer
Dim lugReturn As Long
Dim iLoopcnt As Integer

For iLoopcnt = 0 To 255
  If iLoopcnt = 0 Then
    bReadFlag(iLoopcnt) = 1
  ElseIf (iLoopcnt Mod 2) = 0 Then
    bReadFlag(iLoopcnt) = 1
  Else
    bReadFlag(iLoopcnt) = 0
  End If
  If bReadFlag(iLoopcnt) = 1 Then
    iStartAddress(iLoopcnt) = 100
    iReadCount(iLoopcnt) = 200
  End If
Next iLoopcnt
lugReturn = Application.Run("PCWAYLoggerfncUploadMemory", 1, 1, 1, bReadFlag,
iStartAddress, iReadCount)
If lugReturn = 0 Then
  Call Application.Run("PCWAYLoggersubClipCopy", 200)
  ActiveSheet.Range("A1").Select
  ActiveSheet.Paste
  ActiveSheet.Range("A1").Select
End If
```

### • Download data to extension area in PLC (Except Ethernet)

Function PCWAYLoggerfncDownloadMemory(Argument1 As Integer, Argument2 As Integer, Argument3 As Integer, Argument4() As Byte, Argument5() As Integer, Argument6() As Integer, Argument7() As Integer) As Long

Argument1	:	COM Port No. (1 - 5)
Argument2	:	PLC Station No.
Argument3	:	SLOT No.
Argument4	:	Write Flag 0:Not Write 1:Write
Argument5	:	Start Address No.(0 - 1023)
Argument6	:	Write Number(1 - 1024)
Argument7	:	Write Data
Return Value	:	0 : Normal
		-1 : Fatal Error
		-2 : PCWAY is not started
		-3 : Device No. is out of range
		Else : Other

You should get the area data of 256 array in Argument 4 and 5, 6.



### ◆ EXAMPLE

This sample writes 200 word area to the address 100 in 0 - 255 even number bank of the slot 1 in PLC Unit No.1 after getting the data of 200 column of 128 line on the cell "A1". (Returns to the extension area the data of PCWAYLoggerfncUploadMemory example.)

```

Dim bWriteFlag(0 To 255) As Byte
Dim bStartAddress(0 To 255) As Integer
Dim bWriteCount(0 To 255) As Integer
Dim lngReturn As Long
Dim iLoopcnt As Integer
Dim iX As Integer
Dim iY As Integer
Dim iWriteData(0 To 25599) As Integer

For iY = 0 To 127
    For iX = 0 To 199
        iWriteData(iY * 200 + iX) = Val(Cells(iY + 1, iX + 1))
    Next iX
Next iY

For iLoopcnt = 0 To 255
    If iLoopcnt = 0 Then
        bWriteFlag(iLoopcnt) = 1
    ElseIf (iLoopcnt Mod 2) = 0 Then
        bWriteFlag(iLoopcnt) = 1
    Else
        bWriteFlag(iLoopcnt) = 0
    End If
    If bWriteFlag(iLoopcnt) = 1 Then
        bStartAddress(iLoopcnt) = 100
        bWriteCount(iLoopcnt) = 200
    End If
Next iLoopcnt
lngReturn = Application.Run("PCWAYLoggerfncDownloadMemory", 1, 1, 1, bWriteFlag,
bStartAddress, bWriteCount, iWriteData)

```

#### • Upload data from extension area in PLC (Ethernet)

Function PCWAYLoggerfncUploadMemory(Argument1 As Integer, Argument2 As Integer, Argument3() As Byte, Argument4() As Integer, Argument5() As Integer) As Long

Argument1 : PLC Station No.  
 Argument2 : SLOT No.  
 Argument3 : Read Flag 0:Not Read 1:Read  
 Argument4 : Start Address No.(0 - 1023)  
 Argument5 : Read Number( 1 - 1024)  
 Return Value : 0 : Normal  
                   -1 : Fatal Error  
                   -2 : PCWAY is not started  
                   -3 : Device No. is out of range  
                   Else : Other

You should get the area data of 256 array in Argument 3 and 4, 5.

This function only store the data value in internal memory of PCWAYLOGGER. When you would like to display the data value, you have to paste function after copy to clipboard.

#### • Download data to extension area in PLC (Ethernet)

Function PCWAYLoggerfncDownLoadMemory(Argument1 As Integer, Argument2 As Integer, Argument3() As Byte, Argument4() As Integer, Argument5() As Integer, Argument6() As Integer) As Long

Argument1 : PLC Station No.  
 Argument2 : SLOT No.  
 Argument3 : Write Flag 0:Not Write 1:Write  
 Argument4 : Start Address No.(0 - 1023)  
 Argument5 : Write Number(1 - 1024)  
 Argument6 : Write Data  
 Return Value : 0 : Normal  
                   -1 : Fatal Error  
                   -2 : PCWAY is not started  
                   -3 : Device No. is out of range  
                   Else : Other

You should get the area data of 256 array in Argument 3 and 4, 5.

In case of Ethernet uses Ethernet(Local) of PCWAY.

Register the destinations to Ethernet(Local) of [Communication Settings].

#### • Convert 2Word->1Word

Sub PCWAYLoggersubCnvDwordToWord(Argument1 As Long, Argument 2() As Long, Argument 3() As Integer)

Argument 1 : 2Word Access Number  
 Argument 2 : 2Word Data  
 Argument 3 : 1Word Data

1 Word data area needs the multiple area of 2 word area number.



#### ◆ EXAMPLE

Dim lngDword(0 To 99) As Long  
 Dim intData(0 To 199) As Integer

Call Application.Run("PCWAYLoggersubCnvDwordToWord", 100, lngDword(), intData())

#### • Gets the Error Message

Function PCWAYLoggerfncGetMessage( ) As String

Return value : Message

#### • Sets the Language

Sub PCWAYLoggersubSetLanguage( Argument1 As Integer )

Argument 1 : 0:Japanese 1:English

- **Copy the data value from PCWAY LOGGER internal memory to Clipboard**

(This function is not able to design the value type. Display type is only Decimal / 1 word.)

Sub PCWAYLoggersubClipCopy (Argument 1 As Long)

Argument 1 : Number of Columns in a line

- **Copy the data value from PCWAY LOGGER internal memory to Clipboard**

(This function is able to design the value type.)

Sub PCWAYLoggersubClipCopyEX(Argument 1 As Long, Argument 2 As Integer, Argument 3 As Integer)

Argument 1 : Number of Columns in a line

Argument 2 : Display method

0 : Binary

1 : Octal

2 : Decimal

3 : Hexadecimal (If there is alphabet, Alignment is left.)

4 : Hexadecimal (String type) (Adding ' before value)

5 : MEW Notation

Argument 3 : Number of bytes

1 : 1byte

2 : 1word

3 : 2words

- **Copy from PCWAY LOGGER internal memory to variable arrangement**

Sub PCWAYLoggersubGetData(Argument 1() As Integer)

Argument 3 : arrangement

- **Clear PCWAY LOGGER internal memory**

Sub PCWAYLoggersubMemoryClear()

- **Execute Communication Settings for PCWAY LOGGER**

Function PCWAYLoggerfncShowParamSetDlg()

Return Value : 0 : Normal

Others : Error

- **When PCWAY and PCWAY LOGGER use the same communication setting**

**Example 1** Read FL1000 - 5999 by using COM port

Dim lngReturn As Long

lngReturn = Application.Run("PCWAYLoggerfncUploadEX", 1, 0, "FL", "1000", -1, 5000)

<Design the same COM port using by PCWAY>

**Example 2** Read FL1000 - FL5999 by using Ethernet (Local)

Dim lngReturn As Long

lngReturn = Application.Run("PCWAYLoggerfncUploadEthernet", 1, "FL", "1000", -1, 5000)

<If PCWAY does not use this PLC station No., PCWAY LOGGER can not read.>

- **When PCWAY and PCWAY LOGGER use different port each other.**

It is necessary for you to set the communication condition by using PCWAYLoggerfncShowParamSetDlg() function.

If you execute Macro( ShowParamSet() ) which is in LoggerSample.xls file, the following dialog is appeared.

Then you can set the communication condition.

(LoggerSample.xls is usually located under \Program Files\PCWAY).

- **When PCWAY use Ethernet (Remote) and PCWAY LOGGER use Ethernet**

PCWAY LOGGER has to set Ethernet (Local) by using PCWAYLoggerfncShowParamSetDlg function.

When PCWAY LOGEER uses the same connection to PCWAY. please set the same registration of PCWAY.

When PCWAY LOGEER uses the different connection from PCWAY. please set the different registration.



## ◆ NOTE

**PCWAY LOGGER connect PLC only during uploading or downloading.  
When those operations is completed, the connection is cut off.**

- **How to use PCWAYLoggersubGetData Function**

Copy the internal value of PLC register to the variable arrangement.

**Example** Copy the value of FL 1000 - 5999 to intData()

```
Dim intData[5000] as Integer
```

```
Dim lngReturn As Long
```

```
lngReturn = Application.Run("PCWAYLoggerfncUploadEX", 1, 0, "FL", "1000", -1, 5000)
```

```
If lngReturn = 0 Then
```

```
    Application.Run("PCWAYLoggersubGetData", intData())
```

```
Else
```

```
    MsgBox "Read Error !!!"
```

```
End If
```

- **How to use PCWAYLoggersubGetDataEX function**

It is used to insert the read data of PLC into the variable in a program.

**Example** When reading and inserting the PLC's file register of 1000 to 5000 words into the variable intData sequence using the COM port

```
Dim intData As Variant
Dim lngReturn As Long
Dim lngLoop As Long

lngReturn = Application.Run("PCWAYLoggerfncUploadEX", 1, 0, "FL", "1000", -1, 5000)
If lngReturn = 0 Then
    intData = Application.Run("PCWAYLoggersubGetDataEX")
Else
    MsgBox "Read Error!!!"
Exit Sub
End If
```

' The obtained data is displayed in a message box.

```
For lngLoop = 0 To UBound(intData)
    If MsgBox( intData(lngLoop), vbOKCancel) = vbCancel Then
        Exit For
    End If
Next lngLoop
```

## 8.7 Compatibility Between Each OS and Microsoft® Excel

○: Operable

-: No guarantee of proper operation (Not supported)

Microsoft® Excel products	Windows® Vista *1	Windows® XP	Windows® 2000	Windows® 98, 98SE, ME, NT4.0
Microsoft® Excel 2007	○	○*2	-	-
Microsoft® Excel 2003	○	○	○*3	-
Microsoft® Excel 2002	-	○	○	○
Microsoft® Excel 2000	-	○	○	○
Microsoft® Excel 97	-	○	○	○
Microsoft® Excel 95	-	-	-	-

\*1 Not operable on 64-bit Windows® Vista and Windows® XP.

\*2 Microsoft® Excel2007 is supported on Windows® XP SP2 or later.

\*3 Microsoft® Excel2003 is supported on Windows® 2000 SP3 or later.

## 8.8 Compatibility Between PCWAY and Each OS

---

○: Operable

-: No guarantee of proper operation (Not supported)

PCWAY products	Windows® Vista	Windows® XP	Windows® 2000	Windows® 98, 98SE, ME, NT4.0
Ver2.7400	○	○	○	○
Ver2.7000-Ver2.7300	-	○	○	○*1
Ver2.6 series	-	○	○	○*1
Ver2.5 series	-	○	○	○*1
Ver2.4 series	-	○	○	○*1
Ver2.3 series	-	○*2	○	○*1
Ver2.1 series	-	-	○	○*1
Key unit version	4.102.5.22	4.96/4.85/ 4.102.5.22	4.02/ 4.102.5.22	4.02/ 4.102.5.22

\*1 Runs on Windows® 95 as well.

\*2 The PCWAY Ver2.33 and later versions support Windows® XP.  
(However, a difference file of the key driver is required. It can be downloaded from our website.)





## Record of changes

Manual No.	Date	Desceiption of changes
ARCT1F392E	Feb. 2004	First Edition
ARCT1F392E-2	Oct. 2005	Second Edition
ARCT1F392E-3	Jun. 2007	3rd Edition



These materials are printed on ECF pulp.  
These materials are printed with earth-friendly vegetable-based (soybean oil) ink.



Please contact .....

## Matsushita Electric Works, Ltd.

Automation Controls Company

Head Office: 1048, Kadoma, Kadoma-shi, Osaka 571-8686, Japan

Telephone: +81-6-6908-1050

Facsimile: +81-6-6908-5781

<http://www.mew.co.jp/ac/e/>

All Rights Reserved © 2007 COPYRIGHT Matsushita Electric Works, Ltd.